



ENERG

енергия · ενεργεια



PLA-M100EA2/PUZ-ZM100YDA

SEER



A+++

A++

A+

A

B

C

D

A++

kW **9,5**

SEER **7,4**

kWh/annum **448**

SCOP



A+++

A++

A+

A

B

C

D

A+

kW ×

7,8

×

SCOP ×

4,3

×

kWh/annum ×

2490

×



61dB



63dB



ENERGIA · ЕНЕРГИЯ · ΕΝΕΡΓΕΙΑ · ENERGIJA · ENERGY · ENERGIE · ENERGI

626/2011

A	Model					C	Outdoor unit		PUZ-ZM100YDA		
						B	Indoor unit 1		PLA-M100EA2		
							Indoor unit 2		-		
							Indoor unit 3		-		
							Indoor unit 4		-		
							Indoor unit 5		-		
							Indoor unit 6		-		
D	Sound Power level on cooling mode					F	Out-side	dB(A)	63		
						E	Inside 1	dB(A)	61		
							Inside 2	dB(A)	-		
							Inside 3	dB(A)	-		
							Inside 4	dB(A)	-		
							Inside 5	dB(A)	-		
							Inside 6	dB(A)	-		
G	Refrigerant *1							R32 GWP 675			
H	Cooling	SEER					7,4				
		J	Energy efficiency class				A++				
		K	Annual electricity consumption *2			kWh/a	448				
		L	Design load			kW	9,5				
							Warmer	Average	Colder		
M	Heating	SCOP					-	4,3	-		
		J	Energy efficiency class				-	A+	-		
		K	Annual electricity consumption *2			kWh/a	-	2490	-		
		L	Design load			kW	-	7,8	-		
		N	De- clared capacity	P	at reference design temperature		kW	-	7,8(-10)°C	-	
				R	at bivalent temperature		kW	-	7,8(-10)°C	-	
				S	at operation limit temperature		kW	-	5,8(-20)°C	-	
		T	Back up heating capacity			kW	-	0,0	-		

A	Deutsch	Italiano	Svenska	Polski	Eesti	Malti	Русский
	Français	Ελληνικά	Česky	Slovensko	Gaeilge	Suomi	Norsk
	Nederlands	Português	Slovensky	Български	Latviski	Türkçe	Українська
	Español	Dansk	Magyar	Română	Lietuvių k.	Hrvatski	
	Modell	Modello	Modell	Model	Model	Mudel	Модель
B	Modèle	Μοντέλο	Model	Model	Déanamh	Malli	Модель
	Model	Modelo	Model	Mogel	Models	Model	Модель
	Modelo	Model	Modell	Model	Models	Model	
	Innengerät	Unità interna	Inomhusenhet	Jednostka wewnętrzna	Siseseade	Unità għal għewwa	Внутренний прибор
	Appareil intérieur	Εσωτερική μονάδα	Vnitřní jednotka	Notranja enota	Anonad laistigh	Sisäyksikkö	Innendørsenhet
C	Binnenunit	Unidade interior	Vnútorná jednotka	Вътрешно тяло	Iekšteļu ierīce	Iç ünitesi	Внутрішній блок
	Unidad interior	Indendørsenhed	Beltéri egység	Unitate de interior	Patalpoje montuojamas įrenginys	Unutarnja jedinica	
	Außengerät	Unità esterna	Utomhusenhet	Jednostka zewnętrzna	Välisseade	Unità għal barra	Наружный прибор
	Module extérieur	Εξωτερική μονάδα	Vnější jednotka	Zunanja enota	Anonad lasmuigh	Ulkoyksikkö	Utendørsenhet
	Buitenunit	Unidade exterior	Vonkajšia jednotka	Външно тяло	Ārtpas ierīce	Diş ünitesi	Зовнішній блок
D	Unidad exterior	Utdendørsenhed	Kültéri egység	Unitate de exterior	Lauke montuojamas įrenginys	Vanjska jedinica	
	Schalleistungspegel im Kühlmodus	Livelli di potenza sonora in modalità di raffreddamento	Bulnervivā i nedkylningslāgēt	Poziom mocy dźwięku w trybie chłodzenia	Müratasemed jahutusrežiimis	Livelli tal-qawwa tal-hsejjes fil-modalità tal-ikessih	Значения уровня звуковой мощности в режиме охлаждения
	Niveaux de puissance corrects en mode de refroidissement	Επίπεδα ισχύος ήχου στην κατάσταση ψύξης	Úroveň hlúčnosti v režimu chlazení	Ravni zvočne moči v načinu hlajenja	Leibhéal chumhachta fuaimne ar mhodh fuaraithe	Äänvoimakkuustasot viilennystilassa	Lydtrykknivåer i afkølingsmodus
	Geluidsniveaus in koelstand	Níveis de potência sonora em modo de arrefecimento	Hladiny akustického výkonu v režime chladienia	Нива на звуковата мощност в режим на охлаждане	Akustiskās jaudas līmenis dzesēšanas režīmā	Soğutma modunda ses güç düzeyleri	Рівні звукової потужності у режимі охолодження
	Niveles de potencia del sonido en el modo de refrigeración	Lydstyrkeniveauer i kølefunktion	Hangnyomásszintek hűtés üzem-műban	Nivel sonor în modul de răcire	Garso galios lygis vėsinimo režimu	Razine zvučnog tlaka pri hlađenju	
E	Innen	Innsida	Innsida	Wewnętrzny	Sees	Gewwa	Внутри
	À l'intérieur	Εσωτερικό	Uvnitř	Znotraj	Laistigh	Sisäpuoli	Innvendig
	Binnenkant	Interior	Vo vnútri	Вътре	Iekšteļpās	Iç taraf	Усередині
	Interior	Indvendig	Bent	Interior	Vidinis	Unutra	
	Außen	Esterno	Utsida	Na zewnątrz	Vāļas	Barra	Снаружи
F	À l'extérieur	Εξωτερικό	Venku	Zunaj	Lasmuigh	Ulkupuoli	Utvendig
	Buitenkant	Exterior	Vonku	На открыто	Ārtpas	Diş taraf	Назовні
	Exterior	Udvendig	A szabadban	Exterior	Išorinis	Vani	

G	Deutsch	Italiano	Svenska	Polski	Eesti	Malti	Русский
	Français	Ελληνικά	Česky	Slovensko	Gaeilge	Suomi	Norsk
	Nederlands	Português	Slovensky	Български	Latviski	Türkçe	Українська
	Español	Dansk	Magyar	Română	Lietuvių k.	Hrvatski	
	Kühlmittel	Refrigerante	Köldmedel	Czynnik chłodniczy	Külmutusagens	Refrigerant	Хладагент
H	Réfrigérant	Ψυκτικό	Chladivo	Hładino sredstvo	Cuisneán	Kylmäaine	Kjølemiddel
	Koelmiddel	Refrigerante	Chladivo	Хладилен агент	Aukstumagents	Soğutucu	Холодоагент
	Refrigerante	Kølemiddel	Hűtőközeg	Refrigerent	Saldalas	Rashladno sredstvo	
	Kühlen	Raffreddamento	Kyla	Chłodzenie	Jahutus	Ikessih	Охлаждение
	Refridissement	Ψύξη	Chlazení	Hlajenje	Fuarú	Vilennys	Avkjøling
I	Koelen	Arrefecimento	Chladienie	Охлаждане	Dzesēšana	Soğutma	Охлаждения
	Refrigeración	Køling	Hűtés	Răcire	Vėsinimas	Hlađenje	
	Energieeffizienzklasse	Classe di efficienza energetica	Energiklass	Klasa energetyczna	Energiatõhususe klass	Klassi tal-effiċjenza fl-użu tal-enerġija	Класс эффективности использования энергии
	Classe d'efficacité énergétique	Κλάση ενεργειακής απόδοσης	Třída energetické účinnosti	Razred energijske učinkovitosti	Alcme éifeachtúlachta fuinnimh	Energieathokkuusluokka	Energieeffektivitetsklasse
	Energie-efficiëntieklasse	Classe de eficiéncia energética	Trieda energetickej účinnosti	Клас на енергийна ефективност	Energoefektivitātes klase	Enerji verimlilik sinifi	Клас ефективності енергоспоживання
J	Clase de eficiencia energética	Energieeffektivitetsklasse	Energiahatekonysági osztály	Klasa de eficiență energetică	Enerģijas varojimo efektyvumo klasė	Klasa energijske učinkovitosti	
	Jahresstromverbrauch *2	Consumo annuale di energia elettrica *2	Årlig strömförbrukning *2	Zużycie prądu w skali roku *2	Aastane voolutarbimus *2	Konsum annval tal-elettriku *2	Годовое потребление электроэнергии *2
	Consommation d'électricité annuelle *2	Ετήσια κατανάλωση ρεύματος *2	Roční spotřeba elektrické energie *2	Letna poraba elektrike *2	Ídú leictreachais bhílantúil *2	Vuotuinen sähkönkulutus *2	Årlig strømförbruk *2
	Jaarlijks elektriciteitsverbruik *2	Consumo anual de electricidade *2	Ročná spotreba elektriny *2	Годишна консумация на електроенергия *2	Gada elektroenerģijas patēriņš *2	Yillik elektrik tüketimi *2	Річне споживання електроенергії *2
	Consumo anual de electricidad *2	Årligt elforbrug *2	Éves áramfogyasztás *2	Consum anual de electricitate *2	Metinis elektros energijos suvartojimas *2	Godišnja potrošnja električne energije *2	
K	Lastauslegung	Carico nominale	Dimensionerande belastning	Maksimalne obciążenie	Projekteeritud koormus	Taghbiya tad-disinn	Расчетная нагрузка
	Charge de calcul	Σχεδιασμός φόρτισης	Jmenovitě zatížení	Nazivna obremenitev	Lõd deartha	Laskettu kuormitus	Utformingsbelastning
	Ontwerpbelasting	Carga nominal	Projektované zataženie	Проектен товар	Aprēķina slodze	Tasarim yūkū	Розрахунково навантаження
	Carga de diseño	Brugslast	Méretezési terhelés	Sarcinā nominalā	Projektiņe apkrova	Težina uređaja	
	Heizen (Jahresdurchschnitt)	Riscaldamento (stagione media)	Värme (genomsnittlig årstid)	Ogrzewanie (średnie temperatury)	Kütmine (keskmise hooaeg)	Tishin (Staḡun medju)	Нагрев (средний сезон)
L	Chauffage (moyenne saison)	Θέρμανση (Μέσο χρονικό διάστημα)	Topení (průměrná sezóna)	Ogrevanje (povprečni letni čas)	Téamh (meánséasúr)	Lāmmitys (vuodenajan keskiajo)	Oppvarming (gjennomsnittlig årstid)
	Verwarmen (gemiddeld seizoen)	Aquecimento (Média estação)	Vykurovanie (Priemerná sezóna)	Отопление (Среден сезон)	Sildīšana (vidējī sezonā)	Istma (Oortalama mevsimlik)	Опаления (у середний/теплый сезон)
	Calefacción (temporada promedio)	Varme (genomsnittlig säsong)	Fűtés (átlagos időjárás)	Incălzire (sezon mediu)	Šildymas (vidutinio sezono)	Zagrijavanje (prosječna sezona)	
	Nennkapazität	Capacità dichiarata	Deklarerad kapacitet	Deklarowana pojemność	Deklareeritud võimsus	Kapacitā dīkljarata	Гарантированная мощность
	Capacité déclarée	Δηλωμένη χωρητικότητα	Udāvanā kapacita	Prijavljena zmogljivost	Toileadha fógartha	Ilmoitettu teho	Erklæret kapasitet
M	Aangegeven capaciteit	Capacidade declarada	Deklarovaný výkon	Объявлена мощность	Deklarētā jauda	Beyan edilen kapasite	Гарантована потужність
	Capacidad declarada	Erklæret kapacitet	Névléges teljesítmény	Capacitate declarată	Deklaruotasis pajūgumas	Deklarirani kapacitet	
	bei angegebener Referenztemperatur	alla temperatura di progetto di riferimento	vid dimensionerande referenstemp-eratur	w znamionowej temperaturze odniesienia	projekteerimise võrdlustemperatu-uri juures	f'temperatura tad-disinn ta' referenza	при эталонной расчетной температуре
	à la température de calcul de référence	σε θερμοκρασία σχεδιασμού αναφοράς	při referenční výpočtové teplotě	ob referenční nazivni temperaturi	ag teocht deartha tagartha	perusmitoitulustämpötilassa	ved referansetemperatur for utforming
	bij referentiewerptemperatuur	à temperatura nominal de referència	při referenční výpočtové teplotě	при изчислителна проектна температура	aprēķina references temperatūrā	referans tasarim sıcaklığında	При эталонной розрахунковий температурі
N	a temperatura de diseño de referencia	ved brugsafhængig referencetem-peratur	tervezési referencia-hőmérsékleten	la temperatura de referință nominală	esant norminei projeklinei temperatūrai	f'temperatura bivalenti	при бивалентной температуре
	bei bivalenter Temperatur	alla temperatura bivalente	vid bivalent temperatur	w temperaturze bivalentnej	bivalentse temperatuuri juures	f'temperatura bivalenti	при бивалентной температуре
	à température bivalente	σε θερμοκρασία δισθενούς λειτουργίας	při bivalentní teplotě	při bivalentní temperaturi	ag teocht dhéifhúsach	kaksiarvoisessa lämpötilassa	ved bivalent temperatur
	bij bivalente temperatuur	à temperatura bivalente	při bivalentnej teplotě	при бивалентна температура	bivalentā temperatūrā	iki değeriñ sıcaklığında	При бивалентній температурі
	a temperatura bivalente	ved bivalent temperatur	bivalens hömērsékleten	la temperatura de bivalentē	esant perējimo i dvejopo šildymo režimą temperatūrai	při bivalentnoj temperaturi	
O	bei Temperatur an der Betriebs-grenze	alla temperatura limite di funzio-namento	vid drifttemperatursens grānsvārdē	w granicznej temperaturze roboczej	tõõlamise piirtemperatuuri juures	f'temperatura tal-limitu tat-thaddim	при предельной рабочей температуре
	à température de fonctionnement limite	σε θερμοκρασία ορίου λειτουργίας	při teplotě na hranici provozního limitu	při mejni delovni temperaturi	ag teocht teorann oibrúcháin	toimintarajalaämpötilassa	ved temperatur for driftsgrense
	bij grens werkingstemperatuur	à temperatura de limite de funci-onamento	při hraničné prevádzkovej teplotě	при гранична работна температура	ekspluatācijas robežtemperatūrā	çalışma limiti sıcaklığında	При граничный рабочий температурі
	a temperatura limite de funcion-amiento	ved driftsgrænsetemperatur	maximális üzemi hőmérsékleten	la temperatura limită de funci-onare	esant ribinei veikimo temperatūrai	při graničnoj radnoj temperaturi	
	Backup-Heizleistung	Capacità di riscaldamento addi-zionale	Kapacitet för reservvärme	Zapasowa pojemność grzewcza	Tagavara küttevõimsus	Kapacitā tat-tishin ta' sostenn	Резервная тепловая мощность
P	Capacité de chauffage d'appoint	Δυνατότητα επεδερικής θέρμανσης	Kapacita záložního vytápění	Rezerвна zmogljivost ogrevanja	Toileadha téimh chúlta	Varalämmitysteho	Sikkerhedskapasitet for oppvarm-ing
	Reserveverwarmingscapaciteit	Capacidade de aquecimento de reserva	Výkon záložného vykurovacieho telesa	Мощност на спомагателно електрическо подгряване	Rezerves sildītāja jauda	Yedek ısıtma kapasitesi	Резервна теплова потужність
	Capacidad de calefacción auxiliar	Reservevarmekapacitet	Kiegészítő fűtési teljesítmény	Capacitate de încălzire de siguranță	Pagalbinio šildymo pajūgumas	Kapacitet rezervnog grijanja	

2. Стимуляційні енергії за даними стандартних клітин. І хоча це стимуляційні енергії дуже загальні і від того, як користувачся приладом і до чого він поставлений.

PRODUCT INFORMATION (*1)

INDOOR MODEL 1/2/3	PLA-M100EA2/-/-
PACKAGED AIR CONDITIONER INDOOR MODEL 4/5/6	-/-/-
OUTDOOR MODEL	PUZ-ZM100YDA

Function (indicate if present)	
cooling	Y
heating	Y

Item	symbol	value	unit
Design load			
cooling	Pdesignc	9,5	kW
heating/Average	Pdesignh	7,8	kW
heating/Warmer	Pdesignh	x	kW
heating/Colder	Pdesignh	x	kW

Declared capacity for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj			
Tj=35°C	Pdc	9,50	kW
Tj=30°C	Pdc	7,00	kW
Tj=25°C	Pdc	4,50	kW
Tj=20°C	Pdc	4,40	kW

Declared capacity for heating/Average season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	Pdh	6,90	kW
Tj=2°C	Pdh	4,20	kW
Tj=7°C	Pdh	2,70	kW
Tj=12°C	Pdh	2,40	kW
Tj=bivalent temperature	Pdh	7,80	kW
Tj=operating limit	Pdh	5,80	kW

Declared capacity for heating/Warmer season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=2°C	Pdh	x	kW
Tj=7°C	Pdh	x	kW
Tj=12°C	Pdh	x	kW
Tj=bivalent temperature	Pdh	x	kW
Tj=operating limit	Pdh	x	kW

Declared capacity for heating/Colder season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	Pdh	x	kW
Tj=2°C	Pdh	x	kW
Tj=7°C	Pdh	x	kW
Tj=12°C	Pdh	x	kW
Tj=bivalent temperature	Pdh	x	kW
Tj=operating limit	Pdh	x	kW
Tj=-15°C	Pdh	x	kW

Bivalent temperature			
heating/Average	Tbiv	-10	°C
heating/Warmer	Tbiv	x	°C
heating/Colder	Tbiv	x	°C

Cycling interval capacity			
for cooling	Pcycc	x	kW
for heating	Pcyh	x	kW
Degradation co-efficient cooling	Cdc	0,25	-

Electric power input in power modes other than 'active mode'			
off mode	POFF	22	W
standby mode	PSB	22	W
thermostat - off mode	PTO(c/h)	3 / 43	W
crankcase heater mode	PCK	0	W

Capacity control (indicate one of three options)	
fixed	N
staged	N
variable	Y

If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.

Average (mandatory)	Y
Warmer (if designated)	N
Colder (if designated)	N

Item	symbol	value	unit
Seasonal efficiency			
cooling	SEER	7,4	-
heating/Average	SCOP/A	4,3	-
heating/Warmer	SCOP/W	x	-
heating/Colder	SCOP/C	x	-

Declared energy efficiency ratio, at indoor temperature 27(19) °C and outdoor temperature Tj			
Tj=35°C	EERd	4,30	-
Tj=30°C	EERd	6,20	-
Tj=25°C	EERd	10,00	-
Tj=20°C	EERd	12,90	-

Declared coefficient of performance/Average season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	COPd	2,90	-
Tj=2°C	COPd	4,20	-
Tj=7°C	COPd	5,90	-
Tj=12°C	COPd	7,10	-
Tj=bivalent temperature	COPd	2,30	-
Tj=operating limit	COPd	1,90	-

Declared coefficient of performance/Warmer season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=2°C	COPd	x	-
Tj=7°C	COPd	x	-
Tj=12°C	COPd	x	-
Tj=bivalent temperature	COPd	x	-
Tj=operating limit	COPd	x	-

Declared coefficient of performance/Colder season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	COPd	x	-
Tj=2°C	COPd	x	-
Tj=7°C	COPd	x	-
Tj=12°C	COPd	x	-
Tj=bivalent temperature	COPd	x	-
Tj=operating limit	COPd	x	-
Tj=-15°C	COPd	x	-

Operating limit temperature			
heating/Average	Tol	-20	°C
heating/Warmer	Tol	x	°C
heating/Colder	Tol	x	°C

Cycling interval efficiency			
for cooling	EERcyc	x	-
for heating	COPcyc	x	-
Degradation co-efficient heating	Cdh	0,25	-

Annual electricity consumption			
cooling	QCE	448	kWh/a
heating/Average	QHE	2490	kWh/a
heating/Warmer	QHE	x	kWh/a
heating/Colder	QHE	x	kWh/a

Other items			
Sound power level (indoor model 1/2/3/4/5/6)	LWA	61/-/- -/-/-	dB(A)
Sound power level (outdoor model)	LWA	63	dB(A)
Global warming potential	GWP (*2)	675	kgCO2eq.
Rated air flow (indoor model 1/2/3/4/5/6)	-	1740/-/- -/-/-	m3/h
Rated air flow (outdoor model)	-	4800	m3/h

Contact details for obtaining more information	MITSUBISHI ELECTRIC CORPORATION SHIZUOKA WORKS 3-18-1, Oshika, Suruga-ku, Shizuoka 422-8528, Japan E-mail: melshierp@MitsubishiElectric.co.jp
--	---

(*1) This information is based on the "product information requirement" in COMMISSION REGULATION (EU) No206/2012.

(*2) This GWP value is based on Regulation(EU)No.517/2014 from IPCC 4th Assessment Report.

For Regulation (EU) No. 626/2001, which cites the IPCC Third Assessment Report, Climate Change 2001, the GWP is 550.

TECHNICAL DOCUMENTATION (1)

PACKAGED AIR CONDITIONER	INDOOR MODEL 1	PLA-M100EA2	298H840W840D (mm)
	INDOOR MODEL 2	-	-
	INDOOR MODEL 3	-	-
	INDOOR MODEL 4	-	-
	INDOOR MODEL 5	-	-
	INDOOR MODEL 6	-	-
	OUTDOOR MODEL	PUZ-ZM100YDA	870H1100W460D (mm)

Function	
cooling	Y
heating	Y

The heating season	
Average (mandatory)	Y
Warmer (if designated)	N
Colder (if designated)	N

Capacity control	
fixed	N
staged	N
variable	Y

item	symbol	value	unit
Seasonal efficiency (2)			
cooling	SEER	7,4	-
heating/Average	SCOP/A	4,3	-
heating/Warmer	SCOP/W	x	-
heating/Colder	SCOP/C	x	-

Energy efficiency class			
cooling	SEER	A++	-
heating/Average	SCOP/A	A+	-
heating/Warmer	SCOP/W	x	-
heating/Colder	SCOP/C	x	-

Other items			
Sound power level (indoor model 1/2/3/4/5/6)	LWA	61/-/-/-/-	dB(A)
Sound power level (outdoor model)	LWA	63	dB(A)
Refrigerant	-	R32	-
Global warming potential	GWP (3)	675	kgCO2eq.

identification and signature of the person empowered to bind the supplier	
	Kunihiro Morishita Department Manager, Quality Assurance Department MITSUBISHI ELECTRIC CONSUMER PRODUCTS (THAILAND) CO.,LTD

(1) This information is based on COMMISSION DELEGATED REGULATION (EU)No626/2011.

(2) SEER/SCOP values are measured based on EN 14825:2016: Testing and rating at part load conditions and calculation of seasonal performance.

(3) This GWP value is based on Regulation(EU)No.517/2014 from IPCC 4th Assessment Report.

For Regulation (EU) No. 626/2001, which cites the IPCC Third Assessment Report, Climate Change 2001, the GWP is 550.