

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Ecodan Zubadan 14-200D Packaged	Reg. No.	037-0035-20
Certificate Holder			
Name	Mitsubishi Electric Air Conditioning Systems Europe LTD		
Address	Nettlehill Road, Houston Industrial Estate	Zip	EH54 5EQ
City	Livingston	Country	United Kingdom
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Name of testing laboratory	Universität Stuttgart, IGE, Prüfstelle HLK		
Subtype title	Ecodan Zubadan 14-200D Packaged		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	3.3 kg		
Certification Date	27.07.2020		
Testing basis	HP Keymark scheme rules rev. no. 6		

Model: PUZ-HWM140VHA(-BS) + EHPX-VM*D

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67
Indoor water flow rate	2.41 m ³ /h	1.51 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	176 %	132 %
Prated	14.00 kW	14.00 kW
SCOP	4.47	3.37
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.40 kW	12.40 kW
COP Tj = -7°C	2.55	1.98
Cdh	1.00	1.00
Pdh Tj = +2°C	7.50 kW	7.50 kW
COP Tj = +2°C	4.41	3.25
Cdh	0.99	0.99
Pdh Tj = +7°C	4.90 kW	5.10 kW
COP Tj = +7°C	6.28	4.64
Cdh	0.98	0.99

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	5.70 kW	5.20 kW
COP Tj = 12°C	7.43	6.24
Cdh	0.98	0.98
Pdh Tj = Tbiv	12.40 kW	12.40 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL	13.90 kW	13.90 kW
COP Tj = TOL	2.40	1.75
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.39 kW	1.39 kW
Annual energy consumption Qhe	6464 kWh	8591 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

	Low temperature	Medium temperature
η_s	227 %	132 %
Prated	14.00 kW	14.00 kW
SCOP	5.75	4.07
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14.00 kW	14.00 kW
COP Tj = +2°C	3.15	1.94
Cdh	1.00	1.00
Pdh Tj = +7°C	9.00 kW	9.00 kW
COP Tj = +7°C	5.10	3.25
Cdh	0.99	1.00
Pdh Tj = 12°C	5.50 kW	5.20 kW
COP Tj = 12°C	7.43	5.91
Cdh	0.98	0.98
Pdh Tj = Tbiv	14.00 kW	14.00 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL	13.90 kW	13.90 kW
COP Tj = TOL	3.14	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 17 Dec 2020

Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3252 kWh	4593 kWh

Model: PUZ-HWM140VHA(-BS) + ERPT20X-VM*D

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67
Indoor water flow rate	2.41 m ³ /h	1.51 m ³ /h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	178 %	133 %
Prated	14.00 kW	14.00 kW
SCOP	4.51	3.39
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.40 kW	12.40 kW
COP Tj = -7°C	2.55	1.98
Cdh	1.00	1.00
Pdh Tj = +2°C	7.50 kW	7.50 kW
COP Tj = +2°C	4.41	3.25
Cdh	0.99	0.99
Pdh Tj = +7°C	4.90 kW	5.10 kW
COP Tj = +7°C	6.28	4.64
Cdh	0.98	0.99

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	5.70 kW	5.20 kW
COP Tj = 12°C	7.43	6.24
Cdh	0.98	0.98
Pdh Tj = Tbiv	12.40 kW	12.40 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL	13.90 kW	13.90 kW
COP Tj = TOL	2.40	1.75
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.39 kW	1.39 kW
Annual energy consumption Qhe	6464 kWh	8591 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	232 %	133 %
Prated	14.00 kW	14.00 kW
SCOP	5.87	4.13
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14.00 kW	14.00 kW
COP Tj = +2°C	3.15	1.94
Cdh	1.00	1.00
Pdh Tj = +7°C	9.00 kW	9.00 kW
COP Tj = +7°C	5.10	3.25
Cdh	0.99	1.00
Pdh Tj = 12°C	5.50 kW	5.20 kW
COP Tj = 12°C	7.43	5.91
Cdh	0.98	0.98
Pdh Tj = Tbiv	14.00 kW	14.00 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL	13.90 kW	13.90 kW
COP Tj = TOL	3.14	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 17 Dec 2020

Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	3252 kWh	4593 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.07
Heating up time	1:46 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	152 %
COP	3.58
Heating up time	1:34 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l