

This information was downloaded from the HP KEYMARK database on 24 Sep 2020

Summary of	Ecodan Eco Inverter 4-200D	Reg. No.	037-0008-19
Certificate Holder			
Name	Mitsubishi Electric Air Conditioning Systems Europe LTD		
Address	Nettlehill Road, Houston Industrial Estate	Zip	EH54 5EQ
City	Livingston	Country	United Kingdom
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Name of testing laboratory	Heat Pump Test Center WPZ, Switzerland		
Subtype title	Ecodan Eco Inverter 4-200D		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	HFC-32		
Mass Of Refrigerant	1.2 kg		
Certification Date	15.10.2019		
Testing basis	HP Keymark scheme rules rev. no. 6		

## Model: SUZ-SWM40VA + ERST20D-VM\*D

### General Data

Power supply	1x230V 50Hz
--------------	-------------

### Average Climate

#### EN 14825

	Low temperature	Medium temperature
$\eta_s$	187 %	132 %
Prated	5.10 kW	4.60 kW
SCOP	4.75	3.39
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	4.50 kW	4.10 kW
COP Tj = -7°C	2.92	2.04
Cdh	0.99	0.99
Pdh Tj = +2°C	2.70 kW	2.50 kW
COP Tj = +2°C	4.58	3.25
Cdh	0.97	0.98
Pdh Tj = +7°C	2.60 kW	2.60 kW
COP Tj = +7°C	6.50	4.64
Cdh	0.96	0.97

This information was downloaded from the HP KEYMARK database on 24 Sep 2020

Pdh Tj = 12 °C	2.60 kW	2.30 kW
COP Tj = 12 °C	8.97	6.57
Cdh	0.94	0.95
Pdh Tj = Tbiv	4.50 kW	4.10 kW
COP Tj = Tbiv	2.92	2.04
Pdh Tj = TOL	4.50 kW	4.10 kW
COP Tj = TOL	2.59	1.83
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.70 kW	0.50 kW
Annual energy consumption Qhe	2198 kWh	2788 kWh

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

## Heating

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	4.00 kW	4.50 kW
El input	0.77 kW	1.75 kW
COP	5.20	2.57
Indoor water flow rate	0.69 m <sup>3</sup> /h	0.48 m <sup>3</sup> /h

<b>EN 14511-4</b>	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	159 %
COP	3.80
Heating up time	02:51 h:min
Standby power input	24.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

## Model: SUZ-SWM40VA + ERSD-VM\*D

### General Data

Power supply	1x230V 50Hz
--------------	-------------

### Average Climate

#### EN 14825

	Low temperature	Medium temperature
$\eta_s$	187 %	132 %
Prated	5.10 kW	4.60 kW
SCOP	4.75	3.39
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	4.50 kW	4.10 kW
COP Tj = -7°C	2.92	2.04
Cdh	0.99	0.99
Pdh Tj = +2°C	2.70 kW	2.50 kW
COP Tj = +2°C	4.58	3.25
Cdh	0.97	0.98
Pdh Tj = +7°C	2.60 kW	2.60 kW
COP Tj = +7°C	6.50	4.64
Cdh	0.96	0.97

This information was downloaded from the HP KEYMARK database on 24 Sep 2020

Pdh Tj = 12 °C	2.60 kW	2.30 kW
COP Tj = 12 °C	8.97	6.57
Cdh	0.94	0.95
Pdh Tj = Tbiv	4.50 kW	4.10 kW
COP Tj = Tbiv	2.92	2.04
Pdh Tj = TOL	4.50 kW	4.10 kW
COP Tj = TOL	2.59	1.83
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.70 kW	0.50 kW
Annual energy consumption Qhe	2198 kWh	2788 kWh

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

## Heating

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	4.00 kW	4.50 kW
El input	0.77 kW	1.75 kW
COP	5.20	2.57
Indoor water flow rate	0.69 m <sup>3</sup> /h	0.48 m <sup>3</sup> /h

<b>EN 14511-4</b>	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed