

MITSUBISHI ELECTRIC CORPORATION AIR-CONDITIONING & REFRIGERATION SYSTEMS WORKS

5-66, TEBIRA 6 CHOME, WAKAYAMA-CITY 640-8686, JAPAN PHONE: +81-73-428-9047 FAX: +81-73-428-9002

DECLARATION OF CONFORMITY

(for PED)

We declare that the design manufacturing and inspection of the pressure equipment described following is in conformity with the provisions of annex I of the Directive 2014/68/EU referred to as the Pressure Equipment Directive.

Name of Manufacturer

: MITSUBISHI ELECTRIC CORPORATION

AIR-CONDITIONING AND REFRIGERATION SYSTEMS WORKS

Address

: 6-5-66 TEBIRA WAKAYAMA-CITY 640-8686, JAPAN

Product name

: Hydro Unit

Model names

: CMH-WM250/350/500-A

Brand name

: MITSUBISHI ELECTRIC

Reference of the Directive

: 2014/68/EU Pressure Equipment Directive

Category & Applied conformity assessment procedure:

Equipment	Category	Conformity Assessment Module	Notified Body ID	Remark
Unit Assembly	П	A2	0035	
Heat Exchanger	11	Н	1155	
Pressure Switch	- 11	D1	0035	
Unit Assembly	III	B(Production)+C2	0035	for 500 model
Heat Exchanger	III	H1	1155	for 500 model
Pressure Switch	IV	B(Production)+D	0035	for 500 model

Nortified body 0035: TÜV Rheinland Industrie Service GmbH

Am Grauen Stein, D-51105 Cologne, Germany

Certification No.: 01 202 J/Ü-

Nortified body 1155: SGS Portugal, S.A.

Polo Tecnologico, 1600-546 Lisboa - Portugal

Certification No.: PTC17.00920.5120, PTC17.00921.5120

Reference of the other Directive : 2004/108/EC

Electromagnetic Compatibility

2006/95/EC

Low Voltage

2011/65/EU

Restriction of Hazardous Substances

Refer to DoC: EU19001*

13. Nov. 2019	Miroshi nakata
(date of issue)	Hiroshi Nakata
	Manager
	Quality Assurance Department
(date of revision)	