


Équipements sous pression

Annexe - Données détaillées

PUHY-HP200/250YNW-A



30 juillet 2024

		PUHY-HP200YNW-A	PUHY-HP250YNW-A
		8CV	10CV
Refrigerant	Type	R410A	R410A
Compressor	Model	HNK68	HNK97
	PS[bar]	22,1	22,1
	V[L]	5,2	5,2
	PS*V	114,9	114,9
	Category	I	I
	Approval	These parts (less than Category I) are excluded from the scope of PED by Article 1 clause 3.6. These parts are included in the air conditioner and the air conditioner is covered by Low	
Oil separator	PS[bar]	41,5	41,5
	V[L]	1,1	1,3
	PS*V	45,7	54
	Category	0	0
	Approval	These parts (less than Category I) are excluded from the scope of PED by Article 1 clause 3.6. These parts are included in the air conditioner and the air conditioner is covered by Low	
Accumulator	PS[bar]	22,1	22,1
	V[L]	34,6	34,6
	PS*V	764,7	764,7
	Category	II	II
	Approval	TUV Rheinland approval	
High pressure switch	PS[bar]	41,5	41,5
	DN[φ]	22,6	22,6
	PS*DN	937,9	937,9
	Category	IV⇒ II	IV⇒ II
	Approval	TUV Rheinland and DIN approval	
Heatexchanger	PS[bar]	41,5	41,5
	DN[φ]	< 7,94	< 7,94
	PS*DN	< 329,5	< 329,5
	Category	0	0
Pipe	PS[bar]	41,5	41,5
	DN[φ]	< 28,6	< 28,6
	PS*DN	< 1186,9	< 1186,9
	Category	I	I
Approval	These parts (less than Category I) are excluded from the scope of PED by Article 1 clause 3.6. These parts are included in the air conditioner and the air conditioner is covered by Low		
Check joint	PS[bar]	41,5	41,5
	DN[φ]	6,35	6,35
	PS*DN	263,5	263,5
	Category	0	0
Check valve	PS[bar]	41,5	41,5
	DN[φ]	22,2	22,2
	PS*DN	921,3	921,3
	Category	0	0
Solenoid valve	PS[bar]	41,5	41,5
	DN[φ]	11	11
	PS*DN	456,5	456,5
	Category	0	0
Solenoid valve	PS[bar]	41,5	41,5
	DN[φ]	18	18
	PS*DN	747	747
	Category	0	0
Solenoid valve	PS[bar]	41,5	41,5
	DN[φ]	11,3	11,3
	PS*DN	469	469
	Category	0	0
Solenoid valve	PS[bar]	41,5	41,5
	DN[φ]	11	11
	PS*DN	456,5	456,5
	Category	0	0
4-way valve	PS[bar]	41,5	41,5
	V[L]	< 1,7	< 1,7
	PS*V	< 70,6	< 70,6
	Category	0	0
Linear expansion valve1	PS[bar]	41,5	41,5
	DN[φ]	17,3	17,3
	PS*DN	718	718
	Category	0	0
Linear expansion valve2	PS[bar]	41,5	41,5
	DN[φ]	21,75	21,75
	PS*DN	902,6	902,6
	Category	0	0
Strainer	PS[bar]	41,5	41,5
	DN[φ]	25,4	25,4
	PS*DN	1054,1	1054,1
	Category	I	I
Sub cool coil	PS[bar]	41,5	41,5
	DN[φ]	19,05	19,05
	PS*DN	790,6	790,6
	Category	0	0