

English

Single View for Model

SUBTYPE

Ecodan Power Inverter (TR) 14 + 200F AA

Heat Pump Type: Outdoor Air/Water

APPLICANT

Mitsubishi Electric Air Conditioning Systems Europe LTD
 Nettlehill Road, Houston Industrial Estate
 EH54 5EQ Livingston
 United Kingdom

CERTIFICATION BODY

SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)
 Hudcova 424/56b
 621 00 Brno
 Czech Republic

PUZ-SWM140YAA + ERSF-*M*E

Configure model

Model name	PUZ-SWM140YAA + ERSF-*M*E
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	12 kW	7 kW
El input	2.52 kW	2.59 kW
COP	4.77	2.7

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2			
	+7°C/+12°C	+18°C/+23°C	
El input	4.77 kW	3.73 kW	
Cooling capacity	12.5	14	
EER	2.62	3.75	
EN 14825			
	+7°C/+12°C	+18°C/+23°C	
Pdesignc	12.5 kW	14 kW	
SEER	3.58	4.85	
Pdc Tj = 35°C	12.5 kW	14 kW	
EER Tj = 35°C	2.62	3.75	
Cdc Tj = 35 °C	0.995	0.994	
Pdc Tj = 30°C	9.21 kW	10.32 kW	
EER Tj = 30°C	3.47	4.93	
Cdc Tj = 30 °C	0.992	0.989	
Pdc Tj = 25°C	6 kW	6.63 kW	
EER Tj = 25°C	4.2	5.1	
Cdc Tj = 25 °C	0.985	0.983	
Pdc Tj = 20°C	3.7 kW	4.7 kW	
EER Tj = 20°C	3.49	5.4	
Cdc Tj = 20 °C	0.979	0.975	
Poff	22 W	22 W	
PTO	22 W	22 W	
PSB	22 W	22 W	
PCK	0 W	0 W	
Annual energy consumption Qce	2095 kWh	1731 kWh	

Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	41 dB(A)	41 dB(A)	
Sound power level outdoor	58 dB(A)	58 dB(A)	
EN 14825			
	Low temperature	Medium temperature	
η_s	177 %	135 %	

Prated	14 kW	14 kW
SCOP	4.51	3.46
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.7	1.98
Cdh Tj = -7 °C	0.995	0.996
Pdh Tj = +2°C	7.6 kW	7.5 kW
COP Tj = +2°C	4.54	3.43
Cdh Tj = +2 °C	0.987	0.99
Pdh Tj = +7°C	6.4 kW	6.3 kW
COP Tj = +7°C	5.91	4.61
Cdh Tj = +7 °C	0.98	0.984
Pdh Tj = 12°C	4.1 kW	3.9 kW
COP Tj = 12°C	7.03	6.28
Cdh Tj = +12 °C	0.962	0.965
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.7	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11 kW	11 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.995	0.997
WTOL	70 °C	70 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3 kW	3 kW
Annual energy consumption Qhe	6415 kWh	8354 kWh

[Back](#)
[Show Subtype](#)