

English

Single View for Model

SUBTYPE

Ecodan Power Inverter (TR) 6/8/10 + 300F AA

Heat Pump Type: Outdoor Air/Water

APPLICANT

Mitsubishi Electric Air Conditioning Systems Europe LTD
 Nettlehill Road, Houston Industrial Estate
 EH54 5EQ Livingston
 United Kingdom

CERTIFICATION BODY

SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)
 Hudcova 424/56b
 621 00 Brno
 Czech Republic

PUZ-SWM80VAA + ERST30F-*M*E

Configure model

Model name	PUZ-SWM80VAA + ERST30F-*M*E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	6 kW	4 kW
El input	1.2 kW	1.6 kW
COP	5.02	2.5

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2			
	+7°C/+12°C	+18°C/+23°C	
El input	2.15 kW	1.62 kW	
Cooling capacity	7.1	8	
EER	3.3	4.95	
EN 14825			
	+7°C/+12°C	+18°C/+23°C	
Pdesignc	7.1 kW	8 kW	
SEER	4.13	5.74	
Pdc Tj = 35°C	7.1 kW	8 kW	
EER Tj = 35°C	3.3	4.95	
Cdc Tj = 35 °C	0.993	0.991	
Pdc Tj = 30°C	5.23 kW	5.92 kW	
EER Tj = 30°C	3.85	5.7	
Cdc Tj = 30 °C	0.989	0.986	
Pdc Tj = 25°C	3.36 kW	3.79 kW	
EER Tj = 25°C	4.55	6	
Cdc Tj = 25 °C	0.98	0.976	
Pdc Tj = 20°C	2.5 kW	3.5 kW	
EER Tj = 20°C	4.69	6.75	
Cdc Tj = 20 °C	0.972	0.971	
Poff	15 W	15 W	
PTO	15 W	15 W	
PSB	15 W	15 W	
PCK	0 W	0 W	
Annual energy consumption Qce	1031 kWh	836 kWh	

Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	41 dB(A)	41 dB(A)	
Sound power level outdoor	54 dB(A)	54 dB(A)	
EN 14825			
	Low temperature	Medium temperature	
η_s	184 %	130 %	

Prated	8 kW	8 kW
SCOP	4.68	3.34
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.08 kW	7.08 kW
COP Tj = -7°C	3.22	2.27
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.4 kW	4.4 kW
COP Tj = +2°C	4.78	3.2
Cdh Tj = +2 °C	0.984	0.989
Pdh Tj = +7°C	5 kW	4.4 kW
COP Tj = +7°C	5.61	4.18
Cdh Tj = +7 °C	0.983	0.986
Pdh Tj = 12°C	3 kW	2.8 kW
COP Tj = 12°C	6.19	5.79
Cdh Tj = +12 °C	0.969	0.969
Pdh Tj = Tbiv	7.08 kW	7.08 kW
COP Tj = Tbiv	3.2	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.5 kW	7.4 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	1.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.995	0.996
WTOL	70 °C	70 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.5 kW	0.6 kW
Annual energy consumption Qhe	3528 kWh	4952 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	XL
Efficiency η_{DHW}	130 %
COP	3.14

Heating up time	2:42 h:min
Standby power input	44.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

[Back](#)[Show Subtype](#)