


AIR CONDITIONING SYSTEMS

CITY MULTI



DATA BOOK

MODEL

PURY-P200-1100Y(S)NW-A2/TR2/RU2 (-BS)



Line-up of Outdoor Units of R410A CITY MULTI
Heat Recovery R2-Series



PURY-P200YNW-A2/TR2/RU2(-BS) PURY-P250YNW-A2/TR2/RU2(-BS)
PURY-P300YNW-A2/TR2/RU2(-BS)

8, 10, 12HP



PURY-P350YNW-A2/TR2/RU2(-BS) PURY-P400YNW-A2/TR2/RU2(-BS)
PURY-P450YNW-A2/TR2/RU2(-BS)

14, 16, 18HP



PURY-P500YNW-A2/TR2/RU2(-BS) PURY-P550YNW-A2/TR2/RU2(-BS)

20, 22HP




PURY-P400YSNW-A2/TR2/RU2(-BS) PURY-P450YSNW-A2/TR2/RU2(-BS)
PURY-P500YSNW-A2/TR2/RU2(-BS) PURY-P550YSNW-A2/TR2/RU2(-BS)
PURY-P600YSNW-A2/TR2/RU2(-BS)

16, 18, 20, 22, 24HP



PURY-P650YSNW-A2/TR2/RU2(-BS)

26HP




PURY-P700YSNW-A2/TR2/RU2(-BS) PURY-P750YSNW-A2/TR2/RU2(-BS)
PURY-P800YSNW-A2/TR2/RU2(-BS) PURY-P850YSNW-A2/TR2/RU2(-BS)
PURY-P900YSNW-A2/TR2/RU2(-BS)

28, 30, 32, 34, 36HP



PURY-P950YSNW-A2/TR2/RU2(-BS)

38HP



PURY-P1000YSNW-A2/TR2/RU2(-BS) PURY-P1050YSNW-A2/TR2/RU2(-BS)
PURY-P1100YSNW-A2/TR2/RU2(-BS)

40, 42, 44HP

PURY-P-Y(S)NW-A2/TR2/RU2

1. SPECIFICATIONS	2
2. EXTERNAL DIMENSIONS	25
3. CENTER OF GRAVITY	36
4. ELECTRICAL WIRING DIAGRAMS	37
5. SOUND LEVELS	40
5-1. Sound levels in cooling mode	40
5-2. Sound levels in heating mode	47
6. VIBRATION LEVEL	54
7. OPERATION TEMPERATURE RANGE	55
8. CAPACITY TABLES	56
8-1. Selection of Cooling/Heating Units	56
8-2. Correction by temperature	62
8-3. Correction by total indoor	98
8-4. Correction by refrigerant piping length	110
8-5. Correction by port counts of the BC controller	114
8-6. Correction at frost and defrost	114
8-7. Correction at evaporation-temperature (ET) control	114
9. OPTIONAL PARTS	115
9-1. JOINT and REDUCER	115
9-2. OUTDOOR TWINNING KIT	120
9-3. JOINT KIT "CMY-R160-J1" FOR BC CONTROLLER	121
9-4. FIN GUARD	122
9-5. PANEL HEATER	124
10. ELECTRICAL WORK	125
10-1. General cautions	125
10-2. Power supply for Outdoor unit	126
10-3. Power cable specifications	127
10-4. Power supply examples	128
11. M-NET CONTROL	130
11-1. Transmission cable length limitation	130
11-2. Transmission cable specifications	131
11-3. System configuration restrictions	132
11-4. Address setting	136
12. PIPING DESIGN	146
12-1. R410A Piping material	146
12-2. Piping Design	148
12-3. Refrigerant charging calculation	159
13. OUTDOOR INSTALLATION	163
13-1. Requirement on installation site	163
13-2. Spacing	164
13-3. Piping direction	166
13-4. Weather countermeasure	171
13-5. Countermeasure to wind	171
13-6. Precautions for installing a panel heater	171

1. SPECIFICATIONS

R2-Series

PURY-P-Y-Y(S)NW-A2/TR2/RU2

Model			PURY-P200YNW-A2/TR2/RU2 (-BS)			
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz			
Cooling capacity		*1	kW	22.4		
			BTU/h	76,400		
		Power input	kW	6.68		
			Current input	A	11.2-10.7-10.3	
			EER	kW/kW	3.35	
			SEER	kW/kW	7.27	
Temp. range of cooling	*4	Indoor	W.B.	15.0~24.0°C (59~75°F)		
		Outdoor	D.B.	-5.0~52.0°C (23~126°F)		
Heating capacity (Max)		*2	kW	25.0		
			BTU/h	85,300		
		Power input	kW	6.79		
			Current input	A	11.4-10.8-10.4	
			COP	kW/kW	3.68	
			(Nominal)	*3	kW	22.4
		BTU/h			76,400	
		Power input		kW	5.38	
				Current input	A	9.0-8.6-8.3
		COP	kW/kW	4.16		
SCOP	kW/kW		4.01			
Temp. range of heating	*4	Indoor	D.B.	15.0~27.0°C (59~81°F)		
		Outdoor	W.B.	-20.0~15.5°C (-4~60°F)		
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity			
	Model/Quantity		P10~P250, M20~M140/1~20			
Sound pressure level (measured in anechoic room) *5, 6			dB <A>	59.0/59.0		
Sound power level (measured in anechoic room) *5			dB <A>	76/76		
Refrigerant	High pressure	mm (in.)	15.88 (5/8) Brazed			
piping diameter	Low pressure	mm (in.)	19.05 (3/4) Brazed			
FAN	Type x Quantity		Propeller fan x 1			
	Air flow rate	m³/min	170			
		L/s	2,833			
		cfm	6,003			
	Control, Driving mechanism		Inverter-control, Direct-driven by motor			
	Motor output	kW	0.92 x 1			
	*7 External static press.		0 Pa (0 mmH ₂ O)			
	Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		
Starting method		Inverter				
Motor output		kW	5.0			
Case heater		kW	-			
Lubricant		MEL32				
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>			
External dimension H x W x D		mm	1,858 (1,798 without legs) x 920 x 740			
		in.	73-3/16 (70-13/16 without legs) x 36-1/4 x 29-3/16			
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)			
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection			
	Compressor		-			
	Fan motor		-			
Refrigerant	Type x original charge		R410A x 5.2 kg (12 lbs)			
	Control		Indoor LEV and BC controller			
Net weight		kg (lbs)	214 (472)			
Heat exchanger			Salt-resistant cross fin & copper tube			
HIC circuit (HIC: Heat Inter-Changer)			-			
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing	External		WKB94C4WD			
	Wiring		WKE94L190			
Standard attachment	Document		Installation Manual			
	Accessory		-			
Optional parts			Joint: CMY-Y102SS-G2,CMY-Y102LS-G2,CMY-R160-J1 BC controller: CMB-M104,106,108,1012,1016V-J1 Main BC controller: CMB-M108,1012,1016V-JA1,CMB-P1016V-KA1 Sub BC controller: CMB-M104,108V-KB1			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:		Unit converter	
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		BTU/h	=kW x 3,412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		cfm	=m³/min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered		lbs	=kg/0.4536
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.			
5. Cooling mode/Heating mode			
6. The sound pressure level measured by the conventional method in JIS for reference purpose.			
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.		*Above specification data is subject to rounding variation.	

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P250YNW-A2/TR2/RU2 (-BS)		
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz		
Cooling capacity		*1	kW	28.0	
			BTU/h	95,500	
		Power input	kW	10.25	
			Current input	A	17.3-16.4-15.8
			EER	kW/kW	2.73
			SEER	kW/kW	6.85
Temp. range of cooling	*4	Indoor	W.B.	15.0~24.0°C (59~75°F)	
		Outdoor	D.B.	-5.0~52.0°C (23~126°F)	
Heating capacity (Max)		*2	kW	31.5	
			BTU/h	107,500	
		Power input	kW	9.57	
			Current input	A	16.1-15.3-14.7
			COP	kW/kW	3.29
			(Nominal)	*3	kW
		BTU/h			95,500
		Power input		kW	7.36
				Current input	A
		COP	kW/kW	3.80	
SCOP	kW/kW		4.01		
Temp. range of heating	*4	Indoor	D.B.	15.0~27.0°C (59~81°F)	
		Outdoor	W.B.	-20.0~15.5°C (-4~60°F)	
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity		
	Model/Quantity		P10~P250, M20~M140/1~25		
Sound pressure level (measured in anechoic room) *5, 6			dB <A>	60.5/64.0	
Sound power level (measured in anechoic room) *5			dB <A>	78/83	
Refrigerant	High pressure	mm (in.)	19.05 (3/4) Brazed		
piping diameter	Low pressure	mm (in.)	22.2 (7/8) Brazed		
FAN	Type x Quantity		Propeller fan x 1		
	Air flow rate	m³/min	220		
		L/s	3,667		
		cfm	7,768		
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		
	Motor output	kW	0.92 x 1		
	*7 External static press.		0 Pa (0 mmH₂O)		
	Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1	
Starting method		Inverter			
Motor output		kW	8.0		
Case heater		kW	-		
Lubricant		MEL32			
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>		
External dimension H x W x D		mm	1,858 (1,798 without legs) x 920 x 740		
		in.	73-3/16 (70-13/16 without legs) x 36-1/4 x 29-3/16		
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)		
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection		
	Compressor		-		
	Fan motor		-		
Refrigerant	Type x original charge		R410A x 5.2 kg (12 lbs)		
	Control		Indoor LEV and BC controller		
Net weight	kg (lbs)		223 (492)		
Heat exchanger			Salt-resistant cross fin & copper tube		
HIC circuit (HIC: Heat Inter-Changer)			-		
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)		
Drawing	External		WKB94C4WD		
	Wiring		WKE94L190		
Standard attachment	Document		Installation Manual		
	Accessory		-		
Optional parts			Joint: CMY-Y102SS-G2,CMY-Y102LS-G2,CMY-R160-J1 BC controller: CMB-M104,106,108,1012,1016V-J1 Main BC controller: CMB-M108,1012,1016V-JA1,CMB-P1016V-KA1 Sub BC controller: CMB-M104,108V-KB1		
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.		

Notes:		Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		BTU/h = kW x 3,412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		cfm = m³/min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		lbs = kg/0.4536
Eurovent registered		
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.		
5. Cooling mode/Heating mode		
6. The sound pressure level measured by the conventional method in JIS for reference purpose.		
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.		*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y-Y(S)NW-A2/TR2/RU2

Model			PURY-P300YNW-A2/TR2/RU2 (-BS)			
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz			
Cooling capacity		*1	kW	33.5		
			BTU/h	114,300		
		Power input	kW	11.75		
			Current input	A	19.8-18.8-18.1	
			EER	kW/kW	2.85	
			SEER	kW/kW	6.34	
Temp. range of cooling	*4	Indoor	W.B.	15.0~24.0°C (59~75°F)		
		Outdoor	D.B.	-5.0~52.0°C (23~126°F)		
Heating capacity (Max)		*2	kW	33.5		
			BTU/h	114,300		
		Power input	kW	9.62		
			Current input	A	16.2-15.4-14.8	
			COP	kW/kW	3.48	
			(Nominal)	*3	kW	33.5
		BTU/h			114,300	
		Power input		kW	9.62	
				Current input	A	16.2-15.4-14.8
		Temp. range of heating	*4	Indoor	D.B.	15.0~27.0°C (59~81°F)
Outdoor	W.B.			-20.0~15.5°C (-4~60°F)		
Indoor unit connectable		Total capacity		50~150% of outdoor unit capacity		
		Model/Quantity		P10~P250, M20~M140/1~30		
Sound pressure level (measured in anechoic room) *5, 6			dB <A>	61.0/67.0		
Sound power level (measured in anechoic room) *5			dB <A>	80/86		
Refrigerant	High pressure	mm (in.)	19.05 (3/4) Brazed			
piping diameter	Low pressure	mm (in.)	22.2 (7/8) Brazed			
FAN	Type x Quantity		Propeller fan x 1			
	Air flow rate	m³/min	240			
		L/s	4,000			
		cfm	8,474			
	Control, Driving mechanism		Inverter-control, Direct-driven by motor			
	Motor output	kW	0.92 x 1			
	*7 External static press.		0 Pa (0 mmH₂O)			
	Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		
Starting method		Inverter				
Motor output		kW	9.2			
Case heater		kW	-			
Lubricant		MEL32				
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>			
External dimension H x W x D		mm	1,858 (1,798 without legs) x 920 x 740			
		in.	73-3/16 (70-13/16 without legs) x 36-1/4 x 29-3/16			
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)			
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection			
	Compressor		-			
	Fan motor		-			
Refrigerant	Type x original charge		R410A x 5.2 kg (12 lbs)			
	Control		Indoor LEV and BC controller			
Net weight		kg (lbs)	225 (497)			
Heat exchanger			Salt-resistant cross fin & copper tube			
HIC circuit (HIC: Heat Inter-Changer)			-			
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing	External		WKB94C4WD			
	Wiring		WKE94L190			
Standard attachment	Document		Installation Manual			
	Accessory		-			
Optional parts			Joint: CMY-Y102SS-G2,CMY-Y102LS-G2,CMY-R160-J1 BC controller: CMB-M104,106,108,1012,1016V-J1 Main BC controller: CMB-M108,1012,1016V-JA1,CMB-P1016V-KA1 Sub BC controller: CMB-M104,108V-KB1			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:		Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		BTU/h =kW x 3,412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		cfm =m ³ /min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		lbs =kg/0.4536
Eurovent registered 4. -10 °CD.B.(14 °FD.B.)/-11 °CW.B.(12 °FW.B.) to 21 °CD.B.(70 °FD.B.)/15.5 °CW.B.(60 °FW.B.) with cooling/heating mixed operation.		
5. Cooling mode/Heating mode		
6. The sound pressure level measured by the conventional method in JIS for reference purpose.		
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.		*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P350YNW-A2/TR2/RU2 (-BS)				
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz				
Cooling capacity		*1	kW	40.0			
			BTU/h	136,500			
		Power input	kW	14.92			
			Current input	A	25.1-23.9-23.0		
			EER	kW/kW	2.68		
			SEER	kW/kW	5.98		
Temp. range of cooling	*4	Indoor	W.B.	15.0~24.0°C (59~75°F)			
		Outdoor	D.B.	-5.0~52.0°C (23~126°F)			
Heating capacity (Max)		*2	kW	45.0			
			BTU/h	153,500			
		Power input	kW	13.88			
			Current input	A	23.4-22.2-21.4		
			COP	kW/kW	3.24		
			(Nominal)	*3	kW	40.0	
		BTU/h			136,500		
		Power input		kW	10.89		
				Current input	A	18.3-17.4-16.8	
				COP	kW/kW	3.67	
				SCOP	kW/kW	3.53	
		Temp. range of heating	*4	Indoor	D.B.	15.0~27.0°C (59~81°F)	
Outdoor	W.B.			-20.0~15.5°C (-4~60°F)			
Indoor unit connectable		Total capacity		50~150% of outdoor unit capacity			
		Model/Quantity		P10~P250, M20~M140/1~35			
Sound pressure level (measured in anechoic room) *5, 6			dB <A>	62.5/64.0			
Sound power level (measured in anechoic room) *5			dB <A>	81/83			
Refrigerant	High pressure	mm (in.)	19.05 (3/4) Brazed				
piping diameter	Low pressure	mm (in.)	28.58 (1-1/8) Brazed				
FAN	Type x Quantity		Propeller fan x 2				
	Air flow rate	m³/min	250				
		L/s	4,167				
		cfm	8,828				
	Control, Driving mechanism		Inverter-control, Direct-driven by motor				
	Motor output	kW	0.46 x 2				
	*7 External static press.		0 Pa (0 mmH₂O)				
	Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1			
Starting method		Inverter					
Motor output		kW	12.0				
Case heater		kW	-				
Lubricant		MEL32					
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>				
External dimension H x W x D		mm	1,858 (1,798 without legs) x 1,240 x 740				
		in.	73-3/16 (70-13/16 without legs) x 48-7/8 x 29-3/16				
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)				
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection				
	Compressor		-				
	Fan motor		-				
Refrigerant	Type x original charge		R410A x 8.0 kg (18 lbs)				
	Control		Indoor LEV and BC controller				
Net weight	kg (lbs)		269 (594)				
Heat exchanger			Salt-resistant cross fin & copper tube				
HIC circuit (HIC: Heat Inter-Changer)			-				
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)				
Drawing	External		WKB94C4WE				
	Wiring		WKE94L191				
Standard attachment	Document		Installation Manual				
	Accessory		-				
Optional parts			Joint: CMY-Y102SS-G2,CMY-Y102LS-G2,CMY-R160-J1 BC controller: CMB-M104,106,108,1012,1016V-J1 Main BC controller: CMB-M108,1012,1016V-JA1,CMB-P1016V-KA1 Sub BC controller: CMB-M104,108V-KB1				
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.				

Notes:		Unit converter
1.Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C.D.B./19°C.W.B. (81°F.D.B./66°F.W.B.), Outdoor: 35°C.D.B./24°C.W.B. (95°F.D.B./75°F.W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		BTU/h =kW x 3,412
2.Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C.D.B. (68°F.D.B.), Outdoor: 7°C.D.B./6°C.W.B. (45°F.D.B./43°F.W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		cfm =m³/min x 35.31
3.Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C.D.B. (68°F.D.B.), Outdoor: 7°C.D.B./6°C.W.B. (45°F.D.B./43°F.W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		lbs =kg/0.4536
Eurovent registered		
4.-10 °CD.B.(14 °FD.B.)/-11 °CW.B.(12 °FW.B.) to 21 °CD.B.(70 °FD.B.)/15.5 °CW.B.(60 °FW.B.) with cooling/heating mixed operation.		
5.Cooling mode/Heating mode		
6.The sound pressure level measured by the conventional method in JIS for reference purpose.		
7.External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.		*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P400YNW-A2/TR2/RU2 (-BS)				
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz				
Cooling capacity		*1	kW	45.0			
			BTU/h	153,500			
			Power input	kW	19.65		
			Current input	A	33.1-31.5-30.3		
			EER	kW/kW	2.29		
			SEER	kW/kW	5.82		
Temp. range of cooling		*4	Indoor	W.B.	15.0~24.0°C (59~75°F)		
			Outdoor	D.B.	-5.0~52.0°C (23~126°F)		
Heating capacity (Max)		*2	kW	50.0			
			BTU/h	170,600			
			Power input	kW	16.66		
			Current input	A	28.1-26.7-25.7		
			COP	kW/kW	3.00		
		(Nominal)	*3	kW	45.0		
				BTU/h	153,500		
				Power input	kW	13.39	
				Current input	A	22.6-21.4-20.6	
				COP	kW/kW	3.36	
				SCOP	kW/kW	3.51	
Temp. range of heating		*4	Indoor	D.B.	15.0~27.0°C (59~81°F)		
			Outdoor	W.B.	-20.0~15.5°C (-4~60°F)		
Indoor unit connectable		Total capacity			50~150% of outdoor unit capacity		
		Model/Quantity			P10~P250, M20~M140/1~40		
Sound pressure level (measured in anechoic room) *5, 6			dB <A>	65.0/69.0			
Sound power level (measured in anechoic room) *5			dB <A>	83/88			
Refrigerant	High pressure	mm (in.)	22.2 (7/8) Brazed				
piping diameter	Low pressure	mm (in.)	28.58 (1-1/8) Brazed				
FAN	Type x Quantity		Propeller fan x 2				
	Air flow rate	m³/min	315				
		L/s	5,250				
		cfm	11,123				
	Control, Driving mechanism		Inverter-control, Direct-driven by motor				
	Motor output	kW	0.46 x 2				
	*7 External static press.		0 Pa (0 mmH₂O)				
	Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1			
Starting method		Inverter					
Motor output		kW	16.1				
Case heater		kW	-				
Lubricant		MEL32					
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>				
External dimension H x W x D		mm	1,858 (1,798 without legs) x 1,240 x 740				
		in.	73-3/16 (70-13/16 without legs) x 48-7/8 x 29-3/16				
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)				
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection				
	Compressor		-				
	Fan motor		-				
Refrigerant	Type x original charge		R410A x 8.0 kg (18 lbs)				
	Control		Indoor LEV and BC controller				
Net weight		kg (lbs)	269 (594)				
Heat exchanger			Salt-resistant cross fin & copper tube				
HIC circuit (HIC: Heat Inter-Changer)			-				
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)				
Drawing	External		WKB94C4WE				
	Wiring		WKE94L191				
Standard attachment	Document		Installation Manual				
	Accessory		-				
Optional parts			Joint: CMY-Y102SS-G2,CMY-Y102LS-G2,CMY-R160-J1				
			Main BC controller: CMB-M108,1012,1016V-JA1,CMB-P1016V-KA1				
			Sub BC controller: CMB-M104,108V-KB1				
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.				

Notes:		Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		BTU/h =kW x 3.412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		cfm =m ³ /min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered		lbs =kg/0.4536
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.		
5. Cooling mode/Heating mode		
6. The sound pressure level measured by the conventional method in JIS for reference purpose.		
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.		*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

Model			PURY-P450YNW-A2/TR2/RU2 (-BS)			
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz			
Cooling capacity		*1	kW	50.0		
			BTU/h	170,600		
			Power input	kW	19.84	
			Current input	A	33.4-31.8-30.6	
			EER	kW/kW	2.52	
			SEER	kW/kW	6.38	
Temp. range of cooling		*4	Indoor	W.B.	15.0~24.0°C (59~75°F)	
			Outdoor	D.B.	-5.0~52.0°C (23~126°F)	
Heating capacity (Max)		*2	kW	56.0		
			BTU/h	191,100		
			Power input	kW	18.79	
			Current input	A	31.7-30.1-29.0	
			COP	kW/kW	2.98	
		(Nominal)	*3	kW	50.0	
				BTU/h	170,600	
				Power input	kW	15.33
				Current input	A	25.8-24.5-23.6
				COP	kW/kW	3.26
				SCOP	kW/kW	3.51
		Temp. range of heating		*4	Indoor	D.B.
	Outdoor			W.B.	-20.0~15.5°C (-4~60°F)	
Indoor unit connectable		Total capacity			50~150% of outdoor unit capacity	
		Model/Quantity			P10~P250, M20~M140/1~45	
Sound pressure level (measured in anechoic room) *5, 6			dB <A>		65.5/70.0	
Sound power level (measured in anechoic room) *5			dB <A>		83/89	
Refrigerant piping diameter		High pressure		mm (in.)	22.2 (7/8) Brazed	
		Low pressure		mm (in.)	28.58 (1-1/8) Brazed	
FAN		Type x Quantity			Propeller fan x 2	
		Air flow rate		m³/min	315	
				L/s	5,250	
				cfm	11,123	
				Control, Driving mechanism		
		*7		Motor output	kW	0.46 x 2
				External static press.		
Compressor		Type x Quantity			Inverter scroll hermetic compressor x 1	
		Starting method			Inverter	
		Motor output	kW	16.2		
		Case heater	kW	-		
		Lubricant			MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>			
External dimension H x W x D		mm		1,858 (1,798 without legs) x 1,240 x 740		
				73-3/16 (70-13/16 without legs) x 48-7/8 x 29-3/16		
Protection devices		High pressure protection			High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	
		Inverter circuit (COMP./FAN)			Over-heat protection, Over-current protection	
		Compressor			-	
		Fan motor			-	
Refrigerant		Type x original charge			R410A x 10.8 kg (24 lbs)	
		Control			Indoor LEV and BC controller	
Net weight		kg (lbs)		289 (638)		
Heat exchanger			Salt-resistant cross fin & copper tube			
HIC circuit (HIC: Heat Inter-Changer)			-			
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing		External			WKB94C4WE	
		Wiring			WKE94L191	
Standard attachment		Document			Installation Manual	
		Accessory			-	
Optional parts			Joint: CMY-Y102SS-G2,CMY-Y102LS-G2,CMY-R160-J1			
			Main BC controller: CMB-M108,1012,1016V-JA1,CMB-P1016V-KA1			
			Sub BC controller: CMB-M104,108V-KB1			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:		Unit converter
1.Nominal cooling conditions (subject to JIS B8615-2)		BTU/h =kW x 3,412
Indoor: 27°C.D.B./19°C.W.B. (81°F.D.B./66°F.W.B.), Outdoor: 35°C.D.B./24°C.W.B. (95°F.D.B./75°F.W.B.)		cfm =m³/min x 35.31
Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		lbs =kg/0.4536
2.Nominal heating conditions (subject to JIS B8615-2)		
Indoor: 20°C.D.B. (68°F.D.B.), Outdoor: 7°C.D.B./6°C.W.B. (45°F.D.B./43°F.W.B.)		
Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		
3.Nominal heating conditions (subject to JIS B8615-2)		
Indoor: 20°C.D.B. (68°F.D.B.), Outdoor: 7°C.D.B./6°C.W.B. (45°F.D.B./43°F.W.B.)		
Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		
Eurovent registered		
4.-10 °C.D.B.(14 °F.D.B.)/-11 °C.W.B.(12 °F.W.B.) to 21 °C.D.B.(70 °F.D.B.)/15.5 °C.W.B.(60 °F.W.B.)		
with cooling/heating mixed operation.		
5.Cooling mode/Heating mode		
6.The sound pressure level measured by the conventional method in JIS for reference purpose.		
7.External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O).		
Consult your dealer about the specification when setting External static pressure option.		
		*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P500YNW-A2/TR2/RU2 (-BS)			
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz			
Cooling capacity		*1	kW	56.0		
			BTU/h	191,100		
		Power input	kW	22.22		
		Current input	A	37.5-35.6-34.3		
		EER	kW/kW	2.52		
		SEER	kW/kW	6.24		
Temp. range of cooling	*4	Indoor	W.B.	15.0~24.0°C (59~75°F)		
		Outdoor	D.B.	-5.0~52.0°C (23~126°F)		
Heating capacity (Max)		*2	kW	63.0		
			BTU/h	215,000		
		Power input	kW	21.14		
		Current input	A	35.6-33.9-32.6		
		COP	kW/kW	2.98		
		(Nominal)	*3	kW	56.0	
				BTU/h	191,100	
			Power input	kW	16.76	
			Current input	A	28.2-26.8-25.9	
			COP	kW/kW	3.34	
			SCOP	kW/kW	3.51	
		Temp. range of heating	*4	Indoor	D.B.	15.0~27.0°C (59~81°F)
Outdoor	W.B.			-20.0~15.5°C (-4~60°F)		
Indoor unit connectable		Total capacity		50~150% of outdoor unit capacity		
		Model/Quantity		P10~P250, M20~M140/1~50		
Sound pressure level (measured in anechoic room) *5, 6			dB <A>	63.5/64.5		
Sound power level (measured in anechoic room) *5			dB <A>	82/84		
Refrigerant	High pressure	mm (in.)	22.2 (7/8) Brazed			
piping diameter	Low pressure	mm (in.)	28.58 (1-1/8) Brazed			
FAN	Type x Quantity		Propeller fan x 2			
	Air flow rate	m³/min	295			
		L/s	4,917			
		cfm	10,416			
	Control, Driving mechanism		Inverter-control, Direct-driven by motor			
	Motor output	kW	0.92 x 2			
	*7 External static press.		0 Pa (0 mmH₂O)			
	Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		
		Starting method		Inverter		
Motor output		kW	17.4			
Case heater		kW	-			
Lubricant		MEL32				
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>			
External dimension H x W x D		mm	1,858 (1,798 without legs) x 1,750 x 740			
		in.	73-3/16 (70-13/16 without legs) x 68-15/16 x 29-3/16			
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)			
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection			
	Compressor		-			
	Fan motor		-			
Refrigerant	Type x original charge		R410A x 10.8 kg (24 lbs)			
	Control		Indoor LEV and BC controller			
Net weight		kg (lbs)	335 (739)			
Heat exchanger			Salt-resistant cross fin & copper tube			
HIC circuit (HIC: Heat Inter-Changer)			-			
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing	External		WKB94C4WF			
	Wiring		WKE94L192			
Standard attachment	Document		Installation Manual			
	Accessory		-			
Optional parts			Joint: CMY-Y102SS-G2, CMY-Y102LS-G2, CMY-R160-J1			
			Main BC controller: CMB-M108, 1012, 1016V-JA1, CMB-P1016V-KA1			
			Sub BC controller: CMB-M104, 108V-KB1			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:		Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		BTU/h =kW x 3,412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		cfm =m ³ /min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		lbs =kg/0.4536
Eurovent registered 4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.		
5. Cooling mode/Heating mode		
6. The sound pressure level measured by the conventional method in JIS for reference purpose.		
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.		*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P550YNW-A2/TR2/RU2 (-BS)			
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz			
Cooling capacity		*1	kW	60.0		
			BTU/h	204,700		
			Power input	kW	25.86	
			Current input	A	43.6-41.4-39.9	
			EER	kW/kW	2.32	
			SEER	kW/kW	6.25	
Temp. range of cooling		*4	Indoor	W.B.	15.0~24.0°C (59~75°F)	
			Outdoor	D.B.	-5.0~52.0°C (23~126°F)	
Heating capacity (Max)		*2	kW	69.0		
			BTU/h	235,400		
			Power input	kW	24.55	
			Current input	A	41.4-39.3-37.9	
			COP	kW/kW	2.81	
			(Nominal)	*3	kW	63.0
		BTU/h			215,000	
				Power input	kW	20.00
				Current input	A	33.7-32.0-30.9
				COP	kW/kW	3.15
				SCOP	kW/kW	3.51
		Temp. range of heating		*4	Indoor	D.B.
Outdoor	W.B.				-20.0~15.5°C (-4~60°F)	
Indoor unit connectable		Total capacity		50~150% of outdoor unit capacity		
		Model/Quantity		P10~P250, M20~M140/2~50		
Sound pressure level (measured in anechoic room) *5, 6				dB <A>	70.0/70.0	
Sound power level (measured in anechoic room) *5				dB <A>	89/89	
Refrigerant	High pressure	mm (in.)	22.2 (7/8) Brazed (28.58 (1-1/8) Brazed for the part that exceeds 65 m)			
piping diameter	Low pressure	mm (in.)	28.58 (1-1/8) Brazed			
FAN	Type x Quantity		Propeller fan x 2			
	Air flow rate	m³/min	410			
		L/s	6,833			
		cfm	14,477			
	Control, Driving mechanism		Inverter-control, Direct-driven by motor			
	Motor output	kW	0.92 x 2			
	*7 External static press.		0 Pa (0 mmH₂O)			
	Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		
Starting method		Inverter				
Motor output		kW	20.5			
Case heater		kW	-			
Lubricant		MEL32				
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>			
External dimension H x W x D		mm	1,858 (1,798 without legs) x 1,750 x 740			
		in.	73-3/16 (70-13/16 without legs) x 68-15/16 x 29-3/16			
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)			
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection			
	Compressor		-			
	Fan motor		-			
Refrigerant	Type x original charge		R410A x 10.8 kg (24 lbs)			
	Control		Indoor LEV and BC controller			
Net weight		kg (lbs)	335 (739)			
Heat exchanger			Salt-resistant cross fin & copper tube			
HIC circuit (HIC: Heat Inter-Changer)			-			
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing	External		WKB94C4WF			
	Wiring		WKE94L192			
Standard attachment	Document		Installation Manual			
	Accessory		-			
Optional parts			Joint: CMY-Y102SS-G2,CMY-Y102LS-G2,CMY-R160-J1			
			Main BC controller: CMB-M108,1012,1016V-JA1,CMB-P1016V-KA1			
			Sub BC controller: CMB-M104,108V-KB1			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:		Unit converter
1.Nominal cooling conditions (subject to JIS B8615-2)		BTU/h =kW x 3,412
Indoor: 27°C.D.B./19°C.W.B. (81°F.D.B./66°F.W.B.), Outdoor: 35°C.D.B./24°C.W.B. (95°F.D.B./75°F.W.B.)		cfm =m³/min x 35.31
Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		lbs =kg/0.4536
2.Nominal heating conditions (subject to JIS B8615-2)		
Indoor: 20°C.D.B. (68°F.D.B.), Outdoor: 7°C.D.B./6°C.W.B. (45°F.D.B./43°F.W.B.)		
Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		
3.Nominal heating conditions (subject to JIS B8615-2)		
Indoor: 20°C.D.B. (68°F.D.B.), Outdoor: 7°C.D.B./6°C.W.B. (45°F.D.B./43°F.W.B.)		
Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		
Eurovent registered		
4.-10 °CD.B.(14 °FD.B.)/-11 °CW.B.(12 °FW.B.) to 21 °CD.B.(70 °FD.B.)/15.5 °CW.B.(60 °FW.B.)		
with cooling/heating mixed operation.		
5.Cooling mode/Heating mode		
6.The sound pressure level measured by the conventional method in JIS for reference purpose.		
7.External static pressure option is available (30 Pa/3.1 mmH ₂ O).		
Consult your dealer about the specification when setting External static pressure option.		*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P400YSNW-A2/TR2/RU2 (-BS)
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz
Cooling capacity	*1	kW	44.8
		BTU/h	152,900
	Power input	kW	13.78
		A	23.2-22.0-21.3
	EER	kW/kW	3.25
	SEER	kW/kW	7.05
Temp. range of cooling	Indoor	W.B.	15.0~24.0°C (59~75°F)
	Outdoor	D.B.	-5.0~52.0°C (23~126°F)
Heating capacity (Max)	*2	kW	50.0
		BTU/h	170,600
	Power input	kW	14.00
		A	23.6-22.4-21.6
	COP	kW/kW	3.57
			44.8
	(Nominal) *3	BTU/h	152,900
		kW	11.08
	Current input	A	18.7-17.7-17.1
		kW/kW	4.04
Temp. range of heating	Indoor	D.B.	15.0~27.0°C (59~81°F)
	Outdoor	W.B.	-20.0~15.5°C (-4~60°F)
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity
	Model/Quantity		P10~P250, M20~M140/1~40
Sound pressure level (measured in anechoic room) *5, 6			dB <A> 62.0/62.0
Sound power level (measured in anechoic room) *5			dB <A> 79/79
Refrigerant piping diameter	High pressure	mm (in.)	22.2 (7/8) Brazed
	Low pressure	mm (in.)	28.58 (1-1/8) Brazed

Set Model			PURY-P200YNW-A2/TR2/RU2 (-BS)	PURY-P200YNW-A2/TR2/RU2 (-BS)
Model			Propeller fan x 1	Propeller fan x 1
FAN	Type x Quantity		170	170
	Air flow rate	m ³ /min	2,833	2,833
		L/s	6,003	6,003
		cfm		
	Control, Driving mechanism		Inverter-control, Direct-driven by motor	Inverter-control, Direct-driven by motor
	Motor output	kW	0.92 x 1	0.92 x 1
*7	External static press.		0 Pa (0 mmH ₂ O)	0 Pa (0 mmH ₂ O)
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1	Inverter scroll hermetic compressor x 1
	Starting method		Inverter	Inverter
	Motor output	kW	5.0	5.0
	Case heater	kW	-	-
	Lubricant		MEL32	MEL32
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>	Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>
External dimension H x W x D		mm	1,858 (1,798 without legs) x 920 x 740	1,858 (1,798 without legs) x 920 x 740
		in.	73-3/16 (70-13/16 without legs) x 36-1/4 x 29-3/16	73-3/16 (70-13/16 without legs) x 36-1/4 x 29-3/16
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	High pressure sensor, High pressure switch at 4.15 MPa (601 psi)
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection	Over-heat protection, Over-current protection
	Compressor		-	-
	Fan motor		-	-
Refrigerant	Type x original charge		R410A x 5.2 kg (12 lbs)	R410A x 5.2 kg (12 lbs)
	Control		Indoor LEV and BC controller	
Net weight		kg (lbs)	214 (472)	214 (472)
Heat exchanger			Salt-resistant cross fin & copper tube	Salt-resistant cross fin & copper tube
HIC circuit (HIC: Heat Inter-Changer)			-	-
Pipe between unit and distributor	High pressure	mm (in.)	15.88 (5/8) Brazed	15.88 (5/8) Brazed
	Low pressure	mm (in.)	19.05 (3/4) Brazed	19.05 (3/4) Brazed
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)	
Drawing	External		WKB94C4VZ	
	Wiring		WKE94L190	WKE94L190
Standard attachment	Document		Installation Manual	
	Accessory		-	
Optional parts			Outdoor Twinning kit: CMY-R100VBK4 Joint: CMY-Y102SS-G2, CMY-Y102LS-G2, CMY-R160-J1 Main BC controller: CMB-M108, 1012, 1016V-JA1, CMB-P1016V-KA1 Sub BC controller: CMB-M104, 108V-KB1	
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.	

Notes:	Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	BTU/h =kW x 3,412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	cfm =m ³ /min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered	lbs =kg/0.4536
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.	
5. Cooling mode/Heating mode	
6. The sound pressure level measured by the conventional method in JIS for reference purpose.	
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.	*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

Model			PURY-P450YSNW-A2/TR2/RU2 (-BS)		
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz		
Cooling capacity	*1	kW	50.4		
		BTU/h	172,000		
		Power input	kW		17.08
		Current input	A		28.8-27.3-26.4
		EER	kW/kW		2.95
		SEER	kW/kW		6.85
Temp. range of cooling	*4	Indoor	W.B.		15.0~24.0°C (59~75°F)
		Outdoor	D.B.		-5.0~52.0°C (23~126°F)
Heating capacity (Max)	*2	kW	56.5		
		BTU/h	192,800		
		Power input	kW		16.71
		Current input	A		28.2-26.7-25.8
		COP	kW/kW		3.38
	(Nominal) *3	kW	50.4		
		BTU/h	172,000		
		Power input	kW		13.05
		Current input	A		22.0-20.9-20.1
		COP	kW/kW		3.86
Temp. range of heating	*4	Indoor	D.B.		15.0~27.0°C (59~81°F)
		Outdoor	W.B.		-20.0~15.5°C (-4~60°F)
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity		
	Model/Quantity		P10~P250, M20~M140/1~45		
Sound pressure level (measured in anechoic room) *5, 6		dB <A>		63.0/65.5	
Sound power level (measured in anechoic room) *5		dB <A>		81/84	
Refrigerant piping diameter	High pressure	mm (in.)		22.2 (7/8) Brazed	
	Low pressure	mm (in.)		28.58 (1-1/8) Brazed	

Set Model			PURY-P250YNW-A2/TR2/RU2 (-BS)		PURY-P200YNW-A2/TR2/RU2 (-BS)	
Model						
FAN	Type x Quantity		Propeller fan x 1		Propeller fan x 1	
	Air flow rate	m ³ /min	220		170	
		L/s	3,667		2,833	
		cfm	7,768		6,003	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
	Motor output		0.92 x 1		0.92 x 1	
	*7	External static press.		0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output		8.0		5.0	
	Case heater		-		-	
	Lubricant		MEL32		MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>		Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>	
External dimension H x W x D		mm	1,858 (1,798 without legs) x 920 x 740		1,858 (1,798 without legs) x 920 x 740	
		in.	73-3/16 (70-13/16 without legs) x 36-1/4 x 29-3/16		73-3/16 (70-13/16 without legs) x 36-1/4 x 29-3/16	
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection		Over-heat protection, Over-current protection	
	Compressor		-		-	
	Fan motor		-		-	
Refrigerant	Type x original charge		R410A x 5.2 kg (12 lbs)		R410A x 5.2 kg (12 lbs)	
	Control		Indoor LEV and BC controller			
Net weight		kg (lbs)	223 (492)		214 (472)	
Heat exchanger			Salt-resistant cross fin & copper tube		Salt-resistant cross fin & copper tube	
HIC circuit (HIC: Heat Inter-Changer)			-		-	
Pipe between unit and distributor	High pressure	mm (in.)	19.05 (3/4) Brazed		15.88 (5/8) Brazed	
	Low pressure	mm (in.)	22.2 (7/8) Brazed		19.05 (3/4) Brazed	
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing	External		WKB94C4VZ			
	Wiring		WKE94L190		WKE94L190	
Standard attachment	Document		Installation Manual			
	Accessory		-			
Optional parts			Outdoor Twinning kit: CMY-R100VBK4 Joint: CMY-Y102SS-G2,CMY-Y102LS-G2,CMY-R160-J1 Main BC controller: CMB-M108,1012,1016V-JA1,CMB-P1016V-KA1 Sub BC controller: CMB-M104,108V-KB1			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:			Unit converter	
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)			BTU/h =kW x 3,412	
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)			cfm =m ³ /min x 35.31	
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered			lbs =kg/0.4536	
4. -10 °C D.B./(-14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.				
5. Cooling mode/Heating mode				
6. The sound pressure level measured by the conventional method in JIS for reference purpose.				
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.			*Above specification data is subject to rounding variation.	

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P500YSNW-A2/TR2/RU2 (-BS)	
Power source			3-phase 4-wire 380~400-415 V 50/60 Hz	
Cooling capacity	*1	kW	56.0	
		BTU/h	191,100	
	Power input	kW	21.13	
		Current input	35.6-33.8-32.6	
		EER	2.65	
Temp. range of cooling	*4	SEER	6.64	
		Indoor	15.0~24.0°C (59~75°F)	
	Outdoor	W.B.	-5.0~52.0°C (23~126°F)	
		D.B.		
Heating capacity (Max)	*2	kW	63.0	
		BTU/h	215,000	
	Power input	kW	19.74	
		Current input	33.3-31.6-30.5	
		COP	3.19	
	(Nominal)	*3		
		kW	56.0	
	Power input	BTU/h	191,100	
		kW	15.17	
		Current input	25.6-24.3-23.4	
Temp. range of heating	*4	COP	3.69	
		SCOP	4.01	
	Indoor	D.B.	15.0~27.0°C (59~81°F)	
		W.B.	-20.0~15.5°C (-4~60°F)	
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity	
	Model/Quantity		P10~P250, M20~M140/1~50	
Sound pressure level (measured in anechoic room) *5, 6		dB <A>	63.5/67.0	
Sound power level (measured in anechoic room) *5		dB <A>	81/86	
Refrigerant		High pressure	mm (in.) 22.2 (7/8) Brazed	
piping diameter		Low pressure	mm (in.) 28.58 (1-1/8) Brazed	

Set Model			PURY-P250YNW-A2/TR2/RU2 (-BS)		PURY-P250YNW-A2/TR2/RU2 (-BS)	
Model			Propeller fan x 1		Propeller fan x 1	
FAN	Type x Quantity		Propeller fan x 1		Propeller fan x 1	
	Air flow rate	m ³ /min	220		220	
		L/s	3,667		3,667	
		cfm	7,768		7,768	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
	Motor output	kW	0.92 x 1		0.92 x 1	
*7	External static press.		0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)	
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output	kW	8.0		8.0	
	Case heater	kW	-		-	
	Lubricant		MEL32		MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>		Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>	
External dimension H x W x D		mm	1,858 (1,798 without legs) x 920 x 740		1,858 (1,798 without legs) x 920 x 740	
		in.	73-3/16 (70-13/16 without legs) x 36-1/4 x 29-3/16		73-3/16 (70-13/16 without legs) x 36-1/4 x 29-3/16	
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection		Over-heat protection, Over-current protection	
	Compressor		-		-	
	Fan motor		-		-	
Refrigerant	Type x original charge		R410A x 5.2 kg (12 lbs)		R410A x 5.2 kg (12 lbs)	
	Control		Indoor LEV and BC controller			
Net weight		kg (lbs)	223 (492)		223 (492)	
Heat exchanger			Salt-resistant cross fin & copper tube		Salt-resistant cross fin & copper tube	
HIC circuit (HIC: Heat Inter-Changer)			-		-	
Pipe between unit and distributor	High pressure	mm (in.)	19.05 (3/4) Brazed		19.05 (3/4) Brazed	
	Low pressure	mm (in.)	22.2 (7/8) Brazed		22.2 (7/8) Brazed	
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing	External		WKB94C4VZ			
	Wiring		WKE94L190		WKE94L190	
Standard attachment	Document		Installation Manual			
	Accessory		-			
Optional parts			Outdoor Twinning kit: CMY-R100VBK4 Joint: CMY-Y102SS-G2, CMY-Y102LS-G2, CMY-R160-J1 Main BC controller: CMB-M108, 1012, 1016V-JA1, CMB-P1016V-KA1 Sub BC controller: CMB-M104, 108V-KB1			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:			Unit converter	
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)			BTU/h	=kW x 3,412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)			cfm	=m ³ /min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered			lbs	=kg/0.4536
4. -10 °C D.B./14 °F D.B./-11 °C W.B./12 °F W.B. to 21 °C D.B./70 °F D.B./15.5 °C W.B./60 °F W.B.) with cooling/heating mixed operation.				
5. Cooling mode/Heating mode				
6. The sound pressure level measured by the conventional method in JIS for reference purpose.				
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.			*Above specification data is subject to rounding variation.	

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P550YSNW-A2/TR2/RU2 (-BS)		
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz		
Cooling capacity	*1	kW	61.5		
		BTU/h	209,800		
	Power input	kW	22.69		
	Current input	A	38.3-36.3-35.0		
	EER	kW/kW	2.71		
	SEER	kW/kW	6.40		
Temp. range of cooling	*4	Indoor	W.B.		
		Outdoor	D.B.		
Heating capacity (Max)	*2	kW	65.0		
		BTU/h	221,800		
	Power input	kW	19.81		
	Current input	A	33.4-31.7-30.6		
	COP	kW/kW	3.28		
	(Nominal)	*3	kW	61.5	
			BTU/h	209,800	
		Power input	kW	17.42	
		Current input	A	29.4-27.9-26.9	
		COP	kW/kW	3.53	
SCOP	kW/kW	4.01			
Temp. range of heating	*4	Indoor	D.B.		
		Outdoor	W.B.		
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity		
	Model/Quantity		P10~P250, M20~M140/2~50		
Sound pressure level (measured in anechoic room) *5, 6		dB <A>	64.0/69.0		
Sound power level (measured in anechoic room) *5		dB <A>	83/88		
Refrigerant	High pressure	mm (in.)	22.2 (7/8) Brazed (28.58 (1-1/8) Brazed for the part that exceeds 65 m)		
piping diameter	Low pressure	mm (in.)	28.58 (1-1/8) Brazed		

Set Model			PURY-P300YNW-A2/TR2/RU2 (-BS)		PURY-P250YNW-A2/TR2/RU2 (-BS)	
Model						
FAN	Type x Quantity		Propeller fan x 1		Propeller fan x 1	
	Air flow rate	m ³ /min	240		220	
		L/s	4,000		3,667	
		cfm	8,474		7,768	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
	Motor output	kW	0.92 x 1		0.92 x 1	
	*7	External static press.		0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output	kW	9.2		8.0	
	Case heater	kW	-		-	
	Lubricant		MEL32		MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) 			

Notes:	Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	BTU/h = kW x 3,412 cfm = m ³ /min x 35.31 lbs = kg/0.4536
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered	
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.	
5. Cooling mode/Heating mode	
6. The sound pressure level measured by the conventional method in JIS for reference purpose.	
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.	*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P600YSNW-A2/TR2/RU2 (-BS)		
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz		
Cooling capacity		*1	kW	67.0	
			BTU/h	228,600	
		Power input	kW	24.27	
		Current input	A	40.9-38.9-37.5	
		EER	kW/kW	2.76	
		SEER	kW/kW	6.15	
Temp. range of cooling	Indoor	W.B.	15.0~24.0°C (59~75°F)		
	*4 Outdoor	D.B.	-5.0~52.0°C (23~126°F)		
Heating capacity (Max)		*2	kW	67.0	
			BTU/h	228,600	
		Power input	kW	19.81	
		Current input	A	33.4-31.7-30.6	
		COP	kW/kW	3.38	
(Nominal)	*3	kW	67.0		
		BTU/h	228,600		
	Power input	kW	19.82		
	Current input	A	33.4-31.7-30.6		
	COP	kW/kW	3.38		
	SCOP	kW/kW	4.01		
	Temp. range of heating	Indoor	D.B.	15.0~27.0°C (59~81°F)	
Indoor unit connectable	*4 Outdoor	W.B.	-20.0~15.5°C (-4~60°F)		
	Total capacity	50~150% of outdoor unit capacity			
		Model/Quantity	P10~P250, M20~M140/2~50		
Sound pressure level (measured in anechoic room) *5, 6			dB <A>	64.0/70.0	
Sound power level (measured in anechoic room) *5			dB <A>	83/89	
Refrigerant	High pressure	mm (in.)	22.2 (7/8) Brazed (28.58 (1-1/8) Brazed for the part that exceeds 65 m)		
piping diameter	Low pressure	mm (in.)	28.58 (1-1/8) Brazed		

Set Model			PURY-P300YNW-A2/TR2/RU2 (-BS)		PURY-P300YNW-A2/TR2/RU2 (-BS)	
Model						
FAN	Type x Quantity		Propeller fan x 1		Propeller fan x 1	
	Air flow rate	m ³ /min	240		240	
		L/s	4,000		4,000	
		cfm	8,474		8,474	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
	Motor output	kW	0.92 x 1		0.92 x 1	
7	External static press.		0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)	
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output	kW	9.2		9.2	
	Case heater	kW	-		-	
	Lubricant		MEL32		MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>		Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>	
External dimension H x W x D		mm	1,858 (1,798 without legs) x 920 x 740		1,858 (1,798 without legs) x 920 x 740	
		in.	73-3/16 (70-13/16 without legs) x 36-1/4 x 29-3/16		73-3/16 (70-13/16 without legs) x 36-1/4 x 29-3/16	
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection		Over-heat protection, Over-current protection	
	Compressor		-		-	
	Fan motor		-		-	
Refrigerant	Type x original charge		R410A x 5.2 kg (12 lbs)		R410A x 5.2 kg (12 lbs)	
	Control		Indoor LEV and BC controller			
Net weight		kg (lbs)	225 (497)		225 (497)	
Heat exchanger			Salt-resistant cross fin & copper tube		Salt-resistant cross fin & copper tube	
HIC circuit (HIC: Heat Inter-Changer)			-		-	
Pipe between unit and distributor	High pressure	mm (in.)	19.05 (3/4) Brazed		19.05 (3/4) Brazed	
	Low pressure	mm (in.)	22.2 (7/8) Brazed		22.2 (7/8) Brazed	
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing	External		WKB94C4VZ			
	Wiring		WKE94L190		WKE94L190	
Standard attachment	Document		Installation Manual			
	Accessory		-			
Optional parts			Outdoor Twinning kit: CMY-R100VBK4 Joint: CMY-Y102SS-G2, CMY-Y102LS-G2, CMY-R160-J1 Main BC controller: CMB-M108, 1012, 1016V-JA1, CMB-P1016V-KA1 Sub BC controller: CMB-M104, 108V-KB1			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:	Unit converter
1.Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	BTU/h =kW x 3,412 cfm =m ³ /min x 35.31 lbs =kg/0.4536
2.Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	
3.Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered	
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.	
5.Cooling mode/Heating mode	
6.The sound pressure level measured by the conventional method in JIS for reference purpose.	
7.External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.	*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

Model			PURY-P650YSNW-A2/TR2/RU2 (-BS)
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz
Cooling capacity	*1	kW	73.5
		BTU/h	250,800
	Power input	kW	27.42
		A	46.2-43.9-42.3
		kW/kW	2.68
Temp. range of cooling	*4	Indoor	W.B.
		Outdoor	D.B.
			15.0~24.0°C (59~75°F) -5.0~52.0°C (23~126°F)
Heating capacity (Max)	*2	kW	78.5
		BTU/h	267,800
	Power input	kW	24.07
		A	40.6-38.6-37.2
		kW/kW	3.26
	(Nominal)	COP	3.26
		kW	73.5
		BTU/h	250,800
	Power input	kW	21.18
		A	35.7-33.9-32.7
Temp. range of heating	*4	Indoor	D.B.
		Outdoor	W.B.
			15.0~27.0°C (59~81°F) -20.0~15.5°C (-4~60°F)
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity
	Model/Quantity		P10~P250, M20~M140/2~50
Sound pressure level (measured in anechoic room) *5, 6		dB <A>	65.0/69.0
Sound power level (measured in anechoic room) *5		dB <A>	84/88
Refrigerant piping diameter	High pressure		mm (in.)
	Low pressure		mm (in.)

Set Model			PURY-P350YNW-A2/TR2/RU2 (-BS)		PURY-P300YNW-A2/TR2/RU2 (-BS)	
Model						
FAN	Type x Quantity		Propeller fan x 2		Propeller fan x 1	
	Air flow rate	m ³ /min	250		240	
		L/s	4,167		4,000	
		cfm	8,828		8,474	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
	Motor output	kW	0.46 x 2		0.92 x 1	
	*7	External static press.		0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output	kW	12.0		9.2	
	Case heater	kW	-		-	
	Lubricant		MEL32		MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) 			

Notes:	Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	BTU/h = kW x 3,412 cfm = m ³ /min x 35.31 lbs = kg/0.4536
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered	
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.	
5. Cooling mode/Heating mode	
6. The sound pressure level measured by the conventional method in JIS for reference purpose.	
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.	*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P700YSNW-A2/TR2/RU2 (-BS)	
Power source			3-phase 4-wire 380~400-415 V 50/60 Hz	
Cooling capacity	*1	kW	80.0	
		BTU/h	273,000	
	Power input	kW	30.76	
		A	51.9-49.3-47.5	
		kW/kW	2.60	
		kW/kW	5.80	
Temp. range of cooling	*4	Indoor	15.0~24.0°C (59~75°F)	
		Outdoor	-5.0~52.0°C (23~126°F)	
Heating capacity (Max)	*2	kW	90.0	
		BTU/h	307,100	
	Power input	kW	28.66	
		A	48.3-45.9-44.3	
		kW/kW	3.14	
		COP	80.0	
	(Nominal)	*3 kW	273,000	
		BTU/h	22.47	
	Power input	kW	37.9-36.0-34.7	
		A	3.56	
		kW/kW	3.53	
		SCOP	5.80	
Temp. range of heating	*4	Indoor	15.0~27.0°C (59~81°F)	
		Outdoor	-20.0~15.5°C (-4~60°F)	
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity	
	Model/Quantity		P10~P250, M20~M140/2~50	
Sound pressure level (measured in anechoic room) *5, 6		dB <A>	65.5/67.0	
Sound power level (measured in anechoic room) *5		dB <A>	84/86	
Refrigerant		High pressure	28.58 (1-1/8) Brazed	
piping diameter		Low pressure	34.93 (1-3/8) Brazed	

Set Model			PURY-P350YNW-A2/TR2/RU2 (-BS)		PURY-P350YNW-A2/TR2/RU2 (-BS)	
Model			Propeller fan x 2		Propeller fan x 2	
FAN	Type x Quantity		250		250	
	Air flow rate	m ³ /min	4,167		4,167	
		L/s	8,828		8,828	
		cfm				
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
	Motor output	kW	0.46 x 2		0.46 x 2	
*7	External static press.		0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)	
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output	kW	12.0		12.0	
	Case heater	kW	-		-	
	Lubricant	MEL32		MEL32		
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>		Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>	
External dimension H x W x D		mm	1,858 (1,798 without legs) x 1,240 x 740		1,858 (1,798 without legs) x 1,240 x 740	
		in.	73-3/16 (70-13/16 without legs) x 48-7/8 x 29-3/16		73-3/16 (70-13/16 without legs) x 48-7/8 x 29-3/16	
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection		Over-heat protection, Over-current protection	
	Compressor		-		-	
	Fan motor		-		-	
Refrigerant	Type x original charge		R410A x 8.0 kg (18 lbs)		R410A x 8.0 kg (18 lbs)	
	Control		Indoor LEV and BC controller			
Net weight		kg (lbs)	269 (594)		269 (594)	
Heat exchanger			Salt-resistant cross fin & copper tube		Salt-resistant cross fin & copper tube	
HIC circuit (HIC: Heat Inter-Changer)			-		-	
Pipe between unit and distributor	High pressure	mm (in.)	19.05 (3/4) Brazed		19.05 (3/4) Brazed	
	Low pressure	mm (in.)	28.58 (1-1/8) Brazed		28.58 (1-1/8) Brazed	
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing	External	WKB94C4W1				
	Wiring	WKE94L191		WKE94L191		
Standard attachment	Document	Installation Manual				
	Accessory	-				
Optional parts			Outdoor Twinning kit: CMY-R200VBK4 Joint: CMY-Y102SS-G2,CMY-Y102LS-G2,CMY-R160-J1 Main BC controller: CMB-M108,1012,1016V-JA1,CMB-P1016V-KA1 Sub BC controller: CMB-M104,108V-KB1			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:			Unit converter	
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)			BTU/h	=kW x 3,412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)			cfm	=m ³ /min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered			lbs	=kg/0.4536
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.				
5. Cooling mode/Heating mode				
6. The sound pressure level measured by the conventional method in JIS for reference purpose.				
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.			*Above specification data is subject to rounding variation.	

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P750YSNW-A2/TR2/RU2 (-BS)		
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz		
Cooling capacity	*1	kW	85.0		
		BTU/h	290,000		
		Power input	kW		35.26
		Current input	A		59.5-56.5-54.5
		EER	kW/kW		2.41
		SEER	kW/kW		5.72
Temp. range of cooling	*4	Indoor	W.B.	15.0~24.0°C (59~75°F)	
		Outdoor	D.B.	-5.0~52.0°C (23~126°F)	
Heating capacity (Max)	*2	kW	95.0		
		BTU/h	324,100		
		Power input	kW		31.35
		Current input	A		52.9-50.2-48.4
		COP	kW/kW		3.03
	(Nominal) *3	kW	85.0		
		BTU/h	290,000		
		Power input	kW		24.92
		Current input	A		42.0-39.9-38.5
		COP	kW/kW		3.41
Temp. range of heating	*4	Indoor	D.B.	15.0~27.0°C (59~81°F)	
		Outdoor	W.B.	-20.0~15.5°C (-4~60°F)	
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity		
	Model/Quantity		P10~P250, M20~M140/2~50		
Sound pressure level (measured in anechoic room) *5, 6		dB <A>	67.0/70.5		
Sound power level (measured in anechoic room) *5		dB <A>	86/90		
Refrigerant piping diameter	High pressure	mm (in.)	28.58 (1-1/8) Brazed		
	Low pressure	mm (in.)	34.93 (1-3/8) Brazed		

Set Model			PURY-P400YNW-A2/TR2/RU2 (-BS)		PURY-P350YNW-A2/TR2/RU2 (-BS)	
Model						
FAN	Type x Quantity		Propeller fan x 2		Propeller fan x 2	
	Air flow rate	m ³ /min	315		250	
		L/s	5,250		4,167	
		cfm	11,123		8,828	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
	Motor output	kW	0.46 x 2		0.46 x 2	
	*7	External static press.		0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output	kW	16.1		12.0	
	Case heater	kW	-		-	
	Lubricant		MEL32		MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) 			

Notes:	Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	BTU/h = kW x 3,412 cfm = m ³ /min x 35.31 lbs = kg/0.4536
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered	
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.	
5. Cooling mode/Heating mode	
6. The sound pressure level measured by the conventional method in JIS for reference purpose.	
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.	*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P800YSNW-A2/TR2/RU2 (-BS)			
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz			
Cooling capacity	*1	kW	90.0			
		BTU/h	307,100			
	Power input	kW	40.54			
		Current input	A	68.4-65.0-62.6		
		EER	kW/kW	2.22		
		SEER	kW/kW	5.65		
Temp. range of cooling	Indoor	W.B.	15.0~24.0°C (59~75°F)			
	*4 Outdoor	D.B.	-5.0~52.0°C (23~126°F)			
Heating capacity (Max)	*2	kW	100.0			
		BTU/h	341,200			
	Power input	kW	34.36			
		Current input	A	58.0-55.1-53.1		
		COP	kW/kW	2.91		
		(Nominal)	*3	kW	90.0	
	BTU/h			307,100		
	Power input		kW	27.60		
			Current input	A	46.5-44.2-42.6	
			COP	kW/kW	3.26	
			SCOP	kW/kW	3.51	
	Temp. range of heating	Indoor	D.B.	15.0~27.0°C (59~81°F)		
*4 Outdoor		W.B.	-20.0~15.5°C (-4~60°F)			
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity			
	Model/Quantity		P10~P250, M20~M140/2~50			
Sound pressure level (measured in anechoic room) *5, 6		dB <A>	68.0/72.0			
Sound power level (measured in anechoic room) *5		dB <A>	86/91			
Refrigerant piping diameter	High pressure	mm (in.)	28.58 (1-1/8) Brazed			
	Low pressure	mm (in.)	34.93 (1-3/8) Brazed			

Set Model			PURY-P400YNW-A2/TR2/RU2 (-BS)		PURY-P400YNW-A2/TR2/RU2 (-BS)	
Model						
FAN	Type x Quantity		Propeller fan x 2		Propeller fan x 2	
	Air flow rate	m ³ /min	315		315	
		L/s	5,250		5,250	
		cfm	11,123		11,123	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
	Motor output	kW	0.46 x 2		0.46 x 2	
	*7	External static press.		0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output	kW	16.1		16.1	
	Case heater	kW	-		-	
	Lubricant		MEL32		MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>		Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>	
External dimension H x W x D		mm	1,858 (1,798 without legs) x 1,240 x 740		1,858 (1,798 without legs) x 1,240 x 740	
		in.	73-3/16 (70-13/16 without legs) x 48-7/8 x 29-3/16		73-3/16 (70-13/16 without legs) x 48-7/8 x 29-3/16	
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection		Over-heat protection, Over-current protection	
	Compressor		-		-	
	Fan motor		-		-	
Refrigerant	Type x original charge		R410A x 8.0 kg (18 lbs)		R410A x 8.0 kg (18 lbs)	
	Control		Indoor LEV and BC controller			
Net weight		kg (lbs)	269 (594)		269 (594)	
Heat exchanger			Salt-resistant cross fin & copper tube		Salt-resistant cross fin & copper tube	
HIC circuit (HIC: Heat Inter-Changer)			-		-	
Pipe between unit and distributor	High pressure	mm (in.)	22.2 (7/8) Brazed		22.2 (7/8) Brazed	
	Low pressure	mm (in.)	28.58 (1-1/8) Brazed		28.58 (1-1/8) Brazed	
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing	External		WKB94C4W1			
	Wiring		WKE94L191		WKE94L191	
Standard attachment	Document		Installation Manual			
	Accessory		-			
Optional parts			Outdoor Twinning kit: CMY-R200VBK4 Joint: CMY-Y102SS-G2, CMY-Y102LS-G2, CMY-R160-J1 Main BC controller: CMB-M108, 1012, 1016V-JA1, CMB-P1016V-KA1 Sub BC controller: CMB-M104, 108V-KB1			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:		Unit converter	
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		BTU/h	=kW x 3,412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		cfm	=m ³ /min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered		lbs	=kg/0.4536
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.			
5. Cooling mode/Heating mode			
6. The sound pressure level measured by the conventional method in JIS for reference purpose.			
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.			*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P850YSNW-A2/TR2/RU2 (-BS)			
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz			
Cooling capacity	*1	kW	95.0			
		BTU/h	324,100			
		Power input	kW		40.77	
		Current input	A		68.8-65.3-63.0	
		EER	kW/kW		2.33	
		SEER	kW/kW		5.92	
Temp. range of cooling	*4	Indoor	W.B.	15.0~24.0°C (59~75°F)		
		Outdoor	D.B.	-5.0~52.0°C (23~126°F)		
Heating capacity (Max)	*2	kW	106.0			
		BTU/h	361,700			
		Power input	kW		36.55	
		Current input	A		61.7-58.6-56.4	
		COP	kW/kW		2.90	
	(Nominal) *3	kW	95.0			
		BTU/h	324,100			
		Power input	kW		29.59	
		Current input	A		49.9-47.4-45.7	
		COP	kW/kW		3.21	
Temp. range of heating	*4	SCOP	kW/kW		3.51	
		Indoor	D.B.	15.0~27.0°C (59~81°F)		
		Outdoor	W.B.	-20.0~15.5°C (-4~60°F)		
		Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity	
		Indoor unit connectable	Model/Quantity		P10~P250, M20~M140/2~50	
Sound pressure level (measured in anechoic room) *5, 6		dB <A>	68.5/72.5			
Sound power level (measured in anechoic room) *5		dB <A>	86/92			
Refrigerant piping diameter	High pressure	mm (in.)	28.58 (1-1/8) Brazed			
	Low pressure	mm (in.)	41.28 (1-5/8) Brazed			

Set Model			PURY-P450YNW-A2/TR2/RU2 (-BS)		PURY-P400YNW-A2/TR2/RU2 (-BS)	
Model						
FAN	Type x Quantity		Propeller fan x 2		Propeller fan x 2	
	Air flow rate	m ³ /min	315		315	
		L/s	5,250		5,250	
		cfm	11,123		11,123	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
	Motor output	kW	0.46 x 2		0.46 x 2	
	*7	External static press.		0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output	kW	16.2		16.1	
	Case heater	kW	-		-	
	Lubricant		MEL32		MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) 			

Notes:	Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	BTU/h = kW x 3,412 cfm = m ³ /min x 35.31 lbs = kg/0.4536
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered	
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.	
5. Cooling mode/Heating mode	
6. The sound pressure level measured by the conventional method in JIS for reference purpose.	
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.	*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P900YSNW-A2/TR2/RU2 (-BS)		
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz		
Cooling capacity	*1	kW	100.0		
		BTU/h	341,200		
	Power input	kW	40.98		
	Current input	A	69.1-65.7-63.3		
	EER	kW/kW	2.44		
SEER	kW/kW	6.19			
Temp. range of cooling	Indoor	W.B.	15.0~24.0°C (59~75°F)		
	*4 Outdoor	D.B.	-5.0~52.0°C (23~126°F)		
Heating capacity (Max)	*2	kW	112.0		
		BTU/h	382,100		
	Power input	kW	38.75		
	Current input	A	65.4-62.1-59.8		
	COP	kW/kW	2.89		
	(Nominal)	*3	kW	100.0	
			BTU/h	341,200	
		Power input	kW	31.64	
		Current input	A	53.4-50.7-48.9	
		COP	kW/kW	3.16	
SCOP		kW/kW	3.51		
Temp. range of heating	Indoor	D.B.	15.0~27.0°C (59~81°F)		
	*4 Outdoor	W.B.	-20.0~15.5°C (-4~60°F)		
Indoor unit connectable	Total capacity	50~150% of outdoor unit capacity			
	Model/Quantity	P10~P250, M20~M140/2~50			
Sound pressure level (measured in anechoic room) *5, 6		dB <A>	68.5/73.0		
Sound power level (measured in anechoic room) *5		dB <A>	86/92		
Refrigerant	High pressure	mm (in.)	28.58 (1-1/8) Brazed		
piping diameter	Low pressure	mm (in.)	41.28 (1-5/8) Brazed		

Model			PURY-P450YNW-A2/TR2/RU2 (-BS)		PURY-P450YNW-A2/TR2/RU2 (-BS)	
FAN	Type x Quantity		Propeller fan x 2		Propeller fan x 2	
	Air flow rate	m ³ /min	315		315	
		L/s	5,250		5,250	
		cfm	11,123		11,123	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
Compressor	*7	Motor output	kW		0.46 x 2	
		External static press.	0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)	
	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output		kW		16.2	
External finish	Case heater		kW		-	
	Lubricant		MEL32		MEL32	
	Pre-coated galvanized steel sheets (+powder coating for -BS type)		<MUNSELL 5Y 8/1 or similar>		<MUNSELL 5Y 8/1 or similar>	
	External dimension H x W x D		mm		1,858 (1,798 without legs) x 1,240 x 740	
	in.		73-3/16 (70-13/16 without legs) x 48-7/8 x 29-3/16		73-3/16 (70-13/16 without legs) x 48-7/8 x 29-3/16	
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection		Over-heat protection, Over-current protection	
	Compressor		-		-	
	Fan motor		-		-	
	Refrigerant		Type x original charge		R410A x 10.8 kg (24 lbs)	
Net weight	Control		Indoor LEV and BC controller		R410A x 10.8 kg (24 lbs)	
	kg (lbs)		289 (638)		289 (638)	
	Heat exchanger		Salt-resistant cross fin & copper tube		Salt-resistant cross fin & copper tube	
	HIC circuit (HIC: Heat Inter-Changer)		-		-	
	Pipe between unit and distributor		High pressure		mm (in.)	
Defrosting method	Low pressure		mm (in.)		22.2 (7/8) Brazed	
	Auto-defrost mode (Reversed refrigerant cycle)		28.58 (1-1/8) Brazed		28.58 (1-1/8) Brazed	
	Drawing		External		WKB94C4W1	
	Wiring		WKE94L191		WKE94L191	
	Standard attachment		Document		Installation Manual	
Optional parts	Accessory		-		-	
	Outdoor Twinning kit: CMY-R200VBK4		Joint: CMY-Y102SS-G2, CMY-Y102LS-G2, CMY-R160-J1		Main BC controller: CMB-M108, 1012, 1016V-JA1, CMB-P1016V-KA1	
	Sub BC controller: CMB-M104, 108V-KB1		-		-	
	Remarks		Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual.		Due to continuing improvement, above specifications may be subject to change without notice.	
	-		-		-	

Notes:			Unit converter	
1. Nominal cooling conditions (subject to JIS B8615-2)			BTU/h =kW x 3,412	
Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.)			cfm =m ³ /min x 35.31	
Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)			lbs =kg/0.4536	
2. Nominal heating conditions (subject to JIS B8615-2)			-	
Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.)			-	
Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)			-	
3. Nominal heating conditions (subject to JIS B8615-2)			-	
Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.)			-	
Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)			-	
Eurovent registered			-	
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.)			-	
with cooling/heating mixed operation.			-	
5. Cooling mode/Heating mode			-	
6. The sound pressure level measured by the conventional method in JIS for reference purpose.			-	
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O).			-	
Consult your dealer about the specification when setting External static pressure option.			*Above specification data is subject to rounding variation.	

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P950YSNW-A2/TR2/RU2 (-BS)		
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz		
Cooling capacity	*1	kW	106.0		
		BTU/h	361,700		
	Power input	kW	43.44		
	Current input	A	73.3-69.6-67.1		
	EER	kW/kW	2.44		
	SEER	kW/kW	6.12		
Temp. range of cooling	Indoor	W.B.	15.0~24.0°C (59~75°F)		
	*4 Outdoor	D.B.	-5.0~52.0°C (23~126°F)		
Heating capacity (Max)	*2	kW	119.0		
		BTU/h	406,000		
	Power input	kW	41.17		
	Current input	A	69.5-66.0-63.6		
	COP	kW/kW	2.89		
	(Nominal)	*3	kW	106.0	
			BTU/h	361,700	
		Power input	kW	33.12	
		Current input	A	55.9-53.1-51.1	
		COP	kW/kW	3.20	
SCOP		kW/kW	3.51		
Temp. range of heating	Indoor	D.B.	15.0~27.0°C (59~81°F)		
	*4 Outdoor	W.B.	-20.0~15.5°C (-4~60°F)		
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity		
	Model/Quantity		P10~P250, M20~M140/2~50		
Sound pressure level (measured in anechoic room) *5, 6		dB <A>	68.0/71.5		
Sound power level (measured in anechoic room) *5		dB <A>	86/91		
Refrigerant piping diameter	High pressure	mm (in.)	28.58 (1-1/8) Brazed		
	Low pressure	mm (in.)	41.28 (1-5/8) Brazed		

Set Model			PURY-P500YNW-A2/TR2/RU2 (-BS)		PURY-P450YNW-A2/TR2/RU2 (-BS)	
Model						
FAN	Type x Quantity		Propeller fan x 2		Propeller fan x 2	
	Air flow rate	m ³ /min	295		315	
		L/s	4,917		5,250	
		cfm	10,416		11,123	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
	Motor output	kW	0.92 x 2		0.46 x 2	
	*7	External static press.		0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output	kW	17.4		16.2	
	Case heater	kW	-		-	
	Lubricant		MEL32		MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) 			

Notes:	Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	BTU/h = kW x 3,412 cfm = m ³ /min x 35.31 lbs = kg/0.4536
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered	
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.	
5. Cooling mode/Heating mode	
6. The sound pressure level measured by the conventional method in JIS for reference purpose.	
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.	*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P1000YSNW-A2/TR2/RU2 (-BS)			
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz			
Cooling capacity	*1	kW	112.0			
		BTU/h	382,100			
	Power input	kW	45.90			
		Current input	A	77.4-73.6-70.9		
		EER	kW/kW	2.44		
		SEER	kW/kW	6.05		
Temp. range of cooling	Indoor	W.B.	15.0~24.0°C (59~75°F)			
	*4 Outdoor	D.B.	-5.0~52.0°C (23~126°F)			
Heating capacity (Max)	*2	kW	126.0			
		BTU/h	429,900			
	Power input	kW	43.59			
		Current input	A	73.5-69.9-67.3		
		COP	kW/kW	2.89		
		(Nominal)	*3	kW	112.0	
	BTU/h			382,100		
	Power input		kW	34.56		
			Current input	A	58.3-55.4-53.4	
			COP	kW/kW	3.24	
			SCOP	kW/kW	3.51	
	Temp. range of heating	Indoor	D.B.	15.0~27.0°C (59~81°F)		
*4 Outdoor		W.B.	-20.0~15.5°C (-4~60°F)			
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity			
	Model/Quantity		P10~P250, M20~M140/2~50			
Sound pressure level (measured in anechoic room) *5, 6		dB <A>	66.5/67.5			
Sound power level (measured in anechoic room) *5		dB <A>	85/87			
Refrigerant	High pressure	mm (in.)	28.58 (1-1/8) Brazed			
piping diameter	Low pressure	mm (in.)	41.28 (1-5/8) Brazed			

Set Model			Low pressure		High pressure		FAN (P-03) Brazed	
Model			PURY-P500YNW-A2/TR2/RU2 (-BS)				PURY-P500YNW-A2/TR2/RU2 (-BS)	
FAN	Type x Quantity		Propeller fan x 2				Propeller fan x 2	
	Air flow rate	m ³ /min	295				295	
		L/s	4,917				4,917	
		cfm	10,416				10,416	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor				Inverter-control, Direct-driven by motor	
	Motor output	kW	0.92 x 2				0.92 x 2	
	*7	External static press.		0 Pa (0 mmH ₂ O)				0 Pa (0 mmH ₂ O)
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1				Inverter scroll hermetic compressor x 1	
	Starting method		Inverter				Inverter	
	Motor output	kW	17.4				17.4	
	Case heater	kW	-				-	
	Lubricant		MEL32				MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>				Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>	
External dimension H x W x D		mm	1,858 (1,798 without legs) x 1,750 x 740				1,858 (1,798 without legs) x 1,750 x 740	
		in.	73-3/16 (70-13/16 without legs) x 68-15/16 x 29-3/16				73-3/16 (70-13/16 without legs) x 68-15/16 x 29-3/16	
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)				High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection				Over-heat protection, Over-current protection	
	Compressor		-				-	
	Fan motor		-				-	
Refrigerant	Type x original charge		R410A x 10.8 kg (24 lbs)				R410A x 10.8 kg (24 lbs)	
	Control		Indoor LEV and BC controller					
Net weight		kg (lbs)	335 (739)				335 (739)	
Heat exchanger			Salt-resistant cross fin & copper tube				Salt-resistant cross fin & copper tube	
HIC circuit (HIC: Heat Inter-Changer)			-				-	
Pipe between unit and distributor	High pressure	mm (in.)	22.2 (7/8) Brazed				22.2 (7/8) Brazed	
	Low pressure	mm (in.)	28.58 (1-1/8) Brazed				28.58 (1-1/8) Brazed	
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)					
Drawing	External		WKB94C4W3					
	Wiring		WKE94L192				WKE94L192	
Standard attachment	Document		Installation Manual					
	Accessory		-					
Optional parts			Outdoor Twinning kit: CMY-R200VBK4 Joint: CMY-Y102SS-G2, CMY-Y102LS-G2, CMY-R160-J1 Main BC controller: CMB-P1016V-KA1 Sub BC controller: CMB-M104, 108V-KB1					
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.					

Notes:			Unit converter	
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)			BTU/h	=kW x 3,412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)			cfm	=m ³ /min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered			lbs	=kg/0.4536
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.				
5. Cooling mode/Heating mode				
6. The sound pressure level measured by the conventional method in JIS for reference purpose.				
7. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.			*Above specification data is subject to rounding variation.	

1. SPECIFICATIONS

R2-Series

Model			PURY-P1050YSNW-A2/TR2/RU2 (-BS)		
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz		
Cooling capacity	*1	kW	116.0		
		BTU/h	395,800		
	Power input	kW	49.36		
	Current input	A	83.3-79.1-76.2		
	EER	kW/kW	2.35		
	SEER	kW/kW	6.06		
Temp. range of cooling	Indoor	W.B.	15.0~24.0°C (59~75°F)		
	*4 Outdoor	D.B.	-5.0~52.0°C (23~126°F)		
Heating capacity (Max)	*2	kW	132.0		
		BTU/h	450,400		
	Power input	kW	46.97		
	Current input	A	79.2-75.3-72.6		
	COP	kW/kW	2.81		
	(Nominal)	*3	kW	119.0	
			BTU/h	406,000	
		Power input	kW	37.77	
		Current input	A	63.7-60.5-58.3	
		COP	kW/kW	3.15	
SCOP		kW/kW	3.51		
Temp. range of heating	Indoor	D.B.	15.0~27.0°C (59~81°F)		
	*4 Outdoor	W.B.	-20.0~15.5°C (-4~60°F)		
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity		
	Model/Quantity		P10~P250, M20~M140/3~50		
Sound pressure level (measured in anechoic room) *5, 6		dB <A>	71.0/71.5		
Sound power level (measured in anechoic room) *5		dB <A>	90/91		
Refrigerant piping diameter	High pressure	mm (in.)	34.93 (1-3/8) Brazed		
	Low pressure	mm (in.)	41.28 (1-5/8) Brazed		

Set Model			PURY-P550YNW-A2/TR2/RU2 (-BS)		PURY-P500YNW-A2/TR2/RU2 (-BS)	
Model						
FAN	Type x Quantity		Propeller fan x 2		Propeller fan x 2	
	Air flow rate	m ³ /min	410		295	
		L/s	6,833		4,917	
		cfm	14,477		10,416	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
	Motor output	kW	0.92 x 2		0.92 x 2	
*7	External static press.		0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)	
	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output	kW	20.5		17.4	
	Case heater	kW	-		-	
	Lubricant		MEL32		MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>		Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>	
External dimension H x W x D		mm	1,858 (1,798 without legs) x 1,750 x 740		1,858 (1,798 without legs) x 1,750 x 740	
		in.	73-3/16 (70-13/16 without legs) x 68-15/16 x 29-3/16		73-3/16 (70-13/16 without legs) x 68-15/16 x 29-3/16	
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection		Over-heat protection, Over-current protection	
	Compressor		-		-	
	Fan motor		-		-	
Refrigerant	Type x original charge		R410A x 10.8 kg (24 lbs)		R410A x 10.8 kg (24 lbs)	
	Control		Indoor LEV and BC controller			
Net weight		kg (lbs)	335 (739)		335 (739)	
Heat exchanger			Salt-resistant cross fin & copper tube		Salt-resistant cross fin & copper tube	
HIC circuit (HIC: Heat Inter-Changer)			-		-	
Pipe between unit and distributor	High pressure	mm (in.)	22.2 (7/8) Brazed		22.2 (7/8) Brazed	
	Low pressure	mm (in.)	28.58 (1-1/8) Brazed		28.58 (1-1/8) Brazed	
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing	External		WKB94C4W3			
	Wiring		WKE94L192		WKE94L192	
Standard attachment	Document		Installation Manual			
	Accessory		-			
Optional parts			Outdoor Twinning kit: CMY-R200VBK4 Joint: CMY-Y102SS-G2,CMY-Y102LS-G2,CMY-R160-J1 Main BC controller: CMB-P1016V-KA1 Sub BC controller: CMB-M104,108V-KB1			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:	Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	BTU/h = kW x 3,412 cfm = m ³ /min x 35.31 lbs = kg/0.4536
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)	
4. -10 °C D.B. (14 °F D.B.)/-11 °C W.B. (12 °F W.B.) to 21 °C D.B. (70 °F D.B.)/15.5 °C W.B. (60 °F W.B.) with cooling/heating mixed operation.	
5. Cooling mode/Heating mode	
6. The sound pressure level measured by the conventional method in JIS for reference purpose.	
7. External static pressure option is available (30 Pa/3.1 mmH ₂ O).	
Consult your dealer about the specification when setting External static pressure option.	*Above specification data is subject to rounding variation.

1. SPECIFICATIONS

R2-Series

PURY-P-Y(S)NW-A2/TR2/RU2

Model			PURY-P1100YSNW-A2/TR2/RU2 (-BS)	
Power source			3-phase 4-wire 380~400~415 V 50/60 Hz	
Cooling capacity	*1	kW	120.0	
		BTU/h	409,400	
	Power input	kW	53.32	
		Current input	90.0-85.5-82.4	
		EER	2.25	
Temp. range of cooling	*4	SEER	6.06	
		Indoor	15.0~24.0°C (59~75°F)	
	Outdoor	W.B.	-5.0~52.0°C (23~126°F)	
		D.B.		
Heating capacity (Max)	*2	kW	138.0	
		BTU/h	470,900	
	Power input	kW	50.54	
		Current input	85.3-81.0-78.1	
		COP	2.73	
	(Nominal)	*3		
		kW	126.0	
	Power input	BTU/h	429,900	
		kW	41.17	
		Current input	69.5-66.0-63.6	
Temp. range of heating	*4	COP	3.06	
		SCOP	3.51	
	Indoor	D.B.	15.0~27.0°C (59~81°F)	
		W.B.	-20.0~15.5°C (-4~60°F)	
Indoor unit connectable	Total capacity		50~150% of outdoor unit capacity	
	Model/Quantity		P10~P250, M20~M140/3~50	
Sound pressure level (measured in anechoic room) *5, 6		dB <A>	73.0/73.0	
Sound power level (measured in anechoic room) *5		dB <A>	92/92	
Refrigerant		High pressure	34.93 (1-3/8) Brazed	
piping diameter		Low pressure	41.28 (1-5/8) Brazed	


Set Model			PURY-P550YNW-A2/TR2/RU2 (-BS)		PURY-P550YNW-A2/TR2/RU2 (-BS)	
Model			Propeller fan x 2		Propeller fan x 2	
FAN	Type x Quantity		Propeller fan x 2		Propeller fan x 2	
	Air flow rate	m ³ /min	410		410	
		L/s	6,833		6,833	
		cfm	14,477		14,477	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor		Inverter-control, Direct-driven by motor	
	Motor output	kW	0.92 x 2		0.92 x 2	
*7	External static press.		0 Pa (0 mmH ₂ O)		0 Pa (0 mmH ₂ O)	
Compressor	Type x Quantity		Inverter scroll hermetic compressor x 1		Inverter scroll hermetic compressor x 1	
	Starting method		Inverter		Inverter	
	Motor output	kW	20.5		20.5	
	Case heater	kW	-		-	
	Lubricant	MEL32		MEL32		
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>		Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>	
External dimension H x W x D		mm	1,858 (1,798 without legs) x 1,750 x 740		1,858 (1,798 without legs) x 1,750 x 740	
		in.	73-3/16 (70-13/16 without legs) x 68-15/16 x 29-3/16		73-3/16 (70-13/16 without legs) x 68-15/16 x 29-3/16	
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection		Over-heat protection, Over-current protection	
	Compressor		-		-	
	Fan motor		-		-	
Refrigerant	Type x original charge		R410A x 10.8 kg (24 lbs)		R410A x 10.8 kg (24 lbs)	
	Control		Indoor LEV and BC controller			
Net weight		kg (lbs)	335 (739)		335 (739)	
Heat exchanger			Salt-resistant cross fin & copper tube		Salt-resistant cross fin & copper tube	
HIC circuit (HIC: Heat Inter-Changer)			-		-	
Pipe between unit and distributor	High pressure	mm (in.)	22.2 (7/8) Brazed		22.2 (7/8) Brazed	
	Low pressure	mm (in.)	28.58 (1-1/8) Brazed		28.58 (1-1/8) Brazed	
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing	External	WKB94C4W3				
	Wiring	WKE94L192		WKE94L192		
Standard attachment	Document	Installation Manual				
	Accessory	-				
Optional parts			Outdoor Twinning kit: CMY-R200VBK4 Joint: CMY-Y102SS-G2,CMY-Y102LS-G2,CMY-R160-J1 Main BC controller: CMB-P1016V-KA1 Sub BC controller: CMB-M104,108V-KB1			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:		Unit converter	
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		BTU/h	=kW x 3,412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		cfm	=m ³ /min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered		lbs	=kg/0.4536
4. -10 °C D.B./14 °F D.B./-11 °C W.B./12 °F W.B. to 21 °C D.B./70 °F D.B./15.5 °C W.B./60 °F W.B.) with cooling/heating mixed operation.			
5. Cooling mode/Heating mode			
6. The sound pressure level measured by the conventional method in JIS for reference purpose.			
7. External static pressure option is available (30 Pa/3.1 mmH ₂ O).			
Consult your dealer about the specification when setting External static pressure option.		*Above specification data is subject to rounding variation.	

PURY-P200, 250, 300YNW-A2/TR2/RU2 (-BS)

Unit: mm

- Note 1. Please refer to the next page for information regarding necessary spacing around the unit and foundation work.
2. The detachable leg can be removed at site.
3. At brazing of pipes, wrap the refrigerant service valve with wet cloth and keep the temperature of refrigerant service valve under 120°C.



PURY-P200, 250, 300YNW-A2/TR2/RU2 (-BS)


Unit: mm

◆:When installing a panel heater<Optional parts>

1. Required space around the unit


●In case of single installation

- ① Secure enough space around the unit as shown in the figure below.
 - With a space of at least 300mm(450mm) to the wall on the back of the unit



- ② When the height of the walls on the front, back or on the sides <H> exceeds the wall height limit as defined below

add half of the height that exceeds the height limit <h/2> to the figures that are marked with an asterisk(*).



2. Foundation work

- ① Take into consideration the surface strength, water drainage route, piping route, and wiring route when preparing the installation site.
 - <Note that the drain water comes out of the unit during operation.>
- ② Build the foundation in such way that the corner of the installation leg is securely supported as shown in the right figure.(Fig.A,B)
 - When using a rubber isolating cushion, please ensure it is large enough to cover the entire width of each of the unit's legs.
- ③ The protrusion length of the anchor bolt must not exceed 30mm.(Fig.A,B)
- ④ Use four fixing plates as shown in the right figure <field supply required> when using M12 hole-in anchor bolts <field supply required>.(Fig.C,D)
- ⑤ To prevent small animals and water and snow from entering the unit and damaging its parts, close the gap around the edges of through holes for pipes and wires with filler plates <field supply required>.
- ⑥ When the pipes or cables are routed at the bottom of the unit, make sure that the through hole at the base of the unit does not get blocked with the installation base.
- ⑦ Refer to the Installation Manual when installing units on an installation base.

●In case of collective installation

- ① When multiple units are installed adjacent to each other, secure enough space to allow for air circulation and walkway between groups of units as shown in the figures below.
- ② At least two sides must be left open.
- ③ As with the single installation, add half of the height that exceeds the height limit <h/2> to the figures that are marked with an asterisk(*).
- ④ If there is a wall at both the front and the rear of the unit, install up to six units consecutively in the side direction and provide a space of 1000mm or more as inlet space/ passage space for each six units.





Fig.A (without detachable legs)




Fig.B (with detachable legs)




Fig.C (without detachable legs)




Fig.D (with detachable legs)

◆Outline dwg at panel heater installation

PURY-P350, 400, 450YNW-A2/TR2/RU2 (-BS)

Unit: mm

1. Please refer to the next page for information regarding necessary spacing around the unit and foundation work.
2. The detachable leg can be removed at site.
3. At brazing of pipes, wrap the refrigerant service valve with wet cloth and keep the temperature of refrigerant service valve under 120°C.



Connecting pipe specification		Diameter			
Model		Refrigerant pipe		Service valve	
		High pressure	Low pressure	High pressure	Low pressure
P350	ø19.05 Brazed ^{*)}	ø28.58	Brazed	ø28.58	ø28.58
P400	ø22.2 Brazed ^{*)}	ø28.58	Brazed	ø28.58	ø28.58
P450	ø22.2 Brazed ^{*)}	ø28.58	Brazed	ø28.58	ø28.58

Connect the refrigerant pipe to the service valve according to the Installation Manual.

PURY-P350, 400, 450YNW-A2/TR2/RU2 (-BS)


Unit: mm

◆:When installing a panel heater<Optional parts>


1. Required space around the unit

◆In case of single installation

- ①Secure enough space around the unit as shown in the figure below.
 - With a space of at least 300mm(450mm) to the wall on the back of the unit



- ②When the height of the walls on the front, back or on the sides <H> exceeds the wall height limit as defined below add half of the height that exceeds the height limit <H/2> to the figures that are marked with an asterisk(*).



2. Foundation work

- ①Take into consideration the surface strength, water drainage route, piping route, and wiring route when preparing the installation site.
 - <Note that the drain water comes out of the unit during operation.>
- ②Build the foundation in such way that the corner of the installation leg is securely supported as shown in the right figure.(Fig.A,B)
 - When using a rubber isolating cushion, please ensure it is large enough to cover the entire width of each of the unit's legs.
- ③The protrusion length of the anchor bolt must not exceed 30mm.(Fig.A,B)
- ④Use four fixing plates as shown in the right figure <field supply required> when using M12 hole-in anchor bolts <field supply required> (Fig.C,D)
- ⑤To prevent small animals and water and snow from entering the unit and damaging its parts, close the gap around the edges of through holes for pipes and wires with filler plates <field supply required>.
- ⑥When the pipes or cables are routed at the bottom of the unit, make sure that the through hole at the base of the unit does not get blocked with the installation base.
- ⑦Refer to the Installation Manual when installing units on an installation base.

◆In case of collective installation

- ①When multiple units are installed adjacent to each other, secure enough space to allow for air circulation and walkway between groups of units as shown in the figures below.
- ②At least two sides must be left open.
- ③As with the single installation, add half of the height that exceeds the height limit <H/2> to the figures that are marked with an asterisk(*).
- ④If there is a wall at both the front and the rear of the unit, install up to six units consecutively in the side direction and provide a space of 1000mm or more as inlet space/passage space for each six units.





Fig.A (without detachable legs)




Fig.B (with detachable legs)




Fig.C (without detachable legs)



Fig.D (with detachable legs)


◆Outline dwg at panel heater installation

PURY-P500, 550YNW-A2/TR2/RU2 (-BS)

Unit: mm

Note 1 Please refer to the next page for information regarding necessary spacing around the unit and foundation work.

2. The detachable leg can be removed at site.
3. At brazing of pipes, wrap the refrigerant service valve with wet cloth and keep the temperature of refrigerant service valve under 120°C.



Model	Diameter			
	Refrigerant pipe		Service valve	
	High pressure	Low pressure	High pressure	Low pressure
P500	ø22.2	Brazed *1	ø28.58	Brazed ø28.58
P550	ø22.2	Brazed *1	ø28.58	Brazed ø28.58
	ø28.58	Brazed *2	ø28.58	Brazed ø28.58

41 Connect the refrigerant pipe to the service valve according to the Installation Manual.

2 When the piping length is 65m or longer, use the ø28.58 pipe for the part that exceeds 65m.

No.	Usage	Specifications
①	For pipes	Front through hole 148 × 84 Knockout hole
②		Bottom through hole 150 × 94 Knockout hole
③		Front through hole ø65 or ø40 Knockout hole
④	For wires	Front through hole ø52 or ø27 Knockout hole
⑤		Bottom through hole ø65 Knockout hole
⑥		Bottom through hole ø52 Knockout hole
⑦	For transmission cables	Front through hole ø34 Knockout hole
⑧		Bottom through hole ø34 Knockout hole


PURY-P500, 550YNW-A2/TR2/RU2 (-BS)

Unit: mm


◆:When installing a panel heater<Optional parts>

1. Required space around the unit

◆In case of single installation



- When the height of the walls on the front, back or on the sides <H> exceeds the wall height limit as defined below and half of the height that exceeds the height limit <h/2> to the figures that are marked with an asterisk(*).



2. Foundation work

- Take into consideration the surface strength, water drainage route, piping route, and wiring route when preparing the installation site.
<Note that the drain water comes out of the unit during operation.>
- Build the foundation in such way that the corner of the installation leg is securely supported as shown in the right figure.(Fig.A,B)
When using a rubber isolating cushion, please ensure it is large enough to cover the entire width of each of the unit's legs.
- The protrusion length of the anchor bolt must not exceed 30mm.(Fig.A,B)
- Use six fixing plates as shown in the right figure <field supply required> when using M12 hole-in anchor bolts <field supply required> (Fig.C,D)
- To prevent small animals and water and snow from entering the unit and damaging its parts, close the gap around the edges of through holes for pipes and wires with filler plates <field supply required>.
- When the pipes or cables are routed at the bottom of the unit, make sure that the through hole at the base of the unit does not get blocked with the installation base.
- Refer to the Installation Manual when installing units on an installation base.

- When multiple units are installed adjacent to each other, secure enough space to allow for air circulation and walkway between groups of units as shown in the figures below.
- At least two sides must be left open.
- As with the single installation, add half of the height that exceeds the height limit <h/2> to the figures that are marked with an asterisk(*).
- If there is a wall at both the front and the rear of the unit, install up to three units consecutively in the side direction and provide a space of 1000mm or more as inlet space/ passage space for each three units.




Fig. C (without detachable legs)




Fig. D (with detachable legs)

◆Outline dwg at panel heater installation





Fig. A (without detachable legs)

Fig. B (with detachable legs)

2. EXTERNAL DIMENSIONS

Unit: mm

PURY-P400, 450, 500, 550, 600YSNW-A2/TR2/RU2 (-BS)



Twinning pipe connection size

Package unit name	Outdoor unit 1	PURY-P400YSNW-A2/TR2/RU2 (-BS)	PURY-P450YSNW-A2/TR2/RU2 (-BS)	PURY-P500YSNW-A2/TR2/RU2 (-BS)	PURY-P550YSNW-A2/TR2/RU2 (-BS)	PURY-P600YSNW-A2/TR2/RU2 (-BS)
Component unit name	Outdoor unit 2	PURY-P200YWNW-A2/TR2/RU2 (-BS)	PURY-P250YWNW-A2/TR2/RU2 (-BS)	PURY-P300YWNW-A2/TR2/RU2 (-BS)	PURY-P350YWNW-A2/TR2/RU2 (-BS)	PURY-P300YWNW-A2/TR2/RU2 (-BS)
Outdoor Twinning Kit(optional parts)		PURY-P200YWNW-A2/TR2/RU2 (-BS)	PURY-P200YWNW-A2/TR2/RU2 (-BS)	PURY-P250YWNW-A2/TR2/RU2 (-BS)	PURY-P250YWNW-A2/TR2/RU2 (-BS)	PURY-P300YWNW-A2/TR2/RU2 (-BS)
BC controller ~ Twinning pipe	High pressure a	CMY-R100VBK4	CMY-R100VBK4	CMY-R100VBK4	CMY-R100VBK4	CMY-R100VBK4
	Low pressure b	ø22.2	ø22.2	ø22.2	ø22.2(ø28.58)*	ø22.2(ø28.58)*
Twinning pipe ~Outdoor unit 1	High pressure c	ø15.88	ø19.05	ø19.05	ø19.05	ø19.05
	Low pressure d	ø19.05	ø22.2	ø22.2	ø22.2	ø22.2
Twinning pipe ~Outdoor unit 2	High pressure e	ø15.88	ø15.88	ø19.05	ø19.05	ø19.05
	Low pressure f	ø19.05	ø19.05	ø22.2	ø22.2	ø22.2

* When the piping length is 65m or longer, use the ø28.58 pipe for the part that exceeds 65m.

Note 1. Connect the pipes as shown in the figure above. Refer to the table above for the pipe size.

2. Twinning pipes must be installed horizontally using a level vessel.

2. Twinning pipes must be installed horizontally using a level vessel. Be sure to see the Installation Manual for details of Twinning pipe installation.

3. The pipe section before the Twinning pipe (section "a" and "b" in the figure) must have at least 500mm of straight section ("including the straight pipe that is supplied with the Twinning pipe).


4. Only use the Twinning pipe by Mitsubishi (optional parts).

5. The detachable leg can be removed at site.

PURY-P-Y(S)NW-A2/TR2/RU2

PURY-P650YSNW-A2/TR2/RU2 (-BS)

Unit: mm




Twinning pipe connection size

Package unit name	PURY-P650YSNW-A2/TR2/RU2 (-BS)
Outdoor unit 1	PURY-P350YSNW-A2/TR2/RU2 (-BS)
Outdoor unit 2	PURY-P300YSNW-A2/TR2/RU2 (-BS)
Outdoor Twinning Kit(optional parts)	CMY-R100VBK4
BC controller	
~Twinning pipe	
High pressure	a
Low pressure	b
Twinning pipe	
~Outdoor unit 1	
High pressure	c
Low pressure	d
Twinning pipe	
~Outdoor unit 2	
High pressure	e
Low pressure	f

- Note 1. Connect the pipes as shown in the figure above. Refer to the table above for the pipe size.
2. Twinning pipes must be installed horizontally using a level vessel.
- Be sure to see the Installation Manual for details of Twinning pipe installation.
3. The pipe section before the Twinning pipe (section "a" and "b" in the figure) must have at least 500mm of straight section (*including the straight pipe that is supplied with the Twinning pipe).
4. Only use the Twinning pipe by Mitsubishi (optional parts).
5. The detachable leg can be removed at site.

2. EXTERNAL DIMENSIONS

Unit: mm



Twinning pipe connection size

Package unit name	PUR-P700V-SNW-A2/TR2/RU2 (-BS)	PUR-P750V-SNW-A2/TR2/RU2 (-BS)	PUR-P800V-SNW-A2/TR2/RU2 (-BS)	PUR-P850V-SNW-A2/TR2/RU2 (-BS)	PUR-P900V-SNW-A2/TR2/RU2 (-BS)
Component unit name	Outdoor unit 1	PUR-P350V-SNW-A2/TR2/RU2 (-BS)	PUR-P400V-SNW-A2/TR2/RU2 (-BS)	PUR-P450V-SNW-A2/TR2/RU2 (-BS)	PUR-P450V-SNW-A2/TR2/RU2 (-BS)
	Outdoor unit 2	PUR-P350V-SNW-A2/TR2/RU2 (-BS)	PUR-P350V-SNW-A2/TR2/RU2 (-BS)	PUR-P400V-SNW-A2/TR2/RU2 (-BS)	PUR-P450V-SNW-A2/TR2/RU2 (-BS)
Outdoor Twinning Kit(optional parts)					
BC controller ~ Twinning pipe	High pressure a	ø28.58	ø28.58	ø28.58	ø28.58
	Low pressure b	ø34.93	ø34.93	ø34.93	ø41.28
Twinning pipe ~Outdoor unit 1	High pressure c	ø19.05	ø22.2	ø22.2	ø22.2
	Low pressure d	ø28.58	ø28.58	ø28.58	ø28.58
Twinning pipe ~Outdoor unit 2	High pressure e	ø19.05	ø19.05	ø22.2	ø22.2
	Low pressure f	ø28.58	ø28.58	ø28.58	ø28.58

Note 1. Connect the pipes as shown in the figure above. Refer to the table above for the pipe size.

2. Twinning pipes must be installed horizontally using a level vessel.


Be sure to see the Installation Manual for details of Twinning pipe installation.

3. The pipe section before the Twinning pipe (section "a" and "b" in the figure) must have at least 500mm of straight section (*including the straight pipe that is supplied with the Twinning pipe).

4. Only use the Twinning pipe by Mitsubishi (optional parts).

5. The detachable leg can be removed at site.

PURY-P-Y(S)NW-A2/TR2/RU2



Unit: mm


Twinning pipe connection size

Package unit name	PURY-P950YSNW-A2/TR2/RU2 (-BS)
Outdoor unit 1	PURY-P500YSNW-A2/TR2/RU2 (-BS)
Outdoor unit 2	PURY-P450YSNW-A2/TR2/RU2 (-BS)
Outdoor Twinning Kit(optional parts)	CMY-R200V/BK4
BC controller	
~Twinning pipe	
High pressure	a
Low pressure	b
Twinning pipe	
~Outdoor unit 1	
High pressure	c
Low pressure	d
Twinning pipe	
~Outdoor unit 2	
High pressure	e
Low pressure	f

- Note 1. Connect the pipes as shown in the figure above. Refer to the table above for the pipe size.
2. Twinning pipes must be installed horizontally using a level vessel.
Be sure to see the Installation Manual for details of Twinning pipe installation.
3. The pipe section before the Twinning pipe (section "a" and "b" in the figure) must have at least 500mm of straight section
(*including the straight pipe that is supplied with the Twinning pipe).
4. Only use the Twinning pipe by Mitsubishi (optional parts).
5. The detachable leg can be removed at site.

PURY-P1000, 1050, 1100YSNW-A2/TR2/RU2 (-BS)

Unit: mm



Twinning pipe connection size

Package unit name		PURY-P1000Y-SNW-A2/TR2/RU2 -(BS)	PURY-P1050Y-SNW-A2/TR2/RU2 -(BS)	PURY-P1100Y-SNW-A2/TR2/RU2 -(BS)
Component unit name	Outdoor unit 1	PURY-P500Y-NW-A2/TR2/RU2 -(BS)	PURY-P500Y-NW-A2/TR2/RU2 -(BS)	PURY-P550Y-NW-A2/TR2/RU2 -(BS)
	Outdoor unit 2	PURY-P500Y-NW-A2/TR2/RU2 -(BS)	PURY-P500Y-NW-A2/TR2/RU2 -(BS)	PURY-P550Y-NW-A2/TR2/RU2 -(BS)
Outdoor Twinning Kit(optional parts)		CMY-R200V/BK4		
BC controller ~Twinning pipe	High pressure a	ø28.58	ø34.93	ø34.93
	Low pressure b	ø41.28	ø41.28	ø41.28
	High pressure c	ø22.2	ø22.2	ø22.2
	Low pressure d	ø28.58	ø28.58	ø28.58
~Outdoor unit 1	High pressure e	ø22.2	ø22.2	ø22.2
	Low pressure f	ø28.58	ø28.58	ø28.58
~Outdoor unit 2	High pressure g	ø22.2	ø22.2	ø22.2
	Low pressure h	ø28.58	ø28.58	ø28.58

Note 1. Connect the pipes as shown in the figure above. Refer to the table above for the pipe size.

2. Twinning pipes must be installed horizontally using a level vessel.

z. Twinning pipes must be installed horizontally using a level vessel. Be sure to see the Installation Manual for details of Twinning pipe installation.

3. The pipe section before the Twinning pipe (section "a" and "b" in the figure) must have at least 500mm of straight section

3. The pipe section before the Twinning pipe (section a and b in the figure).


4. Only use the Twinning pipe by Mitsubishi (optional parts).

4. Only use the twinning pipe by Mitsubishi (of
5. The detachable leg can be removed at site.

PURRY-P-Y(S)NW-A2/TR2/RU2

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-P200, 250, 300YNW-A2/TR2/RU2 (-BS)



Unit: mm

Model	X	Y	Z
PURY-P200YNW-A2/TR2/RU2(-BS)	354	338	678
PURY-P250YNW-A2/TR2/RU2(-BS)	356	338	668
PURY-P300YNW-A2/TR2/RU2(-BS)	357	338	665


PURY-P350, 400, 450YNW-A2/TR2/RU2 (-BS)



Unit: mm

Model	X	Y	Z
PURY-P350YNW-A2/TR2/RU2(-BS)	502	344	714
PURY-P400YNW-A2/TR2/RU2(-BS)	502	344	714
PURY-P450YNW-A2/TR2/RU2(-BS)	501	345	741


PURY-P500, 550YNW-A2/TR2/RU2 (-BS)



Unit: mm

Model	X	Y	Z
PURY-P500YNW-A2/TR2/RU2(-BS)	871	305	720
PURY-P550YNW-A2/TR2/RU2(-BS)	871	305	720


PURRY-P-Y(S)NW-A2/TR2/RU2




PURY	LEV9
r11 Difference of appliance.	

Symbol	Symbol	4-way valve	Expansion
21S4a	21S4a	Pressure switch	Control Heating switching
21S4b	21S4b	Pressure switch	Heat exchanger capacity control (only PUMP mode)
63H1	63H1	Pressure switch	Control Heating switching
63H51	63H51	Pressure sensor	Pressure control (only for the outdoor unit)
63H5	63H5	Pressure sensor	Discharge pressure
AC01T.AC01Z	AC01T.AC01Z	Current sensor (AC)	Low pressure
CH00C01, CH03C01, CH05C01, CH07C01	CH00C01, CH03C01, CH05C01, CH07C01	Capacitor (vertical main circuit)	Pressure control (Refrigerant flow rate control)
DC motor	DC motor	Choke coil (for high frequency noise reduction)	Heat exchanger for inverter
LE1V1 *10	LE1V1 *10	Linear expansion valve	Pressure control (Refrigerant flow rate control)
LE1V2a,b	LE1V2a,b	Linear expansion valve	Pressure control (Refrigerant flow rate control)
LE1V2a *10	LE1V2a *10	Linear expansion valve	Pressure control (Refrigerant flow rate control)
LE1V2b *10	LE1V2b *10	Linear expansion valve	Pressure control (Refrigerant flow rate control)
RSR107.02/03	RSR107.02/03	Resistor	For inrush current prevention
SV1a	SV1a	Solenoid valve	For main circuit prevention
SV2	SV2	Solenoid valve	For opening/closing the bypass circuit under the OS
SV2 *10	SV2 *10	Solenoid valve	For opening/closing the discharge circuit under the OS
SV4 *10	SV4 *10	Solenoid valve	For opening/closing the bypass circuit
SV14.15.11	SV14.15.11	Solenoid valve	For opening/closing the bypass circuit
TB1	TB1	Terminal block	For changing (refrigerant flow) (cooling/heating)
TB3	TB3	Terminal block	Power supply
TB7	TB7	Terminal block	Indoor/Outdoor transmission line
TH2 *10	TH2 *10	Thermistor	Central control transmission line
TH3	TH3	Thermistor	Subcool bypass coil temperature
TH4	TH4	Thermistor	Subcool bypass coil temperature
TH5	TH5	Thermistor	Discharge pipe temperature
TH6 *10	TH6 *10	Thermistor	ACC Filter pipe temperature
TH7	TH7	Thermistor	Subcooled liquid refrigerant temperature
TH8	TH8	Thermistor	OA temperature
TH9	TH9	Thermistor	Compressor shell bottom temperature
TH15	TH15	Thermistor	Compressor shell bottom temperature
TH16	TH16	Thermistor	IPM temperature
TH17	TH17	Thermistor	IPM temperature
TH18	TH18	Thermistor	IPM temperature
TH19	TH19	Thermistor	IPM temperature
TH20	TH20	Thermistor	IPM temperature
TH21	TH21	Thermistor	IPM temperature
TH22	TH22	Thermistor	IPM temperature
TH23	TH23	Thermistor	IPM temperature
TH24	TH24	Thermistor	IPM temperature
TH25	TH25	Thermistor	IPM temperature
TH26	TH26	Thermistor	IPM temperature
TH27	TH27	Thermistor	IPM temperature
TH28	TH28	Thermistor	IPM temperature
TH29	TH29	Thermistor	IPM temperature
TH30	TH30	Thermistor	IPM temperature
TH31	TH31	Thermistor	IPM temperature
TH32	TH32	Thermistor	IPM temperature
TH33	TH33	Thermistor	IPM temperature
TH34	TH34	Thermistor	IPM temperature
TH35	TH35	Thermistor	IPM temperature
TH36	TH36	Thermistor	IPM temperature
TH37	TH37	Thermistor	IPM temperature
TH38	TH38	Thermistor	IPM temperature
TH39	TH39	Thermistor	IPM temperature
TH40	TH40	Thermistor	IPM temperature
TH41	TH41	Thermistor	IPM temperature
TH42	TH42	Thermistor	IPM temperature
TH43	TH43	Thermistor	IPM temperature
TH44	TH44	Thermistor	IPM temperature
TH45	TH45	Thermistor	IPM temperature
TH46	TH46	Thermistor	IPM temperature
TH47	TH47	Thermistor	IPM temperature
TH48	TH48	Thermistor	IPM temperature
TH49	TH49	Thermistor	IPM temperature
TH50	TH50	Thermistor	IPM temperature
TH51	TH51	Thermistor	IPM temperature
TH52	TH52	Thermistor	IPM temperature
TH53	TH53	Thermistor	IPM temperature
TH54	TH54	Thermistor	IPM temperature
TH55	TH55	Thermistor	IPM temperature
TH56	TH56	Thermistor	IPM temperature
TH57	TH57	Thermistor	IPM temperature
TH58	TH58	Thermistor	IPM temperature
TH59	TH59	Thermistor	IPM temperature
TH60	TH60	Thermistor	IPM temperature
TH61	TH61	Thermistor	IPM temperature
TH62	TH62	Thermistor	IPM temperature
TH63	TH63	Thermistor	IPM temperature
TH64	TH64	Thermistor	IPM temperature
TH65	TH65	Thermistor	IPM temperature
TH66	TH66	Thermistor	IPM temperature
TH67	TH67	Thermistor	IPM temperature
TH68	TH68	Thermistor	IPM temperature
TH69	TH69	Thermistor	IPM temperature
TH70	TH70	Thermistor	IPM temperature
TH71	TH71	Thermistor	IPM temperature
TH72	TH72	Thermistor	IPM temperature
TH73	TH73	Thermistor	IPM temperature
TH74	TH74	Thermistor	IPM temperature
TH75	TH75	Thermistor	IPM temperature
TH76	TH76	Thermistor	IPM temperature
TH77	TH77	Thermistor	IPM temperature
TH78	TH78	Thermistor	IPM temperature
TH79	TH79	Thermistor	IPM temperature
TH80	TH80	Thermistor	IPM temperature
TH81	TH81	Thermistor	IPM temperature
TH82	TH82	Thermistor	IPM temperature
TH83	TH83	Thermistor	IPM temperature
TH84	TH84	Thermistor	IPM temperature
TH85	TH85	Thermistor	IPM temperature
TH86	TH86		

PURY-P-Y(S)NW-A2/TR2/RU2



PURY-P500, 550YNW-A2/TR2/RU2 (-BS)





- *1. Single-dotted lines indicate wiring not supplied with the unit.
- *2. Dot-dash lines indicate the control box boundaries.
- *3. Refer to the Data book for connecting input/output signal connectors.
- *4. Daisy-chain terminals (TB3) on the outdoor units in the same refrigerant system together.
- *5. Faston terminals have a locking function. Make sure the terminals are securely locked in place after insertion. Press the tab on the terminals to removed them.
- *6. Control box houses high-voltage parts. Before inspecting the inside of the control box turn off the power, keep the unit off for at least 10 minutes, and confirm that the voltage of the connector RYPN has dropped to DC20V or less.
- *7. Control board LED display.

LED2	Normal operation/LED blink
LED3	Normal operation/LED blink
LED4	Normal operation/LED blink
LED5	Normal operation/LED blink
LED6	Normal operation/LED blink
LED7	Normal operation/LED blink
LED8	Normal operation/LED blink
LED9	Normal operation/LED blink
LED10	Normal operation/LED blink
LED11	Normal operation/LED blink
LED12	Normal operation/LED blink
LED13	Normal operation/LED blink
LED14	Normal operation/LED blink
LED15	Normal operation/LED blink
LED16	Normal operation/LED blink
LED17	Normal operation/LED blink
LED18	Normal operation/LED blink
LED19	Normal operation/LED blink
LED20	Normal operation/LED blink
LED21	Normal operation/LED blink
LED22	Normal operation/LED blink
LED23	Normal operation/LED blink
LED24	Normal operation/LED blink
LED25	Normal operation/LED blink
LED26	Normal operation/LED blink
LED27	Normal operation/LED blink
LED28	Normal operation/LED blink
LED29	Normal operation/LED blink
LED30	Normal operation/LED blink
LED31	Normal operation/LED blink
LED32	Normal operation/LED blink
LED33	Normal operation/LED blink
LED34	Normal operation/LED blink
LED35	Normal operation/LED blink
LED36	Normal operation/LED blink
LED37	Normal operation/LED blink
LED38	Normal operation/LED blink
LED39	Normal operation/LED blink
LED40	Normal operation/LED blink
LED41	Normal operation/LED blink
LED42	Normal operation/LED blink
LED43	Normal operation/LED blink
LED44	Normal operation/LED blink
LED45	Normal operation/LED blink
LED46	Normal operation/LED blink
LED47	Normal operation/LED blink
LED48	Normal operation/LED blink
LED49	Normal operation/LED blink
LED50	Normal operation/LED blink
LED51	Normal operation/LED blink
LED52	Normal operation/LED blink
LED53	Normal operation/LED blink
LED54	Normal operation/LED blink
LED55	Normal operation/LED blink
LED56	Normal operation/LED blink
LED57	Normal operation/LED blink
LED58	Normal operation/LED blink
LED59	Normal operation/LED blink
LED60	Normal operation/LED blink
LED61	Normal operation/LED blink
LED62	Normal operation/LED blink
LED63	Normal operation/LED blink
LED64	Normal operation/LED blink
LED65	Normal operation/LED blink
LED66	Normal operation/LED blink
LED67	Normal operation/LED blink
LED68	Normal operation/LED blink
LED69	Normal operation/LED blink
LED70	Normal operation/LED blink
LED71	Normal operation/LED blink
LED72	Normal operation/LED blink
LED73	Normal operation/LED blink
LED74	Normal operation/LED blink
LED75	Normal operation/LED blink
LED76	Normal operation/LED blink
LED77	Normal operation/LED blink
LED78	Normal operation/LED blink
LED79	Normal operation/LED blink
LED80	Normal operation/LED blink
LED81	Normal operation/LED blink
LED82	Normal operation/LED blink
LED83	Normal operation/LED blink
LED84	Normal operation/LED blink
LED85	Normal operation/LED blink
LED86	Normal operation/LED blink
LED87	Normal operation/LED blink
LED88	Normal operation/LED blink
LED89	Normal operation/LED blink
LED90	Normal operation/LED blink
LED91	Normal operation/LED blink
LED92	Normal operation/LED blink
LED93	Normal operation/LED blink
LED94	Normal operation/LED blink
LED95	Normal operation/LED blink
LED96	Normal operation/LED blink
LED97	Normal operation/LED blink
LED98	Normal operation/LED blink
LED99	Normal operation/LED blink
LED100	Normal operation/LED blink


Symbol	Explanation
4-way valve	Coasting/Heating capacity control (only PURY model)
63H1	Pressure switch
63H51	Pressure switch
63H52	Pressure switch
63H53	Pressure switch
63H54	Pressure switch
63H55	Pressure switch
63H56	Pressure switch
63H57	Pressure switch
63H58	Pressure switch
63H59	Pressure switch
63H60	Pressure switch
63H61	Pressure switch
63H62	Pressure switch
63H63	Pressure switch
63H64	Pressure switch
63H65	Pressure switch
63H66	Pressure switch
63H67	Pressure switch
63H68	Pressure switch
63H69	Pressure switch
63H70	Pressure switch
63H71	Pressure switch
63H72	Pressure switch
63H73	Pressure switch
63H74	Pressure switch
63H75	Pressure switch
63H76	Pressure switch
63H77	Pressure switch
63H78	Pressure switch
63H79	Pressure switch
63H80	Pressure switch
63H81	Pressure switch
63H82	Pressure switch
63H83	Pressure switch
63H84	Pressure switch
63H85	Pressure switch
63H86	Pressure switch
63H87	Pressure switch
63H88	Pressure switch
63H89	Pressure switch
63H90	Pressure switch
63H91	Pressure switch
63H92	Pressure switch
63H93	Pressure switch
63H94	Pressure switch
63H95	Pressure switch
63H96	Pressure switch
63H97	Pressure switch
63H98	Pressure switch
63H99	Pressure switch
63H100	Pressure switch
63H101	Pressure switch
63H102	Pressure switch
63H103	Pressure switch
63H104	Pressure switch
63H105	Pressure switch
63H106	Pressure switch
63H107	Pressure switch
63H108	Pressure switch
63H109	Pressure switch
63H110	Pressure switch
63H111	Pressure switch
63H112	Pressure switch
63H113	Pressure switch
63H114	Pressure switch
63H115	Pressure switch
63H116	Pressure switch
63H117	Pressure switch
63H118	Pressure switch
63H119	Pressure switch
63H120	Pressure switch
63H121	Pressure switch
63H122	Pressure switch
63H123	Pressure switch
63H124	Pressure switch
63H125	Pressure switch
63H126	Pressure switch
63H127	Pressure switch
63H128	Pressure switch
63H129	Pressure switch
63H130	Pressure switch
63H131	Pressure switch
63H132	Pressure switch
63H133	Pressure switch
63H134	Pressure switch
63H135	Pressure switch
63H136	Pressure switch
63H137	Pressure switch
63H138	Pressure switch
63H139	Pressure switch
63H140	Pressure switch
63H141	Pressure switch
63H142	Pressure switch
63H143	Pressure switch
63H144	Pressure switch
63H145	Pressure switch
63H146	Pressure switch
63H147	Pressure switch
63H148	Pressure switch
63H149	Pressure switch
63H150	Pressure switch
63H151	Pressure switch
63H152	Pressure switch
63H153	Pressure switch
63H154	Pressure switch
63H155	Pressure switch
63H156	Pressure switch
63H157	Pressure switch
63H158	Pressure switch
63H159	Pressure switch
63H160	Pressure switch
63H161	Pressure switch
63H162	Pressure switch
63H163	Pressure switch
63H164	Pressure switch
63H165	Pressure switch
63H166	Pressure switch
63H167	Pressure switch
63H168	Pressure switch
63H169	Pressure switch
63H170	Pressure switch
63H171	Pressure switch
63H172	Pressure switch
63H173	Pressure switch
63H174	Pressure switch
63H175	Pressure switch
63H176	Pressure switch
63H177	Pressure switch
63H178	Pressure switch
63H179	Pressure switch
63H180	Pressure switch
63H181	Pressure switch
63H182	Pressure switch
63H183	Pressure switch
63H184	Pressure switch
63H185	Pressure switch
63H186	Pressure switch
63H187	Pressure switch
63H188	Pressure switch
63H189	Pressure switch
63H190	Pressure switch
63H191	Pressure switch
63H192	Pressure switch
63H193	Pressure switch
63H194	Pressure switch
63H195	Pressure switch
63H196	Pressure switch
63H197	Pressure switch
63H198	Pressure switch
63H199	Pressure switch
63H200	Pressure switch

5-1. Sound levels in cooling mode

Measurement condition
PURY-P200, 250, 300YNW-A2/TR2/RU2(-BS)

Sound level of PURY-P300YNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	75.5	62.5	62.5	60.0	54.0	49.5	44.5	40.0	61.0
Low noise mode	50/60Hz	54.5	53.0	47.0	46.0	40.0	35.0	33.0	33.5	47.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P200YNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	77.0	61.0	60.5	57.5	51.0	46.5	44.0	41.5	59.0
Low noise mode	50/60Hz	51.0	49.5	43.0	39.5	37.5	29.0	33.0	39.0	44.0



When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P250YNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	78.0	62.5	61.5	59.0	52.0	48.5	48.5	43.0	60.5
Low noise mode	50/60Hz	53.0	51.5	41.5	42.0	35.0	31.5	38.0	38.5	45.0


When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

• Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.

Measurement condition
PURY-P350, 400, 450YNW-A2/TR2/RU2(-BS)

Sound level of PURY-P450YNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	73.5	64.0	66.5	64.5	59.5	55.0	49.5	45.5	65.5
Low noise mode	50/60Hz	64.5	57.0	52.0	49.5	47.5	44.0	39.5	43.5	53.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P350YNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	69.0	63.5	64.0	61.5	56.5	51.5	46.5	40.0	62.5
Low noise mode	50/60Hz	55.0	55.0	50.5	47.0	42.5	37.0	35.5	34.5	49.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


Sound level of PURY-P400YNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	73.5	63.5	66.0	64.0	59.0	54.5	48.5	45.0	65.0
Low noise mode	50/60Hz	64.0	57.0	51.0	48.0	46.5	42.5	38.0	43.5	52.0


When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

- Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.


Measurement condition
PURY-P500, 550YNW-A2/TR2/RU2(-BS)



Measurement condition
PURY-P400, 450, 500, 550, 600YSNW-A2/TR2/RU2(-BS)




Sound level of PURY-P500YNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	77.0	67.5	66.0	61.0	55.5	53.5	50.5	44.0	63.5
Low noise mode	50/60Hz	67.5	60.0	56.5	47.5	45.5	42.5	39.5	34.0	53.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


Sound level of PURY-P400YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	80.0	64.0	63.5	60.5	54.0	49.5	47.0	45.0	62.0
Low noise mode	50/60Hz	54.0	52.5	46.0	42.5	41.0	32.0	36.0	42.0	47.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


Sound level of PURY-P550YNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	79.5	70.5	71.5	69.0	62.5	60.0	54.5	54.0	70.0
Low noise mode	50/60Hz	67.0	60.5	58.0	51.5	48.0	44.5	41.5	35.0	55.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P450YSNW-A2/TR2/RU2(-BS)




		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	81.0	65.0	64.0	61.5	55.0	51.5	50.0	45.5	63.0
Low noise mode	50/60Hz	55.0	53.5	45.5	44.0	39.5	33.5	39.5	41.5	47.5

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


*Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.

Sound level of PURY-P500YSNW-A2/TR2/RU2(-BS)




		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	79.5	66.0	65.0	62.0	55.5	51.5	53.0	46.5	63.5
Low noise mode	50/60Hz	56.0	54.5	44.5	45.0	38.0	35.0	41.0	41.5	48.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Measurement condition
PURY-P650YSNW-A2/TR2/RU2(-BS)


Sound level of PURY-P550YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	79.0	65.5	65.0	62.5	56.0	52.0	51.0	45.0	64.0
Low noise mode	50/60Hz	56.5	55.5	48.5	47.5	41.0	36.5	39.5	39.5	49.5

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


Sound level of PURY-P650YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	77.0	66.0	66.5	64.0	58.5	54.0	48.5	43.5	65.0
Low noise mode	50/60Hz	58.0	57.0	52.0	49.5	44.5	39.0	37.5	37.0	51.5

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.



Sound level of PURY-P600YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	79.0	65.5	66.0	63.0	57.0	52.5	47.5	43.0	64.0
Low noise mode	50/60Hz	57.5	56.0	50.5	49.0	43.0	38.0	36.0	36.5	50.0


When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

• Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.

Measurement condition
PURY-P700, 750, 800, 850, 900YSNW-A2/TR2/RU2(-BS)

Sound level of PURY-P800YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	77.0	67.0	69.0	67.5	62.0	57.5	51.5	48.0	68.0
Low noise mode	50/60Hz	67.0	60.0	54.0	51.0	49.5	45.5	41.0	46.5	55.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P700YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	72.5	66.5	67.0	65.0	59.5	54.5	49.5	43.5	65.5
Low noise mode	50/60Hz	58.0	58.0	53.0	50.0	45.5	40.0	38.5	37.5	52.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P850YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	77.0	67.0	69.5	68.0	62.5	58.0	52.5	48.5	68.5
Low noise mode	50/60Hz	67.5	60.0	54.5	52.0	50.0	46.5	42.0	46.5	55.5

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P750YSNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	75.0	66.5	68.0	66.0	61.0	56.0	50.5	46.0	67.0
Low noise mode	50/60Hz	64.5	59.0	53.5	50.5	48.0	44.0	40.0	44.0	54.0




When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P900YSNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	77.0	67.5	69.5	68.0	62.5	58.0	53.0	49.0	68.5
Low noise mode	50/60Hz	67.5	60.0	55.0	52.5	50.5	47.0	42.5	46.5	56.0


When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

*Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.

Measurement condition
PURY-P950YSNW-A2/TR2/RU2(-BS)

Measurement condition
PURY-P1000, 1050, 1100YSNW-A2/TR2/RU2(-BS)

Sound level of PURY-P950YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	79.0	69.5	69.5	66.5	61.0	57.5	53.0	48.0	68.0
Low noise mode	50/60Hz	69.5	61.5	58.0	51.5	49.5	46.5	42.5	44.0	56.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P1000YSNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	80.0	70.5	69.0	64.5	58.5	57.0	53.5	47.5	66.5
Low noise mode	50/60Hz	70.5	63.0	59.5	50.5	48.5	45.5	42.5	36.5	56.0


When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P1050YSNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Cooling	50/60Hz	81.5	72.5	72.5	70.0	63.5	61.0	56.5	54.5	71.0
Low noise mode	50/60Hz	70.5	63.5	60.5	53.0	50.0	47.0	44.0	37.5	57.5


When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

• Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.




• Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.

5-2. Sound levels in heating mode

Measurement condition
PURY-P200, 250, 300YNW-A2/TR2/RU2(-BS)


Sound level of PURY-P300YNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	74.5	70.0	68.5	65.5	60.5	56.5	52.0	48.0	67.0
Low noise mode	50/60Hz	60.5	58.5	51.5	49.0	44.0	40.5	39.0	41.5	51.5

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


Sound level of PURY-P200YNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	69.0	61.0	60.5	58.0	52.0	47.5	48.0	42.5	59.0
Low noise mode	50/60Hz	43.0	49.0	42.0	40.0	36.0	33.5	37.0	35.5	44.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.



Sound level of PURY-P250YNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	77.0	64.5	65.0	62.5	57.0	52.0	53.0	46.0	64.0
Low noise mode	50/60Hz	47.5	51.5	46.0	44.5	40.5	37.0	41.0	37.5	48.0


When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

- Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.

Measurement condition
PURY-P350, 400, 450YNW-A2/TR2/RU2(-BS)

Sound level of PURY-P450YNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	83.5	71.0	70.5	69.0	63.0	60.5	56.0	50.5	70.0
Low noise mode	50/60Hz	60.5	59.0	56.0	49.0	44.5	44.0	40.0	35.5	53.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P350YNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	72.0	70.5	64.0	62.0	57.0	54.0	51.5	48.0	64.0
Low noise mode	50/60Hz	61.5	59.5	51.5	48.5	45.0	41.5	40.5	42.0	52.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


Sound level of PURY-P400YNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	81.0	69.5	69.5	68.0	62.0	59.0	54.0	48.5	69.0
Low noise mode	50/60Hz	60.0	58.5	55.0	48.0	43.5	43.5	39.0	34.5	52.0


When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

* Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.


Measurement condition
PURY-P500, 550YNW-A2/TR2/RU2(-BS)



Measurement condition
PURY-P400, 450, 500, 550, 600YSNW-A2/TR2/RU2(-BS)




Sound level of PURY-P500YNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	66.0	64.0	65.5	62.5	57.0	56.5	53.0	48.5	64.5
Low noise mode	50/60Hz	62.5	60.5	51.5	49.5	48.0	42.0	44.5	41.0	53.5

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


Sound level of PURY-P400YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	63.5	64.0	63.5	61.0	55.0	50.5	51.0	45.5	62.0
Low noise mode	50/60Hz	46.0	52.0	45.0	43.0	39.0	36.5	40.0	38.5	47.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


Sound level of PURY-P550YNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	77.5	68.0	71.0	69.0	63.0	60.5	56.0	54.0	70.0
Low noise mode	50/60Hz	63.0	62.0	54.0	52.0	49.5	43.5	45.0	41.5	55.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P450YSNW-A2/TR2/RU2(-BS)




		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	77.0	66.5	66.5	64.0	58.5	53.5	54.5	48.0	65.5
Low noise mode	50/60Hz	49.0	53.5	47.5	46.0	42.0	39.0	42.5	40.0	49.5

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


• Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.

Sound level of PURY-P500YSNW-A2/TR2/RU2(-BS)




		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	80.0	67.5	68.0	65.5	60.0	55.0	56.0	49.0	67.0
Low noise mode	50/60Hz	50.5	54.5	49.0	47.5	43.5	40.0	44.0	40.5	51.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Measurement condition
PURY-P650YSNW-A2/TR2/RU2(-BS)


Sound level of PURY-P550YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	79.0	71.5	70.5	67.5	62.5	58.0	55.5	50.5	69.0
Low noise mode	50/60Hz	61.0	59.5	53.0	51.0	46.0	42.5	43.0	43.0	53.5

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


Sound level of PURY-P650YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	76.5	73.5	70.0	67.5	62.5	58.5	55.0	51.5	69.0
Low noise mode	50/60Hz	64.5	62.0	55.0	52.0	48.0	44.0	43.0	45.0	55.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.



Sound level of PURY-P600YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	77.5	73.0	71.5	68.5	63.5	59.5	55.0	51.0	70.0
Low noise mode	50/60Hz	63.5	61.5	54.5	52.0	47.0	43.5	42.0	44.5	54.5


When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

* Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as corridors, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.

Measurement condition
PURY-P700, 750, 800, 850, 900YSNW-A2/TR2/RU2(-BS)

Sound level of PURY-P800YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	84.0	72.5	72.5	71.0	65.0	62.0	57.0	51.5	72.0
Low noise mode	50/60Hz	63.0	61.5	58.0	51.0	46.5	46.5	42.0	37.5	55.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P700YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	75.0	73.5	67.0	65.0	60.0	57.0	54.5	51.0	67.0
Low noise mode	50/60Hz	64.5	62.5	54.5	51.5	48.0	44.5	43.5	45.0	55.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P850YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	85.5	73.5	73.0	71.5	65.5	63.0	58.0	52.5	72.5
Low noise mode	50/60Hz	63.5	62.0	58.5	51.5	47.0	47.0	42.5	38.0	55.5

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P750YSNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	82.0	73.5	71.0	69.0	63.5	60.5	56.0	51.5	70.5
Low noise mode	50/60Hz	64.0	62.0	56.5	51.5	47.5	45.5	43.0	42.5	55.0




When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P900YSNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	86.5	74.0	73.5	72.0	66.0	63.5	59.0	53.5	73.0
Low noise mode	50/60Hz	63.5	62.0	59.0	52.0	47.5	47.0	43.0	38.5	56.0


When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

• Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.

Measurement condition
PURY-P950YSNW-A2/TR2/RU2(-BS)

Measurement condition
PURY-P1000, 1050, 1100YSNW-A2/TR2/RU2(-BS)

Sound level of PURY-P950YSNW-A2/TR2/RU2(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	84.0	72.0	72.0	70.0	64.0	62.0	58.0	53.0	71.5
Low noise mode	50/60Hz	65.0	63.0	57.5	52.5	50.0	46.5	46.0	42.5	56.5

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P1000YSNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	69.0	67.0	68.5	65.5	60.0	59.5	56.0	51.5	67.5
Low noise mode	50/60Hz	65.5	63.5	54.5	52.5	51.0	45.0	47.5	44.0	56.5


When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P1050YSNW-A2/TR2/RU2(-BS)


		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard Heating	50/60Hz	78.0	69.5	72.5	70.0	64.0	62.0	58.0	55.5	71.5
Low noise mode	50/60Hz	66.0	64.5	56.0	54.0	51.5	45.5	48.0	44.0	57.5

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

• Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.



• Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required. For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms. The sound pressure level measured by the conventional method in JIS for reference purpose.

[PURY-P200-550YNW, PURY-P400-1100YSNW]

Measurement condition

Measurement frequency: 1 Hz-80 Hz


Measurement point: Ground surface 20 cm away from the unit leg

Installation condition: Direct installation on the concrete floor

Power source: 3-phase 4-wire 380-400-415 V 50/60 Hz

Operation condition: JIS condition (cooling, heating)

Measurement device: Vibration level meter for vibration pollution VM-1220C (JIS-compliant product)




Vibration level


Model	Vibration level (dB)
PURY-P200YNW-A2/TR2/RU2 (-BS)	45
PURY-P250YNW-A2/TR2/RU2 (-BS)	46
PURY-P300YNW-A2/TR2/RU2 (-BS)	47
PURY-P350YNW-A2/TR2/RU2 (-BS)	47
PURY-P400YNW-A2/TR2/RU2 (-BS)	47
PURY-P450YNW-A2/TR2/RU2 (-BS)	47
PURY-P500YNW-A2/TR2/RU2 (-BS)	48
PURY-P550YNW-A2/TR2/RU2 (-BS)	48
PURY-P400YSNW-A2/TR2/RU2 (-BS)	48
PURY-P450YSNW-A2/TR2/RU2 (-BS)	48.5
PURY-P500YSNW-A2/TR2/RU2 (-BS)	49
PURY-P550YSNW-A2/TR2/RU2 (-BS)	49.5
PURY-P600YSNW-A2/TR2/RU2 (-BS)	50
PURY-P650YSNW-A2/TR2/RU2 (-BS)	50
PURY-P700YSNW-A2/TR2/RU2 (-BS)	50
PURY-P750YSNW-A2/TR2/RU2 (-BS)	50
PURY-P800YSNW-A2/TR2/RU2 (-BS)	50
PURY-P850YSNW-A2/TR2/RU2 (-BS)	50
PURY-P900YSNW-A2/TR2/RU2 (-BS)	50
PURY-P950YSNW-A2/TR2/RU2 (-BS)	50.5
PURY-P1000YSNW-A2/TR2/RU2 (-BS)	51
PURY-P1050YSNW-A2/TR2/RU2 (-BS)	51
PURY-P1100YSNW-A2/TR2/RU2 (-BS)	51

* Vibration level varies depending on the conditions of actual installation site.

• Cooling only



• Heating only



• Combination of cooling/heating operation (Cooling main or Heating main)

Outdoor temperature	Indoor temperature	
	Cooling	Heating
-10 to 21°CDB (14 to 70°FDB)	—	15 to 27°CDB (59 to 81°FDB)
-11 to 15.5°CWB (12 to 60°FWB)	15 to 24°CWB (59 to 75°FWB)	—

*1 When applying product below -20°CWB, consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

8-1. Selection of Cooling/Heating Units

How to determine the capacity when less than or equal 100% indoor model size units are connected in total:

The purpose of this flow chart is to select the indoor and outdoor units. For other purposes, this flow chart is intended only for reference.





Fig.1 Indoor unit temperature correction




Fig.2-1 Outdoor unit temperature correction (capacity)







Fig.2-2 Outdoor unit temperature correction (power input)

*1 When the indoor unit sizes from P/M100 to P/M140 or total capacity indoor units from P/M81 to P/M140 are connected to only 1 port on the BC controller in the R2 system, the cooling capacity of the outdoor unit should be multiplied by a correction factor of 0.97.

How to determine the capacity when greater than 100% indoor model size units are connected in total:

The purpose of this flow chart is to select the indoor and outdoor units. For other purposes, this flow chart is intended only for reference.



*1 When the indoor unit sizes from P/M100 to P/M140 or total capacity indoor units from P/M81 to P/M140 are connected to only 1 port on the BC controller in the R2 system, the cooling capacity of the outdoor unit should be multiplied by a correction factor of 0.97.

<Cooling>

Design Condition	
Outdoor Design Dry Bulb Temperature	37 °C
Total Cooling Load	19.0 kW
Room1	
Indoor Design Dry Bulb Temperature	27 °C
Indoor Design Wet Bulb Temperature	20 °C
Cooling Load	9.0 kW
Room2	
Indoor Design Dry Bulb Temperature	24 °C
Indoor Design Wet Bulb Temperature	18 °C
Cooling Load	10.0 kW
<Other>	
Indoor/Outdoor Equivalent Piping Length	50 m

1. Cooling Calculation

(1) Temporary Selection of Indoor Units

Room1
PLFY-P100

11.2 kW (Rated)

Room2
PLFY-P100

11.2 kW (Rated)

(2) Total Indoor Units Capacity

$$P100 + P100 = P200$$

(3) Selection of Outdoor Unit

The P200 outdoor unit is selected as total indoor units capacity is P200

PUHY-P200

22.4 kW

(4) Total Indoor Units Capacity Correction Calculation

Room1

Indoor Design Wet Bulb Temperature Correction (20°C) 1.03 (Refer to Fig.1)

Room2

Indoor Design Wet Bulb Temperature Correction (18°C) 0.98 (Refer to Fig.1)

Total Indoor Units Capacity (CTi)

$$\begin{aligned}
 CTi &= \Sigma (\text{Indoor Unit Rating} \times \text{Indoor Design Temperature Correction}) \\
 &= 11.2 \times 1.03 + 11.2 \times 0.98 \\
 &= 22.5 \text{ kW}
 \end{aligned}$$

(5) Outdoor Unit Correction Calculation

Outdoor Design Dry Bulb Temperature Correction (37°C) 0.99 (Refer to Fig.2)

Piping Length Correction (50 m) 0.95 (Refer to Fig.3)

Total Outdoor Unit Capacity (CTo)

$$\begin{aligned}
 CTo &= \text{Outdoor Rating} \times \text{Outdoor Design Temperature Correction} \times \text{Piping Length Correction} \\
 &= 22.4 \times 0.99 \times 0.95 \\
 &= 21.0 \text{ kW}
 \end{aligned}$$

(6) Determination of Maximum System Capacity (CTx)

Comparison of Capacity between Total Indoor Units Capacity (CTi) and Total Outdoor Unit Capacity (CTo)

$$CTi = 22.5 > CTo = 21.0, \text{ thus, select } CTo.$$

$$CTx = CTo = 21.0 \text{ kW}$$

(7) Comparison with Essential Load

Against the essential load 19.0kW, the maximum system capacity is 21.0kW: Proper outdoor units have been selected.

(8) Calculation of Maximum Indoor Unit Capacity of Each Room

$$CTx = CTo, \text{ thus, calculate by the calculation below}$$

Room1

$$\begin{aligned}
 &\text{Maximum Capacity} \times \text{Room1 Capacity after the Temperature Correction} / (\text{Room1,2 Total Capacity after the Temperature Correction}) \\
 &= 21.0 \times (11.2 \times 1.03) / (11.2 \times 1.03 + 11.2 \times 0.98) \\
 &= 10.8 \text{ kW} \quad \text{OK: fulfills the load 9.0kW}
 \end{aligned}$$

Room2

$$\begin{aligned}
 &\text{Maximum Capacity} \times \text{Room2 Capacity after the Temperature Correction} / (\text{Room1,2 Total Capacity after the Temperature Correction}) \\
 &= 21.0 \times (11.2 \times 0.98) / (11.2 \times 1.03 + 11.2 \times 0.98) \\
 &= 10.2 \text{ kW} \quad \text{OK: fulfills the load 10.0kW}
 \end{aligned}$$

Go on to the heating trial calculation since the selected units fulfill the cooling loads of Room 1, 2.




Fig.1 Indoor unit temperature correction
To be used to correct indoor unit only




Fig.2 Outdoor unit temperature correction
To be used to correct outdoor unit only




Fig.3 Correction of refrigerant piping length

<Heating>

Design Condition	
Outdoor Design Wet Bulb Temperature	-3 °C
Total Heating Load	18.5 kW
Room1	
Indoor Design Dry Bulb Temperature	25 °C
Heating Load	9.5 kW
Room2	
Indoor Design Dry Bulb Temperature	25 °C
Heating Load	9.0 kW
<Other>	
Indoor/Outdoor Equivalent Piping Length	50 m

2. Heating Calculation

(1) Temporary Selection of Indoor Units

Room1	PLFY-P100	12.5 kW (Rated)
Room2	PLFY-P100	12.5 kW (Rated)

(2) Total Indoor Units Capacity

$$P100 + P100 = P200$$

(3) Selection of Outdoor Unit

The P200 outdoor unit is selected as total indoor units capacity is P200

PUHY-P200	25.0 kW
-----------	---------

(4) Total Indoor Units Capacity Correction Calculation

Room1	
Indoor Design Dry Bulb Temperature Correction (25°C)	0.80 (Refer to Fig.4)
Room2	
Indoor Design Dry Bulb Temperature Correction (25°C)	0.80 (Refer to Fig.4)

Total Indoor Units Capacity (CTi)

$$\begin{aligned} CTi &= \Sigma (\text{Indoor Unit Rating} \times \text{Indoor Design Temperature Correction}) \\ &= 12.5 \times 0.80 + 12.5 \times 0.80 \\ &= 20.0 \text{ kW} \end{aligned}$$

(5) Outdoor Unit Correction Calculation

Outdoor Design Wet Bulb Temperature Correction (-3°C)	0.98 (Refer to Fig.5)
Piping Length Correction (50 m)	0.97 (Refer to Fig.6)
Defrost Correction	0.89 (Refer to Tbl.1)

Total Outdoor Unit Capacity (CTo)

$$\begin{aligned} CTo &= \text{Outdoor Unit Rating} \times \text{Outdoor Design Temperature Correction} \times \text{Piping Length} \\ &\quad \text{Correction} \times \text{Defrost Correction} \\ &= 25.0 \times 0.98 \times 0.97 \times 0.89 \\ &= 21.1 \text{ kW} \end{aligned}$$

(6) Determination of Maximum System Capacity (CTx)

Comparison of Capacity between Total Indoor Units Capacity (CTi) and Total Outdoor Unit Capacity (CTo)

$$CTi = 20.0 < CTo = 21.1, \text{ thus, select } CTi.$$

$$CTx = CTi = 20.0 \text{ kW}$$

(7) Comparison with Essential Load

Against the essential load 18.5kW, the maximum system capacity is 20.0kW: Proper outdoor units have been selected.

(8) Calculation of Maximum Indoor Unit Capacity of Each Room

CTx = CTi, thus, calculate by the calculation below

Room1	
Indoor Unit Rating × Indoor Design Temperature Correction	
= 12.5 × 0.80	
= 10.0 kW	OK: fulfills the load 9.5kW

Room2	
Indoor Unit Rating × Indoor Design Temperature Correction	
= 12.5 × 0.80	
= 10.0 kW	OK: fulfills the load 9.0kW

Completed selecting units since the selected units fulfill the heating loads of Room 1, 2.




Fig.4 Indoor unit temperature correction
To be used to correct indoor unit only




Fig.5 Outdoor unit temperature correction
To be used to correct outdoor unit only




Fig.6 Correction of refrigerant piping length

Tbl.1 Table of correction factor at frost and defrost

Outdoor inlet air temp. °CWB	6	4	2	1	0	-2	-4	-6	-8	-10	-20
Outdoor inlet air temp. °FWB	43	39	36	34	32	28	25	21	18	14	-4
PUHY-P200	1.00	0.95	0.84	0.825	0.83	0.87	0.90	0.95	0.95	0.95	0.95
PUHY-P250	1.00	0.95	0.84	0.825	0.83	0.87	0.90	0.95	0.95	0.95	0.95
PUHY-P300	1.00	0.93	0.82	0.80	0.82	0.86	0.90	0.90	0.95	0.95	0.95
PUHY-P350	1.00	0.93	0.85	0.83	0.84	0.86	0.90	0.90	0.95	0.95	0.95
PUHY-P400	1.00	0.93	0.85	0.83	0.84	0.86	0.90	0.90	0.95	0.95	0.95

PURY-P-Y(S)NW-A2/TR2/RU2

3. Power input of outdoor unit
<Cooling>

(1) Rated power input of outdoor unit	5.19 kW
(2) Calculation of the average indoor temperature power input coefficient	
Coefficient of the outdoor unit for indoor unit 1 (Outdoor temp. 37 °CD.B., Indoor temp. 20 °CW.B.)	1.07
Coefficient of the outdoor unit for indoor unit 2 (Outdoor temp. 37 °CD.B., Indoor temp. 18 °CW.B.)	1.00
Average indoor temp. power input coefficient $(C_{ave}) = \sum_{k=1}^n \{c_k \times (M_k / \sum_{k=1}^n M_k)\}$	
n: Total number of the indoor units	
k: Number of the indoor unit	
c _k : Outdoor unit power input coefficient of k indoor unit room temp.	
M _k : Number part of the k indoor unit model (e.g. P80 → 80)	
$= 1.07 \times 100 / (100 + 100) + 1 \times 100 / (100 + 100)$	
$= 1.04$	
(3) No need to consider Coefficient of the partial load f'(CTi/CTo)	-
(4) Outdoor power input (Plo)	
Maximum System Capacity (CTx) = Total Outdoor unit Capacity (CTo), so use the following formula	
Plo = Outdoor unit Cooling Rated Power Input × Correction Coefficient of Indoor temperature	
$= 5.19 \times 1.04$	
$= 5.4 \text{ kW}$	

<Heating>

(1) Rated power input of outdoor unit 5.73 kW

(2) Calculation of the average indoor temperature power input coefficient

Coefficient of the outdoor unit for indoor unit 1 (Outdoor temp. -3 °CW.B., Indoor temp. 25 °CD.B.)
1.08
Coefficient of the outdoor unit for indoor unit 2 (Outdoor temp. -3 °CW.B., Indoor temp. 25 °CD.B.)
1.08

Average indoor temp. power input coefficient $(C_{ave}) = \sum_{k=1}^n \{c_k \times (M_k / \sum_{k=1}^n M_k)\}$

n: Total number of the indoor units
k: Number of the indoor unit
c_k: Outdoor unit power input coefficient of k indoor unit room temp.
M_k: Number part of the k indoor unit model (e.g. P80 → 80)

= 1.08 × 100/(100 + 100) + 1.08 × 100/(100 + 100)
= 1.08

(3) Coefficient of the partial load $f'(CTi/CTo)$ 0.91

(4) Outdoor power input (P_{lo})

Maximum System Capacity (CT_x) = Total Indoor unit Capacity (CT_i), so use the following formula
P_{lo} = Outdoor unit Heating Rated Power Input × Correction Coefficient of Indoor temperature × $f'(CTi/CTo)$
= 5.73 × 1.08 × 0.91
= 5.65 kW

PURY-P-Y(S)NW-A2/TR2/RU2


8-2. Correction by temperature

CITY MULTI could have varied capacity at different designing temperature. Using the nominal cooling/heating capacity value and the ratio below, the capacity can be observed at various temperature.

PURY-		P200YNW-A2/TR2/RU2	P250YNW-A2/TR2/RU2
Cooling Capacity	kW	22.4	28.0
	BTU/h	76,400	95,500
Input	kW	6.68	10.25

Indoor unit temperature correction

To be used to correct indoor unit capacity only




Outdoor unit temperature correction

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.


Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.



PURY-		P200YNW-A2/TR2/RU2	P250YNW-A2/TR2/RU2
Heating Capacity	kW	25.0	31.5
	BTU/h	85,300	107,500
Input	kW	6.79	9.57

Indoor unit temperature correction


To be used to correct indoor unit capacity only

**Outdoor unit temperature correction**

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-		P300YNW-A2/TR2/RU2	P350YNW-A2/TR2/RU2
Cooling Capacity	kW	33.5	40.0
	BTU/h	114,300	136,500
Input	kW	11.75	14.92

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction


To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.



PURY-		P300YNW-A2/TR2/RU2	P350YNW-A2/TR2/RU2
Heating Capacity	kW	33.5	45.0
	BTU/h	114,300	153,500
Input	kW	9.62	13.88

Indoor unit temperature correction


To be used to correct indoor unit capacity only

**Outdoor unit temperature correction**

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-		P400YNW-A2/TR2/RU2	P450YNW-A2/TR2/RU2	P500YNW-A2/TR2/RU2
Cooling Capacity	kW	45.0	50.0	56.0
	BTU/h	153,500	170,600	191,100
Input	kW	19.65	19.84	22.22

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction


To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.



PURY-		P400YNW-A2/TR2/RU2	P450YNW-A2/TR2/RU2	P500YNW-A2/TR2/RU2
Heating Capacity	kW	50.0	56.0	63.0
	BTU/h	170,600	191,100	215,000
Input	kW	16.66	18.79	21.14

Indoor unit temperature correction


To be used to correct indoor unit capacity only

**Outdoor unit temperature correction**

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-	P550YNW-A2/TR2/RU2	
Cooling Capacity	kW	60.0
	BTU/h	204,700
Input	kW	25.86

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction
To be used to correct outdoor unit only


Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.



PURY-	P550YNW-A2/TR2/RU2
Heating Capacity	kW 69.0
Capacity	BTU/h 235,400
Input	kW 24.55


Indoor unit temperature correction

To be used to correct indoor unit capacity only



Outdoor unit temperature correction

To be used to correct outdoor unit only
 Outdoor unit capacity is NOT affected by the indoor temperature.
 Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.
 When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-		P400YSNW-A2/TR2/RU2	P450YSNW-A2/TR2/RU2	P500YSNW-A2/TR2/RU2
Cooling Capacity	kW	44.8	50.4	56.0
	BTU/h	152,900	172,000	191,100
Input	kW	13.78	17.08	21.13

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction


To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.



PURY-		P400YSNW-A2/TR2/RU2	P450YSNW-A2/TR2/RU2	P500YSNW-A2/TR2/RU2
Heating Capacity	kW	50.0	56.5	63.0
	BTU/h	170,600	192,800	215,000
Input	kW	14.00	16.71	19.74

Indoor unit temperature correction


To be used to correct indoor unit capacity only

**Outdoor unit temperature correction**

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.



Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.


When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2

PURY-		P550YSNW-A2/TR2/RU2	P600YSNW-A2/TR2/RU2	P650YSNW-A2/TR2/RU2
Cooling Capacity	kW	61.5	67.0	73.5
	BTU/h	209,800	228,600	250,800
Input	kW	22.69	24.27	27.42


PURY-		P700YSNW-A2/TR2/RU2
Cooling Capacity	kW	80.0
	BTU/h	273,000
Input	kW	30.76

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction

To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




PURY-		P550YSNW-A2/TR2/RU2	P600YSNW-A2/TR2/RU2	P650YSNW-A2/TR2/RU2
Heating Capacity	kW	65.0	67.0	78.5
	BTU/h	221,800	228,600	267,800
Input	kW	19.81	19.81	24.07

PURY-		P700YSNW-A2/TR2/RU2
Heating Capacity	kW	90.0
	BTU/h	307,100
Input	kW	28.66

Indoor unit temperature correction

To be used to correct indoor unit capacity only




Outdoor unit temperature correction

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-		P750YSNW-A2/TR2/RU2
Cooling Capacity	kW	85.0
	BTU/h	290,000
Input	kW	35.26

Indoor unit temperature correction
To be used to correct indoor unit capacity only




Outdoor unit temperature correction

To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




PURY-	P750YSNW-A2/TR2/RU2
Heating Capacity	kW 95.0
Input	BTU/h 324,100
	kW 31.35

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction
To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.
When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2

PURY-		P800YSNW-A2/TR2/RU2	P850YSNW-A2/TR2/RU2	P900YSNW-A2/TR2/RU2
Cooling Capacity	kW	90.0	95.0	100.0
	BTU/h	307,100	324,100	341,200
Input	kW	40.54	40.77	40.98


PURY-		P950YSNW-A2/TR2/RU2	P1000YSNW-A2/TR2/RU2
Cooling Capacity	kW	106.0	112.0
	BTU/h	361,700	382,100
Input	kW	43.44	45.90

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction

To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




PURY-		P800YSNW-A2/TR2/RU2	P850YSNW-A2/TR2/RU2	P900YSNW-A2/TR2/RU2
Heating Capacity	kW	100.0	106.0	112.0
	BTU/h	341,200	361,700	382,100
Input	kW	34.36	36.55	38.75

PURY-		P950YSNW-A2/TR2/RU2	P1000YSNW-A2/TR2/RU2
Heating Capacity	kW	119.0	126.0
	BTU/h	406,000	429,900
Input	kW	41.17	43.59

Indoor unit temperature correction


To be used to correct indoor unit capacity only

**Outdoor unit temperature correction**

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-		P1050YSNW-A2/TR2/RU2	P1100YSNW-A2/TR2/RU2
Cooling Capacity	kW	116.0	120.0
	BTU/h	395,800	409,400
Input	kW	49.36	53.32

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction
To be used to correct outdoor unit only


Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.



PURY-		P1050YSNW-A2/TR2/RU2	P1100YSNW-A2/TR2/RU2
Heating Capacity	kW	132.0	138.0
	BTU/h	450,400	470,900
Input	kW	46.97	50.54

Indoor unit temperature correction


To be used to correct indoor unit capacity only

**Outdoor unit temperature correction**

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.



Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


Correction by temperature (COP Priority Mode only for heating)

CITY MULTI could have various capacities at different designing temperatures. Using the nominal cooling/heating capacity values and the ratios below, the capacity can be found for various temperatures. To select COP priority mode, SW4 (935) must be set to ON.

PURY-		P200YNW-A2/TR2/RU2	P250YNW-A2/TR2/RU2
Cooling Capacity	kW	22.4	28.0
	BTU/h	76,400	95,500
Input	kW	6.68	10.25


Indoor unit temperature correction

To be used to correct indoor unit capacity only



Outdoor unit temperature correction

To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




COP Priority Mode

PURY-	P200YNW-A2/TR2/RU2	P250YNW-A2/TR2/RU2
Heating Capacity	kW 25.0	31.5
	BTU/h 85,300	107,500
Input	kW 6.79	9.57

Indoor unit temperature correction

To be used to correct indoor unit capacity only




Outdoor unit temperature correction

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-		P300YNW-A2/TR2/RU2	P350YNW-A2/TR2/RU2
Cooling Capacity	kW	33.5	40.0
	BTU/h	114,300	136,500
Input	kW	11.75	14.92

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction

To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




COP Priority Mode

		P300YNW-A2/TR2/RU2	P350YNW-A2/TR2/RU2
Heating Capacity	kW	33.5	45.0
	BTU/h	114,300	153,500
Input	kW	9.62	13.88

Indoor unit temperature correction

To be used to correct indoor unit capacity only




Outdoor unit temperature correction

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-		P400YNW-A2/TR2/RU2	P450YNW-A2/TR2/RU2	P500YNW-A2/TR2/RU2
Cooling Capacity	kW	45.0	50.0	56.0
	BTU/h	153,500	170,600	191,100
Input	kW	19.65	19.84	22.22

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction

To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




COP Priority Mode

PURY-	P400YNW-A2/TR2/RU2	P450YNW-A2/TR2/RU2	P500YNW-A2/TR2/RU2
Heating Capacity	50.0	56.0	63.0
BTU/h	170,600	191,100	215,000
Input	16.66	18.79	21.14
kW			

Indoor unit temperature correction

To be used to correct indoor unit capacity only




Outdoor unit temperature correction

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-	P550YNW-A2/TR2/RU2	
Cooling Capacity	kW	60.0
	BTU/h	204,700
Input	kW	25.86

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction
To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




COP Priority Mode

PURY-		P550YNW-A2/TR2/RU2
Heating Capacity	kW	69.0
	BTU/h	235,400
Input	kW	24.55

Indoor unit temperature correction

To be used to correct indoor unit capacity only




Outdoor unit temperature correction

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-		P400YSNW-A2/TR2/RU2	P450YSNW-A2/TR2/RU2	P500YSNW-A2/TR2/RU2
Cooling Capacity	kW	44.8	50.4	56.0
	BTU/h	152,900	172,000	191,100
Input	kW	13.78	17.08	21.13

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction

To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




COP Priority Mode

PURY-	P400YSNW-A2/TR2/RU2	P450YSNW-A2/TR2/RU2	P500YSNW-A2/TR2/RU2
Heating Capacity	kW 50.0	56.5	63.0
	BTU/h 170,600	192,800	215,000
Input	kW 14.00	16.71	19.74

Indoor unit temperature correction

To be used to correct indoor unit capacity only




Outdoor unit temperature correction

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.



Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.


When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2

PURY-		P550YSNW-A2/TR2/RU2	P600YSNW-A2/TR2/RU2	P650YSNW-A2/TR2/RU2
Cooling Capacity	kW	61.5	67.0	73.5
	BTU/h	209,800	228,600	250,800
Input	kW	22.69	24.27	27.42


PURY-		P700YSNW-A2/TR2/RU2
Cooling Capacity	kW	80.0
	BTU/h	273,000
Input	kW	30.76

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction

To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




COP Priority Mode

PURY-		P550YSNW-A2/TR2/RU2	P600YSNW-A2/TR2/RU2	P650YSNW-A2/TR2/RU2
Heating Capacity	kW	65.0	67.0	78.5
	BTU/h	221,800	228,600	267,800
Input	kW	19.81	19.81	24.07

PURY-		P700YSNW-A2/TR2/RU2
Heating Capacity	kW	90.0
	BTU/h	307,100
Input	kW	28.66

Indoor unit temperature correction

To be used to correct indoor unit capacity only




Outdoor unit temperature correction

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-	P750YSNW-A2/TR2/RU2	
Cooling Capacity	kW	85.0
	BTU/h	290,000
Input	kW	35.26

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction

To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




COP Priority Mode

PURY-			P750YSNW-A2/TR2/RU2
Heating	kW	95.0	
Capacity	BTU/h	324,100	
Input	kW	31.35	

Indoor unit temperature correction

To be used to correct indoor unit capacity only




Outdoor unit temperature correction

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.



Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.


When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2

PURY-		P800YSNW-A2/TR2/RU2	P850YSNW-A2/TR2/RU2	P900YSNW-A2/TR2/RU2
Cooling	kW	90.0	95.0	100.0
Capacity	BTU/h	307,100	324,100	341,200
Input	kW	40.54	40.77	40.98


PURY-		P950YSNW-A2/TR2/RU2	P1000YSNW-A2/TR2/RU2
Cooling	kW	106.0	112.0
Capacity	BTU/h	361,700	382,100
Input	kW	43.44	45.90

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction

To be used to correct outdoor unit only
Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




COP Priority Mode

PURY-		P800YSNW-A2/TR2/RU2	P850YSNW-A2/TR2/RU2	P900YSNW-A2/TR2/RU2
Heating Capacity	kW	100.0	106.0	112.0
	BTU/h	341,200	361,700	382,100
Input	kW	34.36	36.55	38.75

PURY-		P950YSNW-A2/TR2/RU2	P1000YSNW-A2/TR2/RU2
Heating Capacity	kW	119.0	126.0
	BTU/h	406,000	429,900
Input	kW	41.17	43.59

Indoor unit temperature correction

To be used to correct indoor unit capacity only




Outdoor unit temperature correction

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.

PURY-P-Y(S)NW-A2/TR2/RU2


PURY-		P1050YSNW-A2/TR2/RU2	P1100YSNW-A2/TR2/RU2
Cooling Capacity	kW	116.0	120.0
	BTU/h	395,800	409,400
Input	kW	49.36	53.32

Indoor unit temperature correction
To be used to correct indoor unit capacity only



Outdoor unit temperature correction
To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.
Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.




COP Priority Mode

PURY-	P1050YSNW-A2/TR2/RU2	P1100YSNW-A2/TR2/RU2
Heating Capacity	kW 132.0	138.0
	BTU/h 450,400	470,900
Input	kW 46.97	50.54

Indoor unit temperature correction

To be used to correct indoor unit capacity only




Outdoor unit temperature correction

To be used to correct outdoor unit only

Outdoor unit capacity is NOT affected by the indoor temperature.

Outdoor unit power input is affected by the indoor and outdoor temperatures. Please consult the sales office for details.



Values in the heating temperature correction diagram in the range below -20°C (-4°F) are reference values and not guaranteed values. Do not use these reference values for selecting outdoor unit models.

When applying product below -20°C (-4°F), consult your design engineer for cold climate application best practices, including the use of a backup source for heating.


PURY-P-Y(S)NW-A2/TR2/RU2

8-3. Correction by total indoor

CITY MULTI system has different capacities and inputs when many combinations of indoor units with different total capacities are connected. Using following tables, the maximum capacity can be found to ensure the system is installed with enough capacity for a particular application.


PURY-P200YNW-A2/TR2/RU2		
Cooling Capacity	kW	22.4
	BTU/h	76,400
Input	kW	6.68

PURY-P200YNW-A2/TR2/RU2		
Heating Capacity	kW	25.0
	BTU/h	85,300
Input	kW	6.79



PURY-P250YNW-A2/TR2/RU2		
Cooling Capacity	kW	28.0
	BTU/h	95,500
Input	kW	10.25


PURY-P250YNW-A2/TR2/RU2		
Heating Capacity	kW	31.5
	BTU/h	107,500
Input	kW	9.57



PURY-P300YNW-A2/TR2/RU2		
Cooling Capacity	kW	33.5
	BTU/h	114,300
Input	kW	11.75

PURY-P300YNW-A2/TR2/RU2		
Heating Capacity	kW	33.5
	BTU/h	114,300
Input	kW	9.62


PURY-P300YNW-A2/TR2/RU2



PURY-P350YNW-A2/TR2/RU2		
Cooling Capacity	kW	40.0
	BTU/h	136,500
Input	kW	14.92

PURY-P350YNW-A2/TR2/RU2		
Heating Capacity	kW	45.0
	BTU/h	153,500
Input	kW	13.88


PURY-P350YNW-A2/TR2/RU2



PURY-P-Y(S)NW-A2/TR2/RU2


PURY-P400YNW-A2/TR2/RU2		
Cooling Capacity	kW	45.0
	BTU/h	153,500
Input	kW	19.65

PURY-P400YNW-A2/TR2/RU2		
Heating Capacity	kW	50.0
	BTU/h	170,600
Input	kW	16.66



PURY-P450YNW-A2/TR2/RU2		
Cooling Capacity	kW	50.0
	BTU/h	170,600
Input	kW	19.84


PURY-P450YNW-A2/TR2/RU2		
Heating Capacity	kW	56.0
	BTU/h	191,100
Input	kW	18.79



PURY-P500YNW-A2/TR2/RU2		
Cooling Capacity	kW	56.0
	BTU/h	191,100
Input	kW	22.22

PURY-P500YNW-A2/TR2/RU2		
Heating Capacity	kW	63.0
	BTU/h	215,000
Input	kW	21.14


PURY-P500YNW-A2/TR2/RU2



PURY-P550YNW-A2/TR2/RU2		
Cooling Capacity	kW	60.0
	BTU/h	204,700
Input	kW	25.86

PURY-P550YNW-A2/TR2/RU2		
Heating Capacity	kW	69.0
	BTU/h	235,400
Input	kW	24.55


PURY-P550YNW-A2/TR2/RU2



PURY-P-Y(S)NW-A2/TR2/RU2


PURY-P400YSNW-A2/TR2/RU2		
Cooling Capacity	kW	44.8
	BTU/h	152,900
Input	kW	13.78

PURY-P400YSNW-A2/TR2/RU2		
Heating Capacity	kW	50.0
	BTU/h	170,600
Input	kW	14.00



PURY-P450YSNW-A2/TR2/RU2		
Cooling Capacity	kW	50.4
	BTU/h	172,000
Input	kW	17.08


PURY-P450YSNW-A2/TR2/RU2		
Heating Capacity	kW	56.5
	BTU/h	192,800
Input	kW	16.71



PURY-P500YSNW-A2/TR2/RU2		
Cooling Capacity	kW	56.0
	BTU/h	191,100
Input	kW	21.13

PURY-P500YSNW-A2/TR2/RU2		
Heating Capacity	kW	63.0
	BTU/h	215,000
Input	kW	19.74


PURY-P500YSNW-A2/TR2/RU2



PURY-P550YSNW-A2/TR2/RU2		
Cooling Capacity	kW	61.5
	BTU/h	209,800
Input	kW	22.69

PURY-P550YSNW-A2/TR2/RU2		
Heating Capacity	kW	65.0
	BTU/h	221,800
Input	kW	19.81


PURY-P550YSNW-A2/TR2/RU2



PURY-P-Y(S)NW-A2/TR2/RU2


PURY-P600YSNW-A2/TR2/RU2		
Cooling Capacity	kW	67.0
	BTU/h	228,600
Input	kW	24.27

PURY-P600YSNW-A2/TR2/RU2		
Heating Capacity	kW	67.0
	BTU/h	228,600
Input	kW	19.81



PURY-P650YSNW-A2/TR2/RU2		
Cooling Capacity	kW	73.5
	BTU/h	250,800
Input	kW	27.42


PURY-P650YSNW-A2/TR2/RU2		
Heating Capacity	kW	78.5
	BTU/h	267,800
Input	kW	24.07



PURY-P700YSNW-A2/TR2/RU2		
Cooling Capacity	kW	80.0
	BTU/h	273,000
Input	kW	30.76

PURY-P700YSNW-A2/TR2/RU2		
Heating Capacity	kW	90.0
	BTU/h	307,100
Input	kW	28.66


PURY-P700YSNW-A2/TR2/RU2



PURY-P750YSNW-A2/TR2/RU2		
Cooling Capacity	kW	85.0
	BTU/h	290,000
Input	kW	35.26

PURY-P750YSNW-A2/TR2/RU2		
Heating Capacity	kW	95.0
	BTU/h	324,100
Input	kW	31.35


PURY-P750YSNW-A2/TR2/RU2



PURY-P-Y(S)NW-A2/TR2/RU2


PURY-P800YSNW-A2/TR2/RU2		
Cooling Capacity	kW	90.0
	BTU/h	307,100
Input	kW	40.54

PURY-P800YSNW-A2/TR2/RU2		
Heating Capacity	kW	100.0
	BTU/h	341,200
Input	kW	34.36



PURY-P850YSNW-A2/TR2/RU2		
Cooling Capacity	kW	95.0
	BTU/h	324,100
Input	kW	40.77


PURY-P850YSNW-A2/TR2/RU2		
Heating Capacity	kW	106.0
	BTU/h	361,700
Input	kW	36.55



PURY-P900YSNW-A2/TR2/RU2		
Cooling Capacity	kW	100.0
	BTU/h	341,200
Input	kW	40.98

PURY-P900YSNW-A2/TR2/RU2		
Heating Capacity	kW	112.0
	BTU/h	382,100
Input	kW	38.75


PURY-P900YSNW-A2/TR2/RU2



PURY-P950YSNW-A2/TR2/RU2		
Cooling Capacity	kW	106.0
	BTU/h	361,700
Input	kW	43.44

PURY-P950YSNW-A2/TR2/RU2		
Heating Capacity	kW	119.0
	BTU/h	406,000
Input	kW	41.17


PURY-P950YSNW-A2/TR2/RU2



PURY-P-Y(S)NW-A2/TR2/RU2


PURY-P1000YSNW-A2/TR2/RU2		
Cooling Capacity	kW	112.0
	BTU/h	382,100
Input	kW	45.90

PURY-P1000YSNW-A2/TR2/RU2		
Heating Capacity	kW	126.0
	BTU/h	429,900
Input	kW	43.59




PURY-P1050YSNW-A2/TR2/RU2		
Cooling Capacity	kW	116.0
	BTU/h	395,800
Input	kW	49.36

PURY-P1050YSNW-A2/TR2/RU2		
Heating Capacity	kW	132.0
	BTU/h	450,400
Input	kW	46.97



PURY-P1100YSNW-A2/TR2/RU2		
Cooling Capacity	kW	120.0
	BTU/h	409,400
Input	kW	53.32


PURY-P1100YSNW-A2/TR2/RU2		
Heating Capacity	kW	138.0
	BTU/h	470,900
Input	kW	50.54











8-4. Correction by refrigerant piping length




CITY MULTI system can extend the piping flexibly within its limitation for the actual situation. However, a decrease of cooling/heating capacity could happen correspondently. Using following correction factor according to the equivalent length of the piping shown at 8-4-1 and 8-4-2, the capacity can be observed. 8-4-3 shows how to obtain the equivalent length of piping.

8-4-1. Cooling capacity correction




PURY-P600YSNW-A2/TR2/RU2 (-BS)**PURY-P800YSNW-A2/TR2/RU2 (-BS)****PURY-P650YSNW-A2/TR2/RU2 (-BS)****PURY-P850YSNW-A2/TR2/RU2 (-BS)****PURY-P700YSNW-A2/TR2/RU2 (-BS)****PURY-P900YSNW-A2/TR2/RU2 (-BS)****PURY-P750YSNW-A2/TR2/RU2 (-BS)****PURY-P950YSNW-A2/TR2/RU2 (-BS)**

PURY-P-Y(S)NW-A2/TR2/RU2



8-4-2. Heating capacity correction



8-4-3. How to obtain the equivalent piping length

1. PURY-P200YNW-A2/TR2/RU2 (-BS)

Equivalent length = (Actual piping length to the farthest indoor unit) + (0.35 × number of bends in the piping) m

2. PURY-P250, 300YNW-A2/TR2/RU2 (-BS)

Equivalent length = (Actual piping length to the farthest indoor unit) + (0.42 × number of bends in the piping) m

3. PURY-P350YNW-A2/TR2/RU2 (-BS)

Equivalent length = (Actual piping length to the farthest indoor unit) + (0.47 × number of bends in the piping) m

4. PURY-P400, 450, 500, 550, 600, 650Y(S)NW-A2/TR2/RU2 (-BS)

Equivalent length = (Actual piping length to the farthest indoor unit) + (0.50 × number of bends in the piping) m

5. PURY-P700, 750, 800YSNW-A2/TR2/RU2 (-BS)

Equivalent length = (Actual piping length to the farthest indoor unit) + (0.70 × number of bends in the piping) m

6. PURY-P850, 900, 950, 1000, 1050, 1100YSNW-A2/TR2/RU2 (-BS)

Equivalent length = (Actual piping length to the farthest indoor unit) + (0.80 × number of bends in the piping) m

8-5. Correction by port counts of the BC controller

Indoor unit sizes P200 and P250 must be connected to 2 ports on the BC controller.

Indoor unit sizes from P/M100 to P/M140 should normally be connected to 2 ports on the BC controller (set BC controller DIP-SW 4-6 to its ON position).

In cases whereby indoor unit sizes from P/M100 to P/M140 or total capacity indoor units from P/M81 to P/M140 are connected to only 1 port on the BC controller (set BC controller DIP-SW 4-6 to its OFF position), the cooling capacity of the outdoor unit should be multiplied by a correction factor of **0.97**.

8-6. Correction at frost and defrost

Due to frost at the outdoor heat exchanger and the automatic defrost operation, the heating capacity of the outdoor unit can be calculated by multiplying the correction factor shown in the table below.

Table of correction factor at frosting and defrosting

Outdoor inlet air temp. °CWB	6	4	2	1	0	-2	-4	-6	-8	-10	-20
Outdoor inlet air temp. °FWB	43	39	36	34	32	28	25	21	18	14	-4
PURY-P200YNW-A2/TR2/RU2 (-BS)	1.00	0.95	0.84	0.83	0.83	0.87	0.90	0.95	0.95	0.95	0.95
PURY-P250YNW-A2/TR2/RU2 (-BS)	1.00	0.95	0.84	0.83	0.83	0.87	0.90	0.95	0.95	0.95	0.95
PURY-P300YNW-A2/TR2/RU2 (-BS)	1.00	0.93	0.82	0.80	0.82	0.86	0.90	0.90	0.95	0.95	0.95
PURY-P350YNW-A2/TR2/RU2 (-BS)	1.00	0.93	0.85	0.83	0.84	0.86	0.90	0.90	0.95	0.95	0.95
PURY-P400Y(S)NW-A2/TR2/RU2 (-BS)	1.00	0.95	0.90	0.87	0.88	0.89	0.90	0.95	0.95	0.95	0.95
PURY-P450Y(S)NW-A2/TR2/RU2 (-BS)	1.00	0.98	0.89	0.87	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P500Y(S)NW-A2/TR2/RU2 (-BS)	1.00	0.98	0.89	0.86	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P550Y(S)NW-A2/TR2/RU2 (-BS)	1.00	0.94	0.87	0.86	0.87	0.88	0.90	0.90	0.93	0.93	0.93
PURY-P600YSNW-A2/TR2/RU2 (-BS)	1.00	0.94	0.84	0.86	0.87	0.88	0.90	0.90	0.93	0.93	0.93
PURY-P650YSNW-A2/TR2/RU2 (-BS)	1.00	0.94	0.84	0.86	0.87	0.88	0.90	0.90	0.93	0.93	0.93
PURY-P700YSNW-A2/TR2/RU2 (-BS)	1.00	0.98	0.89	0.88	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P750YSNW-A2/TR2/RU2 (-BS)	1.00	0.98	0.89	0.88	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P800YSNW-A2/TR2/RU2 (-BS)	1.00	0.98	0.89	0.88	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P850YSNW-A2/TR2/RU2 (-BS)	1.00	0.98	0.89	0.88	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P900YSNW-A2/TR2/RU2 (-BS)	1.00	0.98	0.89	0.88	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P950YSNW-A2/TR2/RU2 (-BS)	1.00	0.98	0.89	0.87	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P1000YSNW-A2/TR2/RU2 (-BS)	1.00	0.98	0.89	0.86	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P1050YSNW-A2/TR2/RU2 (-BS)	1.00	0.96	0.88	0.86	0.88	0.89	0.91	0.93	0.94	0.94	0.94
PURY-P1100YSNW-A2/TR2/RU2 (-BS)	1.00	0.94	0.87	0.86	0.87	0.88	0.90	0.90	0.93	0.93	0.93

Note

- The high humidity condition (e.g., a foggy atmosphere) which causes frost forming on the heat exchanger will worsen the heating performance of the unit.
- The snow blowing to the heat exchanger will worsen the heating performance of the unit. Install a snow hood as a preventive measure.

8-7. Correction at evaporation-temperature (ET) control

When the target evaporation temperature is changed, the capacity or the power input can be calculated by multiplying the correction factor shown in the table below.

ET *1	°C	6	9	14
Correction factor	Capacity	0.90	0.83	0.55
	Power Input	0.90	0.72	0.36

*1 The evaporation temperature in operation may be different from the preset target evaporation temperature because it depends on such factors as the unit protection control.

The capacity and power input could also fluctuate.


*2 Use the table above which indicates the unit properties as a reference

9-1. JOINT and REDUCER

CITY MULTI units can be easily connected by using Joint sets and Reducer sets provided by Mitsubishi Electric. Refer to section "Piping Design" or the Installation Manual that comes with the Joint set or Reducer set for how to install the Joint set or Reducer set.


CMY-Y102SS-G2

For Gas pipe:




*Pipe diameter is indicated by inside diameter.

For Liquid pipe:




CMY-Y102LS-G2

For Gas pipe:




*Pipe diameter is indicated by inside diameter.

For Liquid pipe:



CMY-R101S-G




<Accessory>

- Cover1 Pcs.
- Band3 Pcs.

Note. Pipe diameter is indicated by inside diameter.

CMY-R102S-G






<Accessory>

- Cover1 Pcs.
- Band3 Pcs.

Note. Pipe diameter is indicated by inside diameter.

CMY-R201S-G

mm






<Accessory>

• Cover3 Pcs.

Note. Pipe diameter is indicated by inside diameter.

CMY-R202S-G

mm






<Accessory>

• Cover3 Pcs.

Note. Pipe diameter is indicated by inside diameter.

CMY-R203S-G

mm




<Accessory>


• Cover3 Pcs.

Note. Pipe diameter is indicated by inside diameter.


CMY-R204S-G



CMY-R205S-G




CMY-R301S-G



Note. Pipe diameter is indicated by inside diameter.


CMY-R302S-G



Note. Pipe diameter is indicated by inside diameter.

CMY-R302S-G1


mm



Note. Pipe diameter is indicated by inside diameter.

CMY-R303S-G


mm



Note. Pipe diameter is indicated by inside diameter.

CMY-R303S-G1


mm



Note. Pipe diameter is indicated by inside diameter.

CMY-R304S-G


mm



Note. Pipe diameter is indicated by inside diameter.

CMY-R304S-G1


mm



Note. Pipe diameter is indicated by inside diameter.

CMY-R305S-G


mm



Note. Pipe diameter is indicated by inside diameter.

CMY-R305S-G1


mm



Note. Pipe diameter is indicated by inside diameter.

CMY-R306S-G

mm




Note. Pipe diameter is indicated by inside diameter.

9-2. OUTDOOR TWINNING KIT



The following optional Outdoor Twinning Kit is needed to use to combine multiple refrigerant pipes. Refer to section "Piping Design" for the details of selecting a proper twinning pipe.

CMY-R100VBK4

Low-pressure twinning pipe




<Deformed pipe(Accessory)>




Note 1. Refer to the figure below for the installation position of the twinning pipe.

The Twinning pipe must be installed horizontally using a level vessel to avoid unit damage.





2. Use the attached pipe to braze the port-opening of the twinning pipe.
3. Pipe diameter is indicated by inside diameter.

High-pressure twinning pipe




<Deformed pipe(Accessory)>




CMY-R200VBK4

Low-pressure twinning pipe




<Deformed pipe(Accessory)>




Note 1. Refer to the figure below for the installation position of the twinning pipe.

The Twinning pipe must be installed horizontally using a level vessel to avoid unit damage.





2. Use the attached pipe to braze the port-opening of the twinning pipe.
3. Pipe diameter is indicated by inside diameter.

High-pressure twinning pipe




<Deformed pipe(Accessory)>



Note 1. Refer to the figure below for the installation position of the twinning pipe.

The Twinning pipe must be installed horizontally using a level vessel to avoid unit damage.







2. Use the attached pipe to braze the port-opening of the twinning pipe.
3. Pipe diameter is indicated by inside diameter.
4. Only use the twinning pipe by Mitsubishi (optional parts).

9-3. JOINT KIT "CMY-R160-J1" FOR BC CONTROLLER

Joint kit "CMY-R160-J1" for BC controller is used to combine 2 ports of the BC controller at a PURY/PQRY system so as to enable down-stream Indoor capacity above P/M80 as shown in Fig. 1.

The Joint kit include following items:



① Instruction	② Joint pipe(Small)	③ Joint pipe(Large)	④ Cover 1	⑤ Cover 2	⑥ Cover 3	⑦ Band	⑧ Reducer 1	⑨ Reducer 2
								
This sheet 1pc	1pc	1pc	2pcs	1pc for gas side	1pc for liquid side	8pcs	1pc	1pc

Please prepare the following items in the field. ① Tape for insulation material sealing ② Extension pipe for refrigerant circuit

② Joint pipe (for liquid side)

③ Joint pipe (for gas side)

mm (in.)



1. Designing CMY-R160-J1 to a PURY/PQRY system

The maximum down-stream Indoor capacity for 1 port of BC controller is P/M80. When the down-stream Indoor capacity is above P/M80, Joint kit CMY-R160-J1 is needed to combined 2 ports of BC controller to enlarge the capacity, like Group 2 and 3 in Fig. 1.

Maximum 3 Indoor units are allowed to connect to 1 port of BC controller or 2 combined ports of BC controller using CMY-R160-J1.

When connecting Indoor units to 1 port of BC controller or 2 combined ports of BC controller using CMY-R160-J1 or CMY-Y102SS-G2 is applicable, like Group 1 and 2 in Fig. 1

Caution: Mixed cooling and heating mode at the same time for Indoor units connecting to 1 port or 2 combined ports is not available.




Fig.1. CMY-R160-J1 applying scheme

2. Piping at the installation site

The connection of CMY-R160-J1 to BC controller and pipe leading to Indoor units is referable to Fig. 2. Non-oxidized brazing is necessary. All piping must be careful to avoid foreign material getting inside.

After piping and air-tight testing, insulation work to the Joint and pipe should be done. Details is available at the Installation Manual.





Fig.2. Connecting CMY-R160-J1

9-4. FIN GUARD


PAC-FG01S-E

For side surfaces of S and L modules (a set of two pieces)

■Left side of the unit




■Right side of the unit




PAC-FG02S-E

For side surfaces of XL modules (a set of two pieces)

■Left side of the unit




■Right side of the unit



PAC-FG01B-E


For rear surface of S module




PAC-FG02B-E

For rear surface of L module (a set of two pieces)

- Behind the unit (left)




- Behind the unit (right)



PAC-FG03B-E


For rear surface of XL module (a set of two pieces of the same type)




9-5. PANEL HEATER

If there is a risk that the drain water will freeze inside the outdoor unit, the installation of a panel heater is recommended. For details, refer to the panel heater Installation Manual.

PAC-PH01EHY-E (for S module)




Front view




Rear view

PAC-PH02EHY-E (for L module)




Front view




Rear view

PAC-PH03EHY-E (for XL module)





Front view



Rear view

10-1. General cautions

- ① Follow ordinance of your governmental organization for technical standard related to electrical equipment, wiring regulations, and guidance of each electric power company.
- ② Wiring for control (hereinafter referred to as transmission cable) shall be (50mm[1-5/8in.] or more) apart from power source wiring so that it is not influenced by electric noise from power source wiring. (Do not insert transmission cable and power source wire in the same conduit.)
- ③ Be sure to provide designated grounding work to outdoor unit.
- ④ Give some allowance to wiring for electrical part box of indoor and outdoor units, because the box is sometimes removed at the time of service work.
- ⑤ Never connect 380~415V(220~240V) power source to terminal block of transmission cable. If connected, electrical parts will be damaged.
- ⑥ Use 2-core shield cable for transmission cable. If transmission cables of different systems are wired with the same multiple-core cable, the resultant poor transmitting and receiving will cause erroneous operations.
- ⑦ When extending the transmission line, make sure to extend the shield cable as well.



10-2. Power supply for Outdoor unit

10-2-1. Electrical characteristics of Outdoor unit at cooling mode

Symbols: MCA (Max Circuit Amps)
RLA (Rated Load Amps) SC (Starting Current)

PURY-P-Y(S)NW-A2/TR2/RU2

PURY-P-YNW-A2/TR2/RU2	Unit Combination	Units			Power supply	Compressor		FAN	RLA(A)(50/60Hz)	
		Hz	Volts	Voltage range	MCA (A)	Output (kW)	SC (A)	Output (kW)	Cooling	Heating
PURY-P200YNW-A2/TR2/RU2(-BS)	-	50/60	380 400 415	Max:456V Min:342V	16.1	5.0	8	0.92	11.2/10.7/10.3	11.4/10.8/10.4
PURY-P250YNW-A2/TR2/RU2(-BS)	-				21.4	8.0	8	0.92	17.3/16.4/15.8	16.1/15.3/14.7
PURY-P300YNW-A2/TR2/RU2(-BS)	-				23.4	9.2	8	0.92	19.8/18.8/18.1	16.2/15.4/14.8
PURY-P350YNW-A2/TR2/RU2(-BS)	-				27.6	12.0	8	0.46+0.46	25.1/23.9/23.0	23.4/22.2/21.4
PURY-P400YNW-A2/TR2/RU2(-BS)	-				35.1	16.1	8	0.46+0.46	33.1/31.5/30.3	28.1/26.7/25.7
PURY-P450YNW-A2/TR2/RU2(-BS)	-				39.0	16.2	8	0.46+0.46	33.4/31.8/30.6	31.7/30.1/29.0
PURY-P500YNW-A2/TR2/RU2(-BS)	-				43.2	17.4	8	0.92+0.92	37.5/35.6/34.3	35.6/33.9/32.6
PURY-P550YNW-A2/TR2/RU2(-BS)	-				51.4	20.5	8	0.92+0.92	43.6/41.4/39.9	41.4/39.3/37.9
PURY-P400YSNW-A2/TR2/RU2(-BS)	PURY-P200YNW-A2/TR2/RU2(-BS)				16.1	5.0	8	0.92	23.2/22.0/21.3	23.6/22.4/21.6
	PURY-P200YNW-A2/TR2/RU2(-BS)				16.1	5.0	8	0.92		
PURY-P450YSNW-A2/TR2/RU2(-BS)	PURY-P250YNW-A2/TR2/RU2(-BS)				21.4	8.0	8	0.92	28.8/27.3/26.4	28.2/26.7/25.8
	PURY-P200YNW-A2/TR2/RU2(-BS)				16.1	5.0	8	0.92		
PURY-P500YSNW-A2/TR2/RU2(-BS)	PURY-P250YNW-A2/TR2/RU2(-BS)				21.4	8.0	8	0.92	35.6/33.8/32.6	33.3/31.6/30.5
	PURY-P250YNW-A2/TR2/RU2(-BS)				21.4	8.0	8	0.92		
PURY-P550YSNW-A2/TR2/RU2(-BS)	PURY-P300YNW-A2/TR2/RU2(-BS)				23.4	9.2	8	0.92	38.3/36.3/35.0	33.4/31.7/30.6
	PURY-P250YNW-A2/TR2/RU2(-BS)				21.4	8.0	8	0.92		
PURY-P600YSNW-A2/TR2/RU2(-BS)	PURY-P300YNW-A2/TR2/RU2(-BS)				23.4	9.2	8	0.92	40.9/38.9/37.5	33.4/31.7/30.6
	PURY-P300YNW-A2/TR2/RU2(-BS)				23.4	9.2	8	0.92		
PURY-P650YSNW-A2/TR2/RU2(-BS)	PURY-P350YNW-A2/TR2/RU2(-BS)				27.6	12.0	8	0.46+0.46	46.2/43.9/42.3	40.6/38.6/37.2
	PURY-P300YNW-A2/TR2/RU2(-BS)				23.4	9.2	8	0.92		
PURY-P700YSNW-A2/TR2/RU2(-BS)	PURY-P350YNW-A2/TR2/RU2(-BS)				27.6	12.0	8	0.46+0.46	51.9/49.3/47.5	48.3/45.9/44.3
	PURY-P350YNW-A2/TR2/RU2(-BS)				27.6	12.0	8	0.46+0.46		
PURY-P750YSNW-A2/TR2/RU2(-BS)	PURY-P400YNW-A2/TR2/RU2(-BS)				35.1	16.1	8	0.46+0.46	59.5/56.5/54.5	52.9/50.2/48.4
	PURY-P350YNW-A2/TR2/RU2(-BS)				27.6	12.0	8	0.46+0.46		
PURY-P800YSNW-A2/TR2/RU2(-BS)	PURY-P400YNW-A2/TR2/RU2(-BS)				35.1	16.1	8	0.46+0.46	68.4/65.0/62.6	58.0/55.1/53.1
	PURY-P400YNW-A2/TR2/RU2(-BS)				35.1	16.1	8	0.46+0.46		
PURY-P850YSNW-A2/TR2/RU2(-BS)	PURY-P450YNW-A2/TR2/RU2(-BS)				39.0	16.2	8	0.46+0.46	68.8/65.3/63.0	61.7/58.6/56.4
	PURY-P400YNW-A2/TR2/RU2(-BS)				35.1	16.1	8	0.46+0.46		
PURY-P900YSNW-A2/TR2/RU2(-BS)	PURY-P450YNW-A2/TR2/RU2(-BS)				39.0	16.2	8	0.46+0.46	69.1/65.7/63.3	65.4/62.1/59.8
	PURY-P450YNW-A2/TR2/RU2(-BS)				39.0	16.2	8	0.46+0.46		
PURY-P950YSNW-A2/TR2/RU2(-BS)	PURY-P500YNW-A2/TR2/RU2(-BS)				43.2	17.4	8	0.92+0.92	73.3/69.6/67.1	69.5/66.0/63.6
	PURY-P450YNW-A2/TR2/RU2(-BS)				39.0	16.2	8	0.46+0.46		
PURY-P1000YSNW-A2/TR2/RU2(-BS)	PURY-P500YNW-A2/TR2/RU2(-BS)				43.2	17.4	8	0.92+0.92	77.4/73.6/70.9	73.5/69.9/67.3
	PURY-P500YNW-A2/TR2/RU2(-BS)				43.2	17.4	8	0.92+0.92		
PURY-P1050YSNW-A2/TR2/RU2(-BS)	PURY-P550YNW-A2/TR2/RU2(-BS)				51.4	20.5	8	0.92+0.92	83.3/79.1/76.2	79.2/75.3/72.6
	PURY-P500YNW-A2/TR2/RU2(-BS)				43.2	17.4	8	0.92+0.92		
PURY-P1100YSNW-A2/TR2/RU2(-BS)	PURY-P550YNW-A2/TR2/RU2(-BS)				51.4	20.5	8	0.92+0.92	90.0/85.5/82.4	85.3/81.0/78.1
	PURY-P550YNW-A2/TR2/RU2(-BS)				51.4	20.5	8	0.92+0.92		

10-3. Power cable specifications

Thickness of wire for main power supply, capacities of the switch and system impedance

	Model	Minimum wire thickness (mm ²)			Ground-fault interrupter *1	Local switch (A)		Breaker for wiring (A) (Non-fuse breaker)	Max. Permissible System Impedance
		Main cable	Branch	Ground		Capacity	Fuse		
Outdoor unit	PURY-P200YNW-A2/TR2/RU2	4.0	-	4.0	30A 100mA 0.1sec. or less	25	25	30	*2
	PURY-P250YNW-A2/TR2/RU2	4.0	-	4.0	30A 100mA 0.1sec. or less	32	32	30	*2
	PURY-P300YNW-A2/TR2/RU2	4.0	-	4.0	30A 100mA 0.1sec. or less	32	32	30	*2
	PURY-P350YNW-A2/TR2/RU2	6.0	-	6.0	40A 100mA 0.1sec. or less	40	40	40	0.26Ω
	PURY-P400YNW-A2/TR2/RU2	10.0	-	10.0	60A 100mA 0.1sec. or less	63	63	60	0.20Ω
	PURY-P450YNW-A2/TR2/RU2	10.0	-	10.0	60A 100mA 0.1sec. or less	63	63	60	0.18Ω
	PURY-P500YNW-A2/TR2/RU2	10.0	-	10.0	60A 100mA 0.1sec. or less	63	63	60	0.16Ω
	PURY-P550YNW-A2/TR2/RU2	10.0	-	10.0	60A 100mA 0.1sec. or less	63	63	60	0.14Ω

*1 The Ground-fault interrupter should support Inverter circuit. The Ground-fault interrupter should combine using of local switch or wiring breaker.

*2 Meet technical requirements of IEC61000-3-3

1. Use dedicated power supplies for the outdoor unit and indoor unit. Ensure OC and OS are wired individually.
2. Bear in mind ambient conditions (ambient temperature, direct sunlight, rain water, etc.) when proceeding with the wiring and connections.
3. The wire size is the minimum value for metal conduit wiring. If the voltage drops, use a wire that is one rank thicker in diameter. Make sure the power-supply voltage does not drop more than 10%. Make sure that the voltage imbalance between the phases is 2% or less.
4. Specific wiring requirements should adhere to the wiring regulations of the region.
5. Power supply cords of parts of appliances for outdoor use shall not be lighter than polychloroprene sheathed flexible cord (design 60245 IEC57). For example, use wiring such as YZW.
6. A switch with at least 3 mm contact separation in each pole shall be provided when the Air Conditioner is installed.
7. For details on indoor unit wiring and breaker for current leakage, refer to the indoor unit Instruction Book and Installation Manual.

⚠ WARNING

- ♦ Be sure to use specified wires for connections and ensure no external force is imparted to terminal connections. If connections are not fixed firmly, heating or fire may result.
- ♦ Be sure to use the appropriate type of overcurrent protection switch. Note that generated overcurrent may include some amount of direct current.

⚠ CAUTION

- ♦ The breakers for current leakage should support Inverter circuit. (e.g. Mitsubishi Electric's NV-S-Series or equivalent). If no earth leakage breaker is installed, it may cause an electric shock.
- ♦ Breakers for current leakage should combine using of switch.
- ♦ Do not use anything other than a breaker with the correct capacity. Using a breaker of too large capacity may cause malfunction or fire.
- ♦ If a large electric current flows due to malfunction or faulty wiring, earth-leakage breakers on the unit side and on the upstream side of the power supply system may both operate.
Depending on the importance of the system, separate the power supply system or take protective coordination of breakers.

Note

- ♦ This device is intended for the connection to a power supply system with a maximum permissible system impedance shown in the above table at the interface point (power service box) of the user's supply.
- ♦ The user must ensure that this device is connected only to a power supply system which fulfils the requirement above.
If necessary, the user can ask the public power supply company for the system impedance at the interface point.
- ♦ This equipment complies with IEC 61000-3-12 provided that the short-circuit power S_{sc} is greater than or equal to $S_{sc}(*2)$ at the interface point between the user's supply and the public system. It is the responsibility of the installer or user of the equipment to ensure, by consultation with the distribution network operator if necessary, that the equipment is connected only to a supply with a short-circuit power S_{sc} greater than or equal to $S_{sc}(*2)$.


$S_{sc}(*2)$

Model	PURY-P200YNW -A2/TR2/RU2	PURY-P250YNW -A2/TR2/RU2	PURY-P300YNW -A2/TR2/RU2	PURY-P350YNW -A2/TR2/RU2	PURY-P400YNW -A2/TR2/RU2	PURY-P450YNW -A2/TR2/RU2	PURY-P500YNW -A2/TR2/RU2	PURY-P550YNW -A2/TR2/RU2
S_{sc} (MVA)	1.25	1.66	1.82	2.14	2.72	3.03	3.35	3.99

10-4. Power supply examples


The local standards and/or regulations is applicable at a higher priority.

10-4-1. PURY-P200, 250, 300, 350, 400, 450, 500, 550YNW-A2/TR2/RU2



Note:

- 1 The transmission cable is not-polarity double-wire.
- 2 Symbol Ⓢ means a screw terminal for wiring.
- 3 The shield wire of transmission cable should be connected to the grounding terminal at Outdoor unit. All shield wire of M-Net transmission cable among Indoor units should be connected to the S terminal at Indoor unit or all shield wire should be connected together. The broken line at the scheme means shield wire.
- 4 When the Outdoor unit connected with system controller, power-supply to TB7 of the outdoor unit(s) is needed. The connector change from CN41 to CN40 at one of the outdoor units will enable the outdoor unit to supply power to TB7, or an extra power supplying unit PAC-SC51KUA should be used. The transmission cable (above 1.25mm², shielded, CVVS/CPEVS/MVVS) among Outdoor units and system controllers is called central control transmission cable. The shield wire of the central control transmission cable must be grounded at the Outdoor unit whose CN41 is changed to CN40. When the power supplying unit PAC-SC51KUA is used, connect the shielded cable to the ground terminal on the PAC-SC51KUA.
- 5 MA R/C transmission cable (0.3-1.25mm²) must be less than 200m in length, while ME R/C transmission cable (0.3-1.25mm²) must be less than 10m in length. But transmission cable to the ME R/C can be extended using a M-NET cable (>=1.25mm²) when the length is counted in the M-Net length.
- 6 MA remote controller and ME remote controller should not be grouped together. When the PAR-CT01MA series, PAR-FS01MA series, PAR-4"x"MA series, or PAR-3"x"MA series ("x" represents 0 or later) is connected to a group, no other MA remote controllers can be connected to the same group.
- 7 If using 1 or 2 (main/sub) MA remote controller to control more than 1 Indoor unit, use MA transmission cable to connect all the TB15 terminals of the Indoor units. It is called "Grouping". If using 1 or 2 (main/sub) ME remote controller control more than 1 indoor unit, set address to Indoor unit and ME remote controller. For the method, refer to 11-4. "Address setting".
- 8 Indoor board consumes power from TB3. The power balance should be considered according to System Design 11-3. "System configuration restrictions".
- 9 If Transmission booster is needed, be sure to connect the shield wires to the both sides to the booster.
- 10 The critical current for choosing power source equipment is approximate 1.4 times of total rated current of the Outdoor unit(s) or Indoor unit(s).
- 11 When System controller (SC) is connected to the system, turn the SW5-1 on.
- 12 The phases of electricity power must be confirmed to be right used. Phase-reverse, or phase-missing could break the controllers.



Symbol		Model	Ground-fault interrupter *1, *2, *4	Local switch		Wiring breaker *4 (NFB) <A>	Minimum Wire thickness	
				BKC <A>	OCP*3, *4 <A>		Power wire <mm²>	Earth wire <mm²>
GFI	Ground-fault interrupter	PURY-P200YNW-A2/TR2/RU2	30A 100mA 0.1sec. or less	25	25	30	4	4
LW	Local switch	PURY-P250YNW-A2/TR2/RU2	30A 100mA 0.1sec. or less	32	32	30	4	4
BKC	Breaker capacity	PURY-P300YNW-A2/TR2/RU2	30A 100mA 0.1sec. or less	32	32	30	4	4
OCP	Over-current protector	PURY-P350YNW-A2/TR2/RU2	40A 100mA 0.1sec. or less	40	40	40	6	6
WB	Wiring breaker	PURY-P400YNW-A2/TR2/RU2	60A 100mA 0.1sec. or less	63	63	60	10	10
NFB	Non-fuse breaker	PURY-P450YNW-A2/TR2/RU2	60A 100mA 0.1sec. or less	63	63	60	10	10
OU	Outdoor unit	PURY-P500YNW-A2/TR2/RU2	60A 100mA 0.1sec. or less	63	63	60	10	10
IU	Indoor unit	PURY-P550YNW-A2/TR2/RU2	60A 100mA 0.1sec. or less	63	63	60	10	10

SC System controller
MA R/C MA remote controller
ME R/C ME remote controller

*1 The Ground-fault interrupter should support Inverter circuit. (e.g. Mitsubishi Electric's NV-S-Series or equivalent).

*2 Ground-fault interrupter should combine using of local switch or wiring breaker.

*3 It shows data for B-type fuse of the breaker for current leakage.

*4 If a large electric current flows due to malfunction or faulty wiring, earth-leakage breakers on the unit side and on the centralized controller side may both operate.



Depending on the importance of the system, separate the power supply system or take protective coordination of breakers.

PURRY-P-Y(S)NW-A2/TR2/RU2

10-4-2. PURY-P400, 450, 500, 550, 600, 650, 700, 750, 800, 850, 900, 950, 1000, 1050, 1100YSNW-A2/TR2/RU2

Note11 SC

Central control transmission cable
≥1.25 mm² or ø1.2 mm
Shield cable
(CVVS, CPEVS, MVVS)



Symbol		Model	Ground-fault interrupter *1, *2, *4	Local switch		Wiring breaker *4	Minimum Wire thickness	
				BKC <A>	OCP*3, *4 <A>	(NFB) <A>	Power wire <mm²>	Earth wire <mm²>
GFI	Ground-fault interrupter	PURY-P200YNW-A2/TR2/RU2	30A 100mA 0.1sec. or less	25	25	30	4	4
LW	Local switch	PURY-P250YNW-A2/TR2/RU2	30A 100mA 0.1sec. or less	32	32	30	4	4
BKC	Breaker capacity	PURY-P300YNW-A2/TR2/RU2	30A 100mA 0.1sec. or less	32	32	30	4	4
OCP	Over-current protector	PURY-P350YNW-A2/TR2/RU2	40A 100mA 0.1sec. or less	40	40	40	6	6
WB	Wiring breaker	PURY-P400YNW-A2/TR2/RU2	60A 100mA 0.1sec. or less	63	63	60	10	10
NFB	Non-fuse breaker	PURY-P450YNW-A2/TR2/RU2	60A 100mA 0.1sec. or less	63	63	60	10	10
OU	Outdoor unit	PURY-P500YNW-A2/TR2/RU2	60A 100mA 0.1sec. or less	63	63	60	10	10
IU	Indoor unit	PURY-P550YNW-A2/TR2/RU2	60A 100mA 0.1sec. or less	63	63	60	10	10

MEES24K031


11-1. Transmission cable length limitation

11-1-1. Using MA Remote controller

Long transmission cable causes voltage down, therefore, the length limitation should be obeyed to secure proper transmission.

Max. length via Outdoor (M-NET cable)	$L_1+L_2+L_3, L_1+L_2+L_4, L_3+L_4, L_5+L_2+L_3, L_5+L_2+L_4$	$\leq 500\text{m}(1000\text{m}^*1)[1640\text{ft.}(3280\text{ft.}^*1)]$	Larger than 1.25 mm ² [AWG16], or $\phi 1.2$ mm or above
Max. length to Outdoor (M-NET cable)	$L_1+L_5, L_3, L_2+L_4+L_5$	$\leq 200\text{m}[656\text{ft.}]$	Larger than 1.25 mm ² [AWG16], or $\phi 1.2$ mm or above
Max. length from MA to Indoor for each group	$a_1+a_2, a_1+a_2+a_3+a_4$	$\leq 200\text{m}[656\text{ft.}]$	0.3-1.25 mm ² [AWG22-16]

*1 When the wiring length exceeds 500 m (1640 ft), consult the sales office.



OC, OS: Outdoor unit controller; IC: Indoor unit controller; MA: MA remote controller


11-1-2. Using ME Remote controller

Long transmission cable causes voltage down, therefore, the length limitation should be obeyed to secure proper transmission.

Max. length via Outdoor (M-NET cable)	$L_1+L_2+L_3+L_4, L_1+L_2+L_5, L_3+L_4+L_5, L_6+L_2+L_3+L_4, L_6+L_2+L_5, L_3+L_5$	$\leq 500\text{m}(1000\text{m}^*1)[1640\text{ft.}(3280\text{ft.}^*1)]$	Larger than 1.25 mm ² [AWG16], or $\phi 1.2$ mm or above
Max. length to Outdoor (M-NET cable)	$L_1+L_6, L_3+L_4, L_2+L_5+L_6$	$\leq 200\text{m}[656\text{ft.}]$	Larger than 1.25 mm ² [AWG16], or $\phi 1.2$ mm or above
Max. length from ME to Indoor	e_1, e_2, e_3, e_4	$\leq 10\text{m}[32\text{ft.}]^*2$	0.3-1.25 mm ² [AWG22-16] *2

*1 When the wiring length exceeds 500 m (1640 ft), consult the sales office.

*2. If the length from ME to Indoor exceed 10m, use 1.25 mm² [AWG16] shielded cable, but the total length should be counted into Max. length via Outdoor.



OC, OS: Outdoor unit controller; IC: Indoor unit controller; ME: ME remote controller

11-2. Transmission cable specifications

	Transmission cables (Li)	MA Remote controller cables	ME Remote controller cables
Type of cable	Shielded cables (2-core) CVVS, CPEVS, and MVVS	VCTF, VCTFK, CVV, VVR, VVF, VCT	Shielded cables (2-core) CVVS, CPEVS, and MVVS
Cable size	Larger than 1.25 mm ² [AWG16], or ø1.2 mm or above	0.3 to 1.25 mm ² [AWG22 to 16] *1 *5	0.3 to 1.25 mm ² [AWG22 to 16] *1 *6
Maximum overall line length	Refer to 11-1.	200 m [656 ft] *3 *4	10 m [32 ft] *2

*1 The use of cables that are smaller than 0.75 mm² (AWG18) is recommended for easy handling.

*2 The section of the cable that exceeds 10 m [32 ft] must be included in the maximum indoor-outdoor transmission line distance.

*3 Max. 70 m [229 ft] for PAR-CT01MA series

*4 Max. 150 m [492 ft] for PAR-FS01MA series

*5 To wire PAR-CT01MA series, PAR-FS01MA series, PAR-4"x"MA series, PAR-3"x"MA series ("x" represents 0 or later), or Simple MA remote controller, use a cable with a size of 0.3 mm² (AWG 22).

*6 When connected to the terminal block on the Simple remote controller, use a cable with a size of 0.75 to 1.25 mm² (AWG18 to 16).

CVVS, MVVS: PVC insulated PVC sheathed shielded control cable
CPEVS: PE insulated PVC sheathed shielded communication cable
CVV: PVC insulated PVC sheathed control cable

11-3. System configuration restrictions

11-3-1. Common restrictions for the CITY MULTI system

For each Outdoor/Heat source unit, the maximum connectable quantity of Indoor unit is specified at its Specifications table.

- A) 1 Group of Indoor units can have 1-16 Indoor units;
*OA processing unit GUF-RD(H) is considered as Indoor unit.
- B) Maximum 2 remote controllers for 1 group;
*MA/ME remote controllers cannot be present together in 1 group.
*When the PAR-CT01MA series, PAR-FS01MA series, PAR-4"x"MA series, or PAR-3"x"MA series ("x" represents 0 or later) is connected to a group, no other MA remote controllers can be connected to the same group.
- C) 1 LOSSNAY unit can interlock maximum 16 Indoor units; 1 Indoor unit can interlock only 1 LOSSNAY unit.
- D) Maximum 3 System controllers are connectable when connecting to TB3 of the Outdoor/Heat source unit.
- E) A maximum of 6 system controllers are connectable to TB3 and TB7 of Outdoor/Heat source unit.
- F) 4 System controllers or more are connectable when connecting to TB7 of the Outdoor/Heat source unit, if the transmission power is supplied by the power supply unit PAC-SC51KUA.
*System controller connected as described in D) would have a risk that the failure of connected Outdoor/Heat source unit would stop power supply to the System controller.

11-3-2. Ensuring proper communication power and the number of connected units for M-NET

In order to ensure proper communication among Outdoor/Heat source unit, Indoor unit, LOSSNAY, OA processing unit GUF-RD(H), and Controllers, the transmission power situation for the M-NET should be observed. In some cases, Transmission booster should be used. Taking the power consumption of Indoor unit as 1, the equivalent power consumption or supply of others are listed at Table 1 and Table 2.

Both the transmission line for centralized controller and indoor-outdoor transmission line must meet the conditions listed below. (Both conditions a) and b) must be met.)

a) [Total equivalent power consumption] ≤ [The equivalent power supply]

b) [Total equivalent number of units (Table 1)] ≤ [40]

Table 1 The equivalent power consumption and the equivalent number of units

Category	Model	The equivalent power consumption	The equivalent number of units
CITY MULTI indoor unit OA unit CITY MULTI connection kit Air handling unit controller	Except for the models indicated by *2 PEFY-AF2500, 3000, 4000, 5000, 6000MH GUF-50, 100 PAC-LV11M-J PAC-AH125, 140, 250, 500M-J	1	1
CITY MULTI indoor unit *2	PDFY-P100VM-E-RE	2	2
BC controller	CMB-P/M	2	1
HBC controller	CMB-WP	2	1
	CMB-WM-V-AA/AB		
	CMB-WM-F-AA CMB-WM-V-BB	2	2
Hydro unit	CMH-WM-V-A	2	1
PWFY *1	P100VM-E1-BU	6	1
	P200VM-E1-AU P200VM-E2-AU	5	1
	(E)P100VM-E1-AU (E)P100VM-E2-AU P140VM-E1-AU P140VM-E2-AU	1	1
	P250, 300, 500, 600VM-E(-F)	1	1
	P750, 900VM-E(-F)	2	2
PFAV		1	1
PFV, PEV	P200, 250, 400, 500YM-A	1	1
MA remote controller/ LOSSNAY	PAR-CT01MAA PAR-FS01MA PAR-21, 31, 32, 33, 40, 41MAA PAC-YT52CRA PAR-FA32MA LGH PZ-60, 61, 62DR PZ-43SMF-E	0	0
ME remote controller	PAR-U02MEDA	0.5	1
	PZ-52SF	0.25	1
System controller	AE-C400E/EW-C50E AE-200E/AE-50E/EW-50E	0	0
	AG-150A EB-50GU-J PAC-IF01AHC-J	0.5	1
	AT-50B	1.5	5
	PAC-YG60MCA PAC-YG66DCA PAC-YG63MCA	0.25	1
ON/OFF controller	PAC-YT40ANRA	1	1
MN converter	CMS-MNG-E	2	1
Outdoor/Heat source unit	TB7 power consumption	0	0
System control interface	MAC-333IF-E		
A-M converter	PAC-SF83MA-E	0	0

*1 PWFY cannot be connected to PUMY model.

Table 2 The equivalent power supply

Category	Model	The equivalent power supply		
Transmission Booster	PAC-SF46EPA-G	25 *1		
Power supply unit	PAC-SC51KUA	5		
Expansion controller	PAC-YG50ECA	6		
BM ADAPTER	BAC-HD150	6		
System controller	AE-C400E/EW-C50E	0.75		
	AE-200E/AE-50E	0.75		
	EW-50E	1.5		
Outdoor/Heat source unit		TB3 and TB7 total	TB7 only	TB3 only
	Outdoor unit except S-Series and TKA *2	32 *1	6	32 *1-equivalent power supplied to TB7
	S-Series outdoor unit	12 *1	0	12 *1
	S-Series outdoor unit (YBM)	32 *1	0	32 *1
	TKA outdoor unit	32 *1	- *3	32 *1

*1 When one or more indoor units listed below is connected, subtract 3 from the equivalent power supply.

Table 3

Category	Model
Indoor unit	Sized P200/P250
	PEFY-AF4000/5000/6000MH, PFFY-P400/500YM-E, PFFY-P400/500YMH-C
	PFFY-P300/600YM-E-F, PFFY-P300/600YM-C-F, PDFY-P100VM-E-RE
Air handling unit controller	PAC-AH250/500M-J
PFAV	PFAV-P500/600/750/900VM-E(-F)
PFV	PFV-P400/500YM-A
PEV	PEV-P400/500YM-A

*2 If PAC-SC51KUA is used to supply power at TB7 side, no power supply need from Outdoor/Heat source unit at TB7, Connector TB3 itself will therefore have 32.

*3 Do not supply power to TB7 from TKA outdoor units.

Use PAC-SC51KUA or PAC-SF46EPA-G when connecting an M-NET device to TB7.


With the equivalent power consumption values and the equivalent number of units in Table 1 and Table 2, PAC-SF46EPA-G can be designed into the air-conditioner system to ensure proper system communication according to (A), (B), (C).

- (A) Firstly, count from TB3 at TB3 side the total equivalent number of units of Indoor units, OA processing units, ME remote controller, and System controllers. If the total equivalent number of units reaches 40, a PAC-SF46EPA-G should be set.
- (B) Secondly, count from TB7 side to TB3 side the total transmission power consumption. If the total equivalent power supply reaches 32, a PAC-SF46EPA-G should be set. Yet, if a PAC-SC51KUA or another controller with a built-in power supply, such as AE-C400E/EW-C50E, is used to supply power at TB7 side, count from TB3 side only.
- (C) Thirdly, count from TB7 at TB7 side the total transmission power consumption. If the total equivalent power supply for only TB7 reaches 6, a PAC-SF46EPA-G should be set. Also, count from TB7 at TB7 side the total equivalent number of units of System controllers, and so on. If the total equivalent number of units reaches 40, a PAC-SF46EPA-G should be set.

* The equivalent power supply of S-Series outdoor unit is 12.

* When one or more indoor units listed in Table 3 is connected, subtract 3 from the equivalent power supply.

■ System example



11-3-3. Ensuring proper power supply to System controller


The power to System controller (excluding AE-C400E, EW-C50E) is supplied via M-NET transmission line. M-NET transmission line at TB7 side is called Centralized control transmission line while one at TB3 side is called Indoor-Outdoor/Heat source transmission line. There are 4 ways to supply power to the System controller.

- A) Connecting to TB3 of the Outdoor/Heat source unit and receiving power from the Outdoor/Heat source unit.
- B) Connecting to TB7 of the Outdoor/Heat source unit and receiving power from the Outdoor/Heat source unit.
(Not applicable to the PUMY model)
- C) Connecting to TB7 of the Outdoor/Heat source unit but receiving power from power supply unit PAC-SC51KUA.
- D) Connecting to TB7 of the Outdoor/Heat source unit and receiving power from system controllers (AE-C400E, EW-C50E).

11-3-3-A. When connecting to TB3 of the Outdoor/Heat source unit and receiving power from the Outdoor/Heat source unit.

Maximum 3 System controllers can be connected to TB3.
If there is more than 1 Outdoor/Heat source unit, it is necessary to replace power supply switch connector CN41 with CN40 on one Outdoor/Heat source unit.


Fig. 11-3-3-A



11-3-3-B. When connecting to TB7 of the Outdoor/Heat source unit and receiving power from the Outdoor/Heat source unit. (Not applicable to the PUMY model)

A maximum of 6 system controller are connectable to TB3 and TB7 of Outdoor/Heat source unit. (Not applicable to the PUMY model)
It is necessary to replace power supply switch connector CN41 with CN40 on one Outdoor/Heat source unit.


Fig. 11-3-3-B



11-3-3-C. When connecting to TB7 of the Outdoor/Heat source unit but receiving power from PAC-SC51KUA.

When feeding power to the system controller from the power-supply unit PAC-SC51KUA, leave the power jumper connected to the CN41 of the outdoor/heat-source unit as it is (factory setting). The equivalent power consumption of a controller that is connectable to a PAC-SC51KUA is "5" as shown in Table 2. When connecting a system controller with an equivalent power consumption of greater than 5, use a transmission booster PAC-SF46EPA-G.

Fig. 11-3-3-C




11-3-3-D. When connecting to TB7 of the Outdoor/Heat source unit and receiving power from system controllers (AE-C400E, EW-C50E).

System controllers (AE-C400E, EW-C50E) have a built-in function to supply power to the M-NET transmission lines, so no power needs to be supplied to the M-NET transmission lines from the Outdoor/Heat source units or from PAC-SC51KUA.

When feeding power to the system controller from the power-supply unit PAC-SC51KUA, leave the power jumper connected to the CN41 of the outdoor/heat-source unit as it is (factory setting).
Refer to 11-3-2 for information about the power-supply capacity of each system controller (EW-C50E) to the sub system controllers.

Fig. 11-3-3-D



11-3-4. Power supply to expansion controller

1-phase 100-240VAC power supply is needed.

The power supply unit PAC-SC51KUA is not necessary.

The expansion controller supplies power through TB3, which equals 6 indoor units. (refer to Table 2)

11-3-5. Power supply to BM ADAPTER

1-phase 100-240VAC power supply is needed.

The power supply unit PAC-SC51KUA is not necessary when only BM ADAPTER is connected.

Yet, make sure to move the power jumper from CN41 to CN40 on the BM ADAPTER.

11-3-6. Power supply to AE-C400E/EW-C50E

1-phase 100-240VAC power supply is needed.


The power supply unit PAC-SC51KUA is not necessary when connecting only the AE-C400E/EW-C50E.

11-4. Address setting

11-4-1. Switch operation

In order to constitute CITY MULTI in a complete system, switch operation for setting the unit address No. and connection No. is required.

- ① Address No. of outdoor unit, indoor unit and remote controller.
The address No. is set at the address setting board.
In the case of R2 system, it is necessary to set the same No. at the branch No. switch of indoor unit as that of the BC controller connected. (When connecting two or more branches, use the lowest branch No.)



- ② Caution for switch operations

- Be sure to shut off power source before switch setting. If operated with power source on, switch can not operate properly.
- No units with identical unit address shall exist in one whole air conditioner system. If set erroneously, the system can not operate.

- ③ MA remote controller

- When connecting only one remote controller to one group, it is always the main remote controller.
When connecting two remote controllers to one group, set one remote controller as the main remote controller and the other as the sub remote controller.
- The factory setting is "Main".

PAR-4"x"MAA ("x" represents 0 or later), PAR-CT01MA, PAR-FS01MA

The MA remote controller does not have the switches listed above.

Refer to the installation manual for the function setting.

PAC-YT52CRA

Setting the dip switches

There are switches on the back of the top case. Remote controller Main/Sub and other function settings are performed using these switches. Ordinarily, only change the Main/Sub setting of SW1.

(The factory settings are ON for SW1, 2, and 3 and OFF for SW4.)

SW No.	SW contents Main	ON	OFF	Comment
1	Remote controller Main/Sub setting	Main	Sub	Set one of the two remote controllers at one group to "ON".
2	Temperature display units setting	Celsius	Fahrenheit	When the temperature is displayed in [Fahrenheit], set to "OFF".
3	Cooling/heating display in AUTO mode	Yes	No	When you do not want to display "Cooling" and "Heating" in the AUTO mode, set to "OFF".
4	Indoor temperature display	Yes	No	When you want to display the indoor temperature, set to "ON".

11-4-2. Rule of setting address

Unit		Address setting	Example	Note
Indoor unit System control interface (MAC-333IF-E) A-M converter (PAC-SF83MA-E) Air handling unit controller (PAC-AH125, 140, 250, 500M-J) CITY MULTI connection Kit (PAC-LV11M-J)		01 ~ 50	 	Use the most recent address within the same group of indoor units. Make the indoor units address connected to the BC controller (Sub) larger than the indoor units address connected to the BC controller (Main). If applicable, set the sub BC controllers in an PURY system in the following order: (1) Indoor unit to be connected to the BC controller (Main) (2) Indoor unit to be connected to the BC controller (No.1 Sub) (3) Indoor unit to be connected to the BC controller (No.2 Sub) Set the address so that (1)<(2)<(3) A maximum of 12 BC controllers are connectable.
Outdoor unit		51 ~ 99, 100 (Note1)	 	The smallest address of indoor unit in same refrigerant system + 50 Assign sequential address numbers to the outdoor units in one refrigerant circuit system. OC, OS1 and OS2 are automatically detected. (Note 2) * Please reset one of them to an address between 51 and 99 when two addresses overlap. * The address automatically becomes "100" if it is set as "01~ 50"
BC controller (Main)		52 ~ 99, 100	 	The address of outdoor unit + 1 * Please reset one of them to an address between 51 and 99 when two addresses overlap. * The address automatically becomes "100" if it is set as "01~ 50"
BC controller (Sub)		52 ~ 99, 100	 	Lowest address within the indoor units connected to the BC controller (Sub) plus 50.
Local remote controller	ME Remote controller (Main)	101 ~ 150	1 Fixed  	The smallest address of indoor unit in the group + 100 * The place of "100" is fixed to "1"
	ME Remote controller (Sub)	151 ~ 199, 200	1 Fixed  	The address of main remote controller + 50 * The address automatically becomes "200" if it is set as "00"
System controller	ON/OFF remote controller	201 ~ 250	  	The smallest group No. to be managed + 200 * The smallest group No. to be managed is changeable.
	AE-C400E/EW-C50E AE-200E/AE-50E EW-50E AG-150A AT-50B	000, 201 ~ 250	  	* AT-50B cannot be set to "000".
	PAC-YG50ECA	000, 201 ~ 250	  	* Settings are made on the initial screen of AG-150A.
	BAC-HD150	000, 201 ~ 250	  	* Settings are made with setting tool of BM ADAPTER.
PI, AI, DIDO	PAC-YG60MCA	01 ~ 50	 	
	PAC-YG63MCA	01 ~ 50	 	
	PAC-YG66DCA	01 ~ 50	 	
LOSSNAY, OA processing unit		01 ~ 50	 	After setting the addresses of all the indoor units, assign an arbitrary address.
PAC-IF01AHC		201 ~ 250	2 Fixed  	

Note1: To set the address to "100", set it to "50"

Note2: Outdoor units OC, OS1 and OS2 in one refrigerant circuit system are automatically detected. OC, OS1 and OS2 are ranked in descending order of capacity. If units are the same capacity, they are ranked in ascending order of their address.

11-4-3. System examples

Factory setting


Original switch setting of the outdoors, indoors, controllers and BM ADAPTER at shipment is as follows.

- Outdoor unit : Address: 00, CN41: ON (Jumper), DipSW5-1: OFF
- Indoor unit : Address: 00
- BC controller : Address: 00
- ME remote controller : Address: 101
- BM ADAPTER : Address: 000, CN41: ON (Jumper)
- AE-C400E/EW-C50E : Address: 000, CN21: ON (Jumper)

Setting at the site

- DipSW5-1(Outdoor) : When the System Controller is used, all the Dip SW5-1 at the outdoor units should be set to "ON".
- DipSW 4-1 and 4-6 (BC controller) : Set DipSW 4-6 to ON at BC controller, in case of connected Indoor unit sized P100-P250 with 2 ports. It is also possible to connect Indoor unit sized P100-P140 with 1 port (set DipSW 4-1 and 4-6 to OFF).
- CN40/CN41 : Change jumper from CN41 to CN 40 at outdoor control board will activate central transmission power supply to TB7;
(Change jumper at only one outdoor unit when activating the transmission power supply without using a power supply unit.)
Change jumper from CN41 to CN 40 at BM ADAPTER will activate transmission power supply to BM ADAPTER itself;
Power supply unit is recommended to use for a system having more than 1 outdoor unit, because the central transmission power supply from TB7 of one of outdoor units is risking that the outdoor unit failure may let down the whole system controller system.
- CN21(AE-C400E/EW-C50E) : Activates the power supply to M-NET transmission line from AE-C400E/EW-C50E (CN21: ON (power supplied), OFF (power not supplied))

11-4-3-1. MA remote controller, Single-refrigerant-system, No System Controller




*1 For Wireless R/C and Signal receiver unit (SRU), channel 1, 2 and 3 are selectable and should be set to same channel.

NOTE:

1. Outdoor units OC and OS in one refrigerant circuit system are automatically detected.
OC and OS are ranked in descending order of capacity. If units are the same capacity, they are ranked in ascending order of their address.
2. No address setting is needed.
3. For a system having more than 32 indoor unit, confirm the need of Booster at 11-3. "System configuration restrictions".
4. Indoor units should be set with a branch number.
5. Address setting is required if a sub BC controller is connected.
6. When the PAR-CT01MA series, PAR-FS01MA series, PAR-4"x"MA series, or PAR-3"x"MA series ("x" represents 0 or later) is connected to a group, no other MA remote controllers can be connected to the same group.

11-4-3-2. MA remote controller, Single-refrigerant-system, System Controller



*1 For Wireless R/C and Signal receiver unit (SRU), channel 1, 2 and 3 are selectable and should be set to same channel.


*SC can be connected to TB3 side or TB7 side;

Should SC connected to TB7 side, change Jumper from CN41 to CN40 at the Outdoor unit module so as to supply power to the SC.

NOTE:

1. Outdoor units OC and OS in one refrigerant circuit system are automatically detected.
OC and OS are ranked in descending order of capacity. If units are the same capacity, they are ranked in ascending order of their address.
2. Address should be set to Indoor units and centralized controller.
3. For a system having more than 32 indoor unit, confirm the need of Booster at 11-3. **"System configuration restrictions"**.
4. Indoor units should be set with a branch number.
5. When the PAR-CT01MA series, PAR-FS01MA series, PAR-4"x"MA series, or PAR-3"x"MA series ("x" represents 0 or later) is connected to a group, no other MA remote controllers can be connected to the same group.

11-4-3-3. MA remote controller, Multi-refrigerant-system, System Controller at TB7/TB3 side, Booster for long M-NET wiring



*1 For Wireless R/C and Signal receiver unit (SRU), channel 1, 2 and 3 are selectable and should be set to same channel.

*2 System controller should connect to TB7 at Outdoor and use power supply unit together in Multi-Refrigerant-System.

For AE-C400E and EW-C50E, the power supply unit PAC-SC51KUA is unused.

*3 When multiple system controllers are connected in the system, set the controller with more functions than others as a "main" controller and others as "sub".

AE-C400E and EW-C50E are for exclusive use as a "main" system controller and cannot be used as a "sub" system controller.


Make the setting to only one of the system controllers for "prohibition of operation from local remote controller".

*4 The power supply unit is not necessary for AE-C400E and EW-C50E.

NOTE:

- Outdoor units OC and OS in one refrigerant circuit system are automatically detected.
OC and OS are ranked in descending order of capacity. If units are the same capacity, they are ranked in ascending order of their address.
- Address should be set to Indoor units, LOSSNAY, and system controller.
- M-NET power is supplied by the Outdoor unit at TB3, while Indoor unit and ME remote controller consume the M-NET power for transmission use. The power balance is needed to consider for long M-NET wiring. Details refer to 11-3. **"System configuration restrictions"**.
- Indoor units should be set with a branch number.
- Assign an address to each of the sub BC controllers which equals the sum of the smallest address of the indoor units that are connected to each sub BC controller and 50.
- When the PAR-CT01MA series, PAR-FS01MA series, PAR-4"x"MA series, or PAR-3"x"MA series ("x" represents 0 or later) is connected to a group, no other MA remote controllers can be connected to the same group.


11-4-3-4. ME remote controller, Single-refrigerant-system, No system controller



NOTE:

1. Outdoor units OC and OS in one refrigerant circuit system are automatically detected. OC and OS are ranked in descending order of capacity. If units are the same capacity, they are ranked in ascending order of their address.
2. Address should be set to Indoor units and ME remote controllers.
3. M-NET power is supplied by the Outdoor unit at TB3, while Indoor unit and ME RC consume the M-NET power for transmission use. The power balance is needed to consider for long M-NET wiring. Details refer to 11-3. "System configuration restrictions".
4. Indoor units should be set with a branch number.

11-4-3-5. ME remote controller, Single-refrigerant-system, System controller, LOSSNAY




*SC can be connected to TB3 side or TB7 side;

Should SC connected to TB7 side, change Jumper from CN41 to CN40 at the Outdoor unit module so as to supply power to the SC.

NOTE:

1. Outdoor units OC and OS in one refrigerant circuit system are automatically detected. OC and OS are ranked in descending order of capacity. If units are the same capacity, they are ranked in ascending order of their address.
2. Address should be set to Indoor units, LOSSNAY, centralized controller, and ME remote controllers.
3. For a system having more than 32 indoor unit, confirm the need of Booster at 11-3. "System configuration restrictions".
4. Indoor units should be set with a branch number.

11-4-3-6. ME remote controller, Multi-refrigerant-system, System Controller at TB7 side, LOSSNAY, Booster for long M-NET wiring



*1 System controller should connect to TB7 at Outdoor and use power supply unit together in Multi-Refrigerant-System.

For AE-C400E and EW-C50E, the power supply unit PAC-SC51KUA is unused.

*2 When multiple system controllers are connected in the system, set the controller with more functions than others as a "main" controller and others as "sub".


AE-C400E and EW-C50E are for exclusive use as a "main" system controller and cannot be used as a "sub" system controller.

Make the setting to only one of the system controllers for "prohibition of operation from local remote controller".

NOTE:

- Outdoor units OC and OS in one refrigerant circuit system are automatically detected.
OC and OS are ranked in descending order of capacity. If units are the same capacity, they are ranked in ascending order of their address.
- M-NET power is supplied by the Outdoor unit at TB3, while Indoor unit and ME RC consume the M-NET power for transmission use.
The power balance is needed to consider for long M-NET wiring. Details refer to 11-3. "System configuration restrictions".
- Indoor units should be set with a branch number.
- Assign an address to each of the sub BC controllers which equals the sum of the smallest address of the indoor units that are connected to each sub BC controller and 50.
When the address assigned to sub BC controller overlaps those of any other units including outdoor units (OC/OS) or main BC controller, sub BC controller will be given priority to have the address.

11-4-3-7. Example: BC, BC sub



NOTE • Indoor units should be set with a branch number.


• BC (main) address = O/U address + 1

• BC (sub) address = Lowest address within the indoor units connected to the BC controller (sub) + 50

• If applicable, set the sub BC controllers in an PURY system in the following order:

- (1) Indoor unit to be connected to the BC controller (Main)
 - (2) Indoor unit to be connected to the BC controller (No.1 Sub)
 - (3) Indoor unit to be connected to the BC controller (No.2 Sub)
- Set the address so that (1)<(2)<(3)
A maximum of 12 BC controllers are connectable.


11-4-3-8. ME remote controller, Multi-refrigerant-system, No Power supply unit



NOTE

- It is necessary to change the connector to CN40 on the outdoor unit control board (only one outdoor unit) when the group is set between other refrigerant systems.
- It is necessary to set on the remote controller by manual when group sets on the different refrigerant system. Please refer to remote controller installation manual.


11-4-3-9. ME remote controller, Multi-refrigerant-system, System Controller at TB7 side, No Power supply unit



NOTE

- It is necessary to change the connector to CN40 on the outdoor unit control board (only one outdoor unit) when the group is set between other refrigerant systems.
- It is necessary to set on the remote controller by manual when group sets on the different refrigerant system. Please refer to remote controller installation manual.

AE-C400E can control max. 400 indoor units/via EW-C50E.




*2 When the PAR-CT01MA series, PAR-FS01MA series, PAR-4"x"MA series, or PAR-3"x"MA series ("x" represents 0 or later) is connected to a group, no other MA remote controllers can be connected to the same group.

11-4-3-11. BACnet®

EW-C50E (AE-C400E) can control up to 50 units/groups (including LOSSNAY).

*To use the BACnet® function on EW-C50E (AE-C400E), BACnet® license registration is required.



*1 For Wireless R/C and Signal receiver unit (SRU), channel 1, 2 and 3 are selectable and should be set to same channel.

*2 When the PAR-CT01MA series, PAR-FS01MA series, PAR-4"x"MA series, or PAR-3"x"MA series ("x" represents 0 or later) is connected to a group, no other MA remote controllers can be connected to the same group.

12-1. R410A Piping material

Refrigerant pipe for CITY MULTI shall be made of phosphorus deoxidized copper, and has two types.

A. Type-O: Soft copper pipe (annealed copper pipe), can be easily bent with human's hand.

B. Type-1/2H pipe: Hard copper pipe (Straight pipe), being stronger than Type-O pipe of the same radial thickness.

The maximum operation pressure of R410A air conditioner is 4.30 MPa [623psi]. The refrigerant piping should ensure the safety under the maximum operation pressure. MITSUBISHI ELECTRIC recommends pipe size as Table1, or You shall follow the local industrial standard. Pipes of radial thickness 0.7mm or less shall not be used.

Table 1. Copper pipe size and radial thickness for R410A CITY MULTI.



Size (mm)	Size (in.)	Radial thickness (mm)	Radial thickness (mil)	Pipe type
ø6.35	ø1/4"	0.8	[32]	Type-O
ø9.52	ø3/8"	0.8	[32]	Type-O
ø12.7	ø1/2"	0.8	[32]	Type-O
ø15.88	ø5/8"	1.0	[40]	Type-O
ø19.05	ø3/4"	1.2	[48]	Type-O
ø19.05	ø3/4"	1.0	[40]	Type-1/2H or H
ø22.2	ø7/8"	1.0	[40]	Type-1/2H or H
ø25.4	ø1"	1.0	[40]	Type-1/2H or H
ø28.58	ø1-1/8"	1.0	[40]	Type-1/2H or H
ø31.75	ø1-1/4"	1.1	[44]	Type-1/2H or H
ø34.93	ø1-3/8"	1.2	[48]	Type-1/2H or H
ø41.28	ø1-5/8"	1.4	[56]	Type-1/2H or H

* For pipe sized ø19.05 (3/4") for R410A air conditioner, choice of pipe type is up to you.

* The figures in the radial thickness column are based on the Japanese standards and provided only as a reference. Use pipes that meet the local standards.

Flare

Due to the relative higher operation pressure of R410A compared to R22, the flare connection should follow dimensions mentioned below so as to achieve enough the air-tightness.


Flare pipe	Pipe size	A (For R410A) (mm[in.])	Flare nut	Pipe size	B (For R410A) (mm[in.])
	ø6.35 [1/4"]	9.1		ø6.35 [1/4"]	17.0
	ø9.52 [3/8"]	13.2		ø9.52 [3/8"]	22.0
	ø12.70 [1/2"]	16.6		ø12.70 [1/2"]	26.0
	ø15.88 [5/8"]	19.7		ø15.88 [5/8"]	29.0
	ø19.05 [3/4"]	24.0		ø19.05 [3/4"]	36.0

Procedures for installing the branched pipes

Refer to the instructions that came with the branched pipe kit (separately sold) for details.


[1] Branches on the indoor-unit side

- ♦Restriction on installing the low-pressure pipe joint between outdoor/heat source units and Sub BC (for P-J type, P-JA type, P-KA type, and P-KB type)



-Regarding the low-pressure pipe joint between outdoor/heat source units and Sub BC, A and B must be installed horizontally, and C must be installed upward higher than the horizontal plane of A and B.

- ♦Restriction on installing the branch joint between Main BC and Sub BC on the high-pressure piping, low-pressure piping, and liquid piping.




-Regarding the branch joint between Main BC and Sub BC on the high-pressure/low-pressure/liquid piping, A and B must be installed horizontally, and C must be installed upward higher than the horizontal plane of A and B.

[2] Branches on the outdoor/heat source-unit side

Note. Refer to the figure below for the installation position of the twinning pipe.

The Twinning pipe must be installed horizontally using a level vessel to avoid unit damage.



- ♦Minimum length of the straight section of the pipe before the branched pipes

Always use the pipes supplied in the branched pipe kit, and make sure the straight section of the pipe immediately before it connects to the branched pipe is at least 500 mm (19-11/16 in.). Failure to do so may damage the unit.

12-2. Piping Design

12-2-1. IF 16 ports or less are in use, i.e., if only one BC controller is in use with no sub BC controller

"BC controller," "BC controller (Main)," and "BC controller (Sub)" that appear in this section refer to the P-J type, P-JA type, P-KA type, and P-KB type.

Note1. No Header usable on PURY system.

Note2. Indoor unit sized P100-P250/M100-M140 should be connected to BC controller via Y shape joint CMY-R160-J1 ; If the system consists only of PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units, connect to the BC controller via Y-shape joint CMY-R160-J1.

Note3. Indoor unit sized P100-P250/M100-M140 does NOT share BC controller ports with other Indoor units ;

Note4. As bents cause pressure loss on transportation of refrigerant, fewer bents design is better ;

Piping length needs to consider the actual length and equivalent length which bents are counted.

Equivalent piping length (m)=Actual piping length* $\frac{1}{2}$ x Number of bent.

Note5. Set DIP-SW 4-6 to ON of BC controller, in case of connected Indoor unit sized P100-P250/M100-M140 with 2 ports. If the system consists only of PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units, set the dipswitches SW4-1 and SW4-6 on the BC controller to ON.

Note6. It is also possible to connect Indoor unit sized P/M100-P/M140 with 1 port (set DIP-SW 4-1 and 4-6 to OFF). PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units can be connected to the system using a single port.

However, the cooling capacity decreases a little (For details, refer to the chapter OUTDOOR UNITS, 8-5. Correction by port counts of the BC controller).

Note7. Do not connect multiple indoor units to the same port when operating each of them in different mode (cooling, heating, stop, and thermo-off). In case of connecting multiple indoor units to the same port, connecting all indoor units to one remote controller and switching SW1-1 ON in the all connected indoor units (switch to thermostat built in the remote controller) are recommended.

Note8. Indoor capacity is described as its model size. For example, PEFY-P63VME-E, its capacity is P63.

Note9. Total down-stream indoor capacity is the summary of the model size of Indoors down-stream. For example, PEFY-P63VME-E + PEFY-P32VME-E: Total Indoor capacity = P63 + P32 = P95.

Note10. To enable the continuous heating mode, set SW4 (848) to ON.

Note11. To connect the BC controller to the main pipe, use the reducer (CMY-R301S-G, CMY-R302S-G, or CMY-R304S-G).

Note12. Install the pipes correctly referring to the section titled "Procedures for installing the branched pipes."




Fig. 12-2-1AA




Fig. 12-2-1A Piping scheme

Piping length limitation *9

Item	Piping in the figure	Max. length	Max. equivalent length
Total piping length (Total length of high pressure and liquid pipes)	A+B+C+D+E+a+b+c+d+e+f+g+i	*1	-
Farthest IU from OU	A+D+E+i	165 [541']	190 [623']
Distance between OU and BC	A	110 [360'] *1	110 [360'] *1
Farthest IU from BC controller	D+E+i	60 [197'] *2*3	60 [197'] *2*3
Height between OU and IU (OU above IU)	H	50 [164'] *6	-
Height between OU and IU (OU under IU)	H'	40 [131'] *7	-
Height between IU and BC	h1	15 [49'] (10 [32']) *4	-
Height between IU and IU	h2	30 [98'] (20 [65']) *5	-

OU: Outdoor Unit; IU: Indoor Unit; BC: BC controller

*1. Refer to the section 12-2-7.

*2. Details refer to Fig. 1.

*3. When the P200 or P250 model of indoor units are connected to the system, the maximum distance from the BC controller to the farthest indoor unit (indicated as "D + E + i" in the figure is 40 meters.)

*4. Distance of Indoor sized P200, P250 from BC must be less than 10 m, if any.

*5. Distance of Indoor sized P200, P250 from IU must be less than 20 m, if any.

*6. 90 m is available depending on the model and installation conditions.

For more detailed information, contact your local distributor.

*7. 60 m is available depending on the model and installation conditions.


For more detailed information, contact your local distributor.

*8. When the high pressure piping length is 65 m or less, use $\phi 22.2$ ($\phi 7/8$) pipe.

When the high pressure piping length exceeds 65 m, use $\phi 28.58$ ($\phi 1-1/8$) pipe for the part that exceeds 65 m.

*9. Total length of high-pressure pipes and liquid pipes

Fig. 1 Piping length and height between IU and BC controller



Bent equivalent length

Outdoor Model	m/bent (ft./bent)
P200YNW-A2/TR2/RU2	0.35 [1.15']
P250YNW-A2/TR2/RU2	0.42 [1.38']
P300YNW-A2/TR2/RU2	0.42 [1.38']
P350YNW-A2/TR2/RU2	0.47 [1.54']
P400YNW-A2/TR2/RU2	0.50 [1.64']
P450YNW-A2/TR2/RU2	0.50 [1.64']
P500YNW-A2/TR2/RU2	0.50 [1.64']
P550YNW-A2/TR2/RU2	0.50 [1.64']

Piping "A" size selection rule

Outdoor Model	Pipe(High pressure)	Pipe(Low pressure)
P200YNW-A2/TR2/RU2	$\phi 15.88$ [5/8"]	$\phi 19.05$ [3/4"]
P250YNW-A2/TR2/RU2	$\phi 19.05$ [3/4"]	$\phi 22.20$ [7/8"]
P300YNW-A2/TR2/RU2	$\phi 19.05$ [3/4"]	$\phi 22.20$ [7/8"]
P350YNW-A2/TR2/RU2	$\phi 19.05$ [3/4"]	$\phi 28.58$ [1-1/8"]
P400YNW-A2/TR2/RU2	$\phi 22.20$ [7/8"]	$\phi 28.58$ [1-1/8"]
P450YNW-A2/TR2/RU2	$\phi 22.20$ [7/8"]	$\phi 28.58$ [1-1/8"]
P500YNW-A2/TR2/RU2	$\phi 22.20$ [7/8"]	$\phi 28.58$ [1-1/8"]
P550YNW-A2/TR2/RU2	$\phi 22.20$ [7/8"] *8	$\phi 28.58$ [1-1/8"]

Piping "B", "C", "D", "E" size selection rule

Total down-stream Indoor capacity	Pipe(Liquid)	Pipe(Gas)
P/M140 or less	$\phi 9.52$ [3/8"]	$\phi 15.88$ [5/8"]
P/M141-P/M200	$\phi 9.52$ [3/8"]	$\phi 19.05$ [3/4"]
P/M201-P/M250	$\phi 9.52$ [3/8"]	$\phi 22.20$ [7/8"]

Piping "a", "b", "c", "d", "e", "f", "g", "i" size selection rule

Indoor Unit size	Pipe(Liquid)	Pipe(Gas)
P10 to P50, M20 to M50, GUF-50RD(H)	$\phi 6.35$ [1/4"]	$\phi 12.70$ [1/2"]
P63 to P140, M63 to M140, GUF-100RD(H)	$\phi 9.52$ [3/8"]	$\phi 15.88$ [5/8"]
P200	$\phi 9.52$ [3/8"]	$\phi 19.05$ [3/4"]
P250	$\phi 9.52$ [3/8"]	$\phi 22.20$ [7/8"]

Selection criteria for joints_A

Total down-stream Indoor capacity	Joint
-P/M200	CMY-Y102SS-G2
P/M201-P/M250	CMY-Y102LS-G2

12-2-2. IF more than 16 ports are in use, or if there is more than one BC controller in use for one outdoor unit

"BC controller," "BC controller (Main)," and "BC controller (Sub)" that appear in this section refer to the P-J type, P-JA type, P-KA type, and P-KB type.

Note1. No Header usable on PURY system.

Note2. Indoor unit sized P100-P250/M100-M140 should be connected to BC controller via Y shape joint CMY-R160-J1 ; If the system consists only of PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units, connect to the BC controller via Y-shape joint CMY-R160-J1.

Note3. Indoor unit sized P100-P250/M100-M140 does NOT share BC controller ports with other Indoor units ;

Note4. As bents cause pressure loss on transportation of refrigerant, fewer bents design is better ; Piping length needs to consider the actual length and equivalent length which bents are counted. Equivalent piping length (m)=Actual piping length+"M" x Number of bent.

Note5. Set DIP-SW 4-6 to ON of BC controller, in case of connected Indoor unit sized P100-P250/M100-M140 with 2 ports. If the system consists only of PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units, set the dipswitches SW4-1 and SW4-6 on the BC controller to ON.

Note6. It is also possible to connect Indoor unit sized P/M100-P/M140 with 1 port (set DIP-SW 4-1 and 4-6 to OFF). PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units can be connected to the system using a single port. However, the cooling capacity decreases a little (For details, refer to the chapter OUTDOOR UNITS, 8-5. Correction by port counts of the BC controller).

Note7. Do not connect multiple indoor units to the same port when operating each of them in different mode (cooling, heating, stop, and thermo-off). In case of connecting multiple indoor units to the same port, connecting all indoor units to one remote controller and switching SW1-1 ON in the all connected indoor units (switch to thermostat built in the remote controller) are recommended.

Note8. The maximum total capacity of indoor units that can be connected to each sub BC controller CMB-M*V-KB1 is 350.

Note9. Indoor capacity is described as its model size. For example, PEFY-P63VML-E, its capacity is P63.

Note10. Total down-stream Indoor capacity is the summary of the model size of Indoors down-stream. For example, PEFY-P63VML-E + PEFY-P32VML-E : Total Indoor capacity = P63 + P32 = P95.

Note11. To enable the continuous heating mode, set SW4 (848) to ON.

Note12. To connect the BC controller to the main pipe, use the reducer (CMY-R301S-G, CMY-R302S-G, or CMY-R304S-G).

Note13. To connect the sub BC controller to the main BC controller, use the reducer (CMY-R303S-G, CMY-R305S-G, or CMY-R306S-G).

Note14. Install the pipes correctly referring to the section titled "Procedures for installing the branched pipes."





Fig. 12-2-2AA



OU: Outdoor unit, IU: Indoor unit

Piping length limitation *11

Item	Piping in the figure	Max. length	Max. equivalent length
Total piping length (Total length of high pressure and liquid pipes)	A+B+C+D+E+F+G+J+K+a+b+c+d+e+f+g+i+j+k+m+n	*1	-
Farthest IU from OU	A+F+G+J+K+n	165 [541']	190 [623']
Distance between OU and BC	A	110 [360'] *1	110 [360'] *1
Farthest IU from BC controller	D+E+i	60 [197'] *2*3	60 [197'] *2*3
Farthest IU from BC controller via Sub BC controller	F+G+J+K+n	90 [295'] *9	90 [295'] *9
Height between OU and IU (OU above IU)	H	50 [164'] *7	-
Height between OU and IU (OU under IU)	H'	40 [131'] *8	-
Height between IU and BC	h1	15 [49'] (10 [32']) *4	-
Height between IU and IU	h2	30 [98'] (20 [65']) *5	-
Height between BC(Main or Sub) and BC(Sub)	h3	15 [49'] (10 [32']) *6	-

OU: Outdoor Unit; IU: Indoor Unit; BC: BC controller

*1. Refer to the section 12-2-7.

*2. Details refer to Fig. 2.

*3. When the P200 or P250 model of indoor units are connected to the system, the maximum distance from the BC controller to the farthest indoor unit (indicated as "D + E + i" in the figure is 40 meters.)

*4. Distance of Indoor sized P200, P250 from BC must be less than 10 m, if any.

*5. Distance of Indoor sized P200, P250 from IU must be less than 20 m, if any.

*6. When using 2 Sub BC controllers, max. height "h3" should be considered.

*7. 90 m is available depending on the model and installation conditions. For more detailed information, contact your local distributor.

*8. 60 m is available depending on the model and installation conditions. For more detailed information, contact your local distributor.

*9. When the piping length or the vertical separation exceeds the limit specified in Fig. 2, connect a sub BC to the system.

The restriction for a system with a sub BC connection is shown in Fig. 3.

When a given system configuration falls within the shaded area in Fig. 3, increase the size of the high-pressure pipe and the liquid pipe between the main

BC and sub BC by one size. When using P/M32, P/M40, P/M50, P/M100, or P/M125 model of indoor units, increase the size of the liquid branch pipe between the sub BC and indoor unit by one size.

When using indoor models P/M140 or larger, the restrictions shown in Fig. 2 cannot be exceeded.

*10. When the high pressure piping length is 65 m or less, use ø22.2 (ø7/8) pipe.

When the high pressure piping length exceeds 65 m, use ø22.2 (ø7/8) pipe until 65 m, use ø28.58 (ø1-1/8) pipe for the part that exceeds 65 m.

*11. Total length of high-pressure pipes and liquid pipes

Bent equivalent length

Outdoor Model	m/bent [ft./bent]
P200YNW-A2/TR2/RU2	0.35 [1.15']
P250YNW-A2/TR2/RU2	0.42 [1.38']
P300YNW-A2/TR2/RU2	0.42 [1.38']
P350YNW-A2/TR2/RU2	0.47 [1.54']
P400YNW-A2/TR2/RU2	0.50 [1.64']
P450YNW-A2/TR2/RU2	0.50 [1.64']
P500YNW-A2/TR2/RU2	0.50 [1.64']
P550YNW-A2/TR2/RU2	0.50 [1.64']

Piping length and height between IU and BC controller




Fig. 2





Fig. 3



*9. When the piping length or the vertical separation exceeds the limit specified in Fig. 2, connect a sub BC to the system.

The restriction for a system with a sub BC connection is shown in Fig. 3.

When a given system configuration falls within the shaded area in Fig. 3, increase the size of the high-pressure pipe and the liquid pipe between the main BC and sub BC by one size.

When using P/M32, P/M40, P/M50, P/M100, or P/M125 model of indoor units, increase the size of the liquid branch pipe between the sub BC and indoor unit by one size.

When using indoor models P/M140 or larger, the restrictions shown in Fig. 2 cannot be exceeded.

Piping "A" size selection rule

(mm [in.])

Outdoor Model	Pipe(High pressure)	Pipe(Low pressure)
P200YNW-A2/TR2/RU2	ø15.88 [5/8"]	ø19.05 [3/4"]
P250YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø22.20 [7/8"]
P300YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø22.20 [7/8"]
P350YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø28.58 [1-1/8"]
P400YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P450YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P500YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P550YNW-A2/TR2/RU2	ø22.20 [7/8"] *10	ø28.58 [1-1/8"]

Selection criteria for joints_A

Total down-stream Indoor capacity	Joint
-P/M200	CMY-Y102SS-G2
P/M201-P/M250	CMY-Y102LS-G2

Selection criteria for joints_B

Outdoor Model	Joint
P200-P550YNW-A2/TR2/RU2	CMY-R101S-G

Selection criteria for joints_C

Total down-stream Indoor capacity	Joint
-P/M350	CMY-R201S-G
P/M351-P/M550	CMY-R202S-G

Piping "B", "C", "D", "E" size selection rule

(mm [in.])

Total down-stream Indoor capacity	Pipe(Liquid)	Pipe(Gas)
P/M140 or less	ø9.52 [3/8"]	ø15.88 [5/8"]
P/M141-P/M200	ø9.52 [3/8"]	ø19.05 [3/4"]
P/M201-P/M250	ø9.52 [3/8"]	ø22.20 [7/8"]

Piping "a", "b", "c", "d", "e", "f", "g", "i", "j", "k", "m", "n" size selection rule (mm [in.])

Indoor Unit size	Pipe(Liquid)	Pipe(Gas)
P10 to P50, M20 to M50, GUF-50RD(H)	ø6.35 [1/4"]	ø12.70 [1/2"]
P63 to P140, M63 to M140, GUF-100RD(H)	ø9.52 [3/8"]	ø15.88 [5/8"]
P200	ø9.52 [3/8"]	ø19.05 [3/4"]
P250	ø9.52 [3/8"]	ø22.20 [7/8"]

Piping "F", "G", "J", "K" size selection rule

(mm [in.])

Total down-stream Indoor capacity	Pipe(Liquid)	Pipe(HP Gas)	Pipe(LP Gas)
P/M200 or less	ø9.52 [3/8"]	ø15.88 [5/8"]	ø19.05 [3/4"]
P/M201 to P/M300	ø9.52 [3/8"]	ø19.05 [3/4"]	ø22.20 [7/8"]
P/M301 to P/M350	ø12.70 [1/2"]	ø19.05 [3/4"]	ø28.58 [1-1/8"]
P/M351 to P/M400	ø12.70 [1/2"]	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P/M401 to P/M600	ø15.88 [5/8"]	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P/M601 to P/M650	ø15.88 [5/8"]	ø28.58 [1-1/8"]	ø28.58 [1-1/8"]
P/M651 to P/M800	ø19.05 [3/4"]	ø28.58 [1-1/8"]	ø34.93 [1-3/8"]
P/M801 to P/M1000	ø19.05 [3/4"]	ø28.58 [1-1/8"]	ø41.28 [1-5/8"]
P/M1001 or above	ø19.05 [3/4"]	ø34.93 [1-3/8"]	ø41.28 [1-5/8"]

HP: High pressure, LP: Low pressure

12-2-3. IF more than 16 ports are in use, or if there is more than one BC controller in use for two outdoor units

"BC controller," "BC controller (Main)," and "BC controller (Sub)" that appear in this section refer to the P-J type, P-JA type, P-KA type, and P-KB type.

Note1. No Header usable on PURY system.

Note2. Indoor unit sized P100-P250/M100-M140 should be connected to BC controller via Y shape joint CMY-R160-J1 ; If the system consists only of PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units, connect to the BC controller via Y-shape joint CMY-R160-J1.

Note3. Indoor unit sized P100-P250/M100-M140 does NOT share BC controller ports with other Indoor units ;

Note4. As bents cause pressure loss on transportation of refrigerant, fewer bents design is better ; Piping length needs to consider the actual length and equivalent length which bents are counted. Equivalent piping length (m)=Actual piping length* Σ Number of bent.

Note5. Set DIP-SW 4-6 to ON of BC controller, in case of connected Indoor unit sized P100-P250/M100-M140 with 2 ports. If the system consists only of PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units, set the dipswitches SW4-1 and SW4-6 on the BC controller to ON.

Note6. It is also possible to connect Indoor unit sized P/M100-P/M140 with 1 port (set DIP-SW 4-1 and 4-6 to OFF). PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units can be connected to the system using a single port. However, the cooling capacity decreases a little (For details, refer to the chapter "Correction by port counts of the BC controller").

Note7. Do not connect multiple indoor units to the same port when operating each of them in different mode (cooling, heating, stop, and thermo-off). In case of connecting multiple indoor units to the same port, connecting all indoor units to one remote controller and switching SW1-1 ON in the all connected indoor units (switch to thermostat built in the remote controller) are recommended.

Note8. The maximum total capacity of indoor units that can be connected to each sub BC controller CMB-M-V-KB1 is 350.

Note9. Indoor capacity is described as its model size. For example, PEFY-P63VML-E, its capacity is P63.

Note10. Total down-stream Indoor capacity is the summary of the model size of Indoors down-stream. For example, PEFY-P63VML-E + PEFY-P32VML-E : Total Indoor capacity = P63 + P32 = P95.

Note11. To enable the continuous heating mode, set SW4 (848) to ON.

Note12. To connect the BC controller to the main pipe, use the reducer (CMY-R301S-G, CMY-R302S-G, or CMY-R304S-G).

Note13. To connect the sub BC controller to the main BC controller, use the reducer (CMY-R303S-G, CMY-R305S-G, or CMY-R306S-G).

Note14. Install the pipes correctly referring to the section titled "Procedures for installing the branched pipes."





Fig. 12-2-3AA



OU: Outdoor unit, IU: Indoor unit

Fig. 12-2-3A Piping scheme

Piping length limitation *11

Item	Piping in the figure	Max. length	Max. equivalent length
Total piping length (Total length of high pressure and liquid pipes)	$L+M+A+B+C+D+E+F+G+J+K+A+b+c+d+e+f+g+i+j+k+m+n$	*1	-
Farthest IU from OU	$L(M)+A+F+G+J+K+n$	165 [541']	190 [623']
Distance between OU and BC	$L(M)+A$	110 [360'] *1	110 [360'] *1
Farthest IU from BC controller	$D+E+i$	60 [197'] *2 *3	60 [197'] *2*3
Farthest IU from BC controller via Sub BC controller	$F+G+J+K+n$	90 [295'] *9	90 [295'] *9
Height between OU and IU (OU above IU)	H	50 [164'] *7	-
Height between OU and IU (OU under IU)	H'	40 [131'] *8	-
Height between IU and BC	h1	15 [49'] (10 [32']) *4	-
Height between IU and IU	h2	30 [98'] (20 [65']) *5	-
Height between BC(Main or Sub) and BC(Sub)	h3	15 [49'] (10 [32']) *6	-
Distance between Main unit and Sub unit	L+M	5 [16']	-
Height between Main unit and Sub unit	h4	0.1 [0.3']	-

OU: Outdoor Unit; IU: Indoor Unit; BC: BC controller

*1. Refer to the section 12-2-7.

*2. Details refer to Fig. 2.

*3. When the P200 or P250 model of indoor units are connected to the system, the maximum distance from the BC controller to the farthest indoor unit (indicated as "D + E + i" in the figure is 40 meters.)

*4. Distance of Indoor sized P200, P250 from BC must be less than 10 m, if any.

*5. Distance of Indoor sized P200, P250 from IU must be less than 20 m, if any.

*6. When using 2 Sub BC controllers, max. height "h3" should be considered.

*7. 90 m is available depending on the model and installation conditions. For more detailed information, contact your local distributor.

*8. 60 m is available depending on the model and installation conditions. For more detailed information, contact your local distributor.

*9. When the piping length or the vertical separation exceeds the limit specified in Fig. 2, connect a sub BC to the system.

The restriction for a system with a sub BC connection is shown in Fig. 3.

When a given system configuration falls within the shaded area in Fig. 3, increase the size of the high-pressure pipe and the liquid pipe between the main BC and sub BC by one size.

When using P/M32, P/M40, P/M50, P/M100, or P/M125 model of indoor units, increase the size of the liquid branch pipe between the sub BC and indoor unit by one size.

When using indoor models P/M140 or larger, the restrictions shown in Fig. 2 cannot be exceeded.

*10. When the high pressure piping length is 65 m or less, use ø22.2 (ø7/8) pipe.

When the high pressure piping length exceeds 65 m, use ø22.2 (ø7/8) pipe until 65 m, use ø28.58 (ø1-1/8) pipe for the part that exceeds 65 m.

*11. Total length of high-pressure pipes and liquid pipes

Bent equivalent length

Outdoor Model	m/bent [ft./bent]
P400YSNW-A2/TR2/RU2	0.50 [1.64']
P450YSNW-A2/TR2/RU2	0.50 [1.64']
P500YSNW-A2/TR2/RU2	0.50 [1.64']
P550YSNW-A2/TR2/RU2	0.50 [1.64']
P600YSNW-A2/TR2/RU2	0.50 [1.64']
P650YSNW-A2/TR2/RU2	0.50 [1.64']
P700YSNW-A2/TR2/RU2	0.70 [2.29']
P750YSNW-A2/TR2/RU2	0.70 [2.29']
P800YSNW-A2/TR2/RU2	0.70 [2.29']
P850YSNW-A2/TR2/RU2	0.80 [2.62']
P900YSNW-A2/TR2/RU2	0.80 [2.62']
P950YSNW-A2/TR2/RU2	0.80 [2.62']
P1000YSNW-A2/TR2/RU2	0.80 [2.62']
P1050YSNW-A2/TR2/RU2	0.80 [2.62']
P1100YSNW-A2/TR2/RU2	0.80 [2.62']

Piping length and height between IU and BC controller




Fig. 2





Fig. 3



*9. When the piping length or the vertical separation exceeds the limit specified in Fig. 2, connect a sub BC to the system.

The restriction for a system with a sub BC connection is shown in Fig. 3.

When a given system configuration falls within the shaded area in Fig. 3, increase the size of the high-pressure pipe and the liquid pipe between the main BC and sub BC by one size.

When using P/M32, P/M40, P/M50, P/M100, or P/M125 model of indoor units, increase the size of the liquid branch pipe between the sub BC and indoor unit by one size.

When using indoor models P/M140 or larger, the restrictions shown in Fig. 2 cannot be exceeded.

Piping "A" size selection rule

(mm [in.])

Outdoor Model	Pipe(High pressure)	Pipe(Low pressure)
P400YSNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P450YSNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P500YSNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P550YSNW-A2/TR2/RU2	ø22.20 [7/8"] *10	ø28.58 [1-1/8"]
P600YSNW-A2/TR2/RU2	ø22.20 [7/8"] *10	ø28.58 [1-1/8"]
P650YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø28.58 [1-1/8"]
P700YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø34.93 [1-3/8"]
P750YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø34.93 [1-3/8"]
P800YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø34.93 [1-3/8"]
P850YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø41.28 [1-5/8"]
P900YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø41.28 [1-5/8"]
P950YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø41.28 [1-5/8"]
P1000YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø41.28 [1-5/8"]
P1050YSNW-A2/TR2/RU2	ø34.93 [1-3/8"]	ø41.28 [1-5/8"]
P1100YSNW-A2/TR2/RU2	ø34.93 [1-3/8"]	ø41.28 [1-5/8"]

Piping "L", "M" size selection rule

(mm [in.])

Outdoor Model	Pipe(High pressure)	Pipe(Low pressure)
P200YNW-A2/TR2/RU2	ø15.88 [5/8"]	ø19.05 [3/4"]
P250YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø22.20 [7/8"]
P300YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø22.20 [7/8"]
P350YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø28.58 [1-1/8"]
P400YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P450YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P500YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P550YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]

Piping "B", "C", "D", "E" size selection rule

(mm [in.])

Total down-stream Indoor capacity	Pipe(Liquid)	Pipe(Gas)
P/M140 or less	ø9.52 [3/8"]	ø15.88 [5/8"]
P/M141-P/M200	ø9.52 [3/8"]	ø19.05 [3/4"]
P/M201-P/M250	ø9.52 [3/8"]	ø22.20 [7/8"]

Selection criteria for joints_A

Total down-stream Indoor capacity	Joint
-P/M200	CMY-Y102SS-G2
P/M201-P/M250	CMY-Y102LS-G2

Piping "a", "b", "c", "d", "e", "f", "g", "i", "j", "k", "m", "n" size selection rule (mm [in.])

Indoor Unit size	Pipe(Liquid)	Pipe(Gas)
P10 to P50, M20 to M50, GUF-50RD(H)	ø6.35 [1/4"]	ø12.70 [1/2"]
P63 to P140, M63 to M140, GUF-100RD(H)	ø9.52 [3/8"]	ø15.88 [5/8"]
P200	ø9.52 [3/8"]	ø19.05 [3/4"]
P250	ø9.52 [3/8"]	ø22.20 [7/8"]

Selection criteria for joints_B

Outdoor Model	Joint
P400-P650YSNW-A2/TR2/RU2	CMY-R101S-G
P700-P1100YSNW-A2/TR2/RU2	CMY-R102S-G

Piping "F", "G", "J", "K" size selection rule

(mm [in.])

Total down-stream Indoor capacity	Pipe(Liquid)	Pipe(HP Gas)	Pipe(LP Gas)
P/M200 or less	ø9.52 [3/8"]	ø15.88 [5/8"]	ø19.05 [3/4"]
P/M201 to P/M300	ø9.52 [3/8"]	ø19.05 [3/4"]	ø22.20 [7/8"]
P/M301 to P/M350	ø12.70 [1/2"]	ø19.05 [3/4"]	ø28.58 [1-1/8"]
P/M351 to P/M400	ø12.70 [1/2"]	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P/M401 to P/M600	ø15.88 [5/8"]	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P/M601 to P/M650	ø15.88 [5/8"]	ø28.58 [1-1/8"]	ø28.58 [1-1/8"]
P/M651 to P/M800	ø19.05 [3/4"]	ø28.58 [1-1/8"]	ø34.93 [1-3/8"]
P/M801 to P/M1000	ø19.05 [3/4"]	ø28.58 [1-1/8"]	ø41.28 [1-5/8"]
P/M1001 or above	ø19.05 [3/4"]	ø34.93 [1-3/8"]	ø41.28 [1-5/8"]

Selection criteria for joints_C

Total down-stream Indoor capacity	Joint
-P/M350	CMY-R201S-G
P/M351-P/M600	CMY-R202S-G
P/M601-P/M650	CMY-R203S-G
P/M651-P/M1000	CMY-R204S-G
P/M1001-	CMY-R205S-G

HP: High pressure, LP: Low pressure

12-2-4. IF 16 ports or less are in use, i.e., if only one BC controller is in use with no sub BC controller

"BC controller," "BC controller (Main)," and "BC controller (Sub)" that appear in this section refer to the M-J1 type, M-JA1 type, P-KA1 type, and M-KB1 type.

Note1. No Header usable on PURY system.

Note2. Indoor unit sized P100-P250/M100-M140 should be connected to BC controller via Y shape joint CMY-R160-J1 ; If the system consists only of PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units, connect to the BC controller via Y-shape joint CMY-R160-J1.

Note3. Indoor unit sized P100-P250/M100-M140 does NOT share BC controller ports with other Indoor units ;

Note4. As bends cause pressure loss on transportation of refrigerant, fewer bends design is better ;

Piping length needs to consider the actual length and equivalent length which bends are counted.

Equivalent piping length (m)=Actual piping length+"M" x Number of bent.

Note5. Set DIP-SW 4-6 to ON of BC controller, in case of connected Indoor unit sized P100-P250/M100-M140 with 2 ports. If the system consists only of PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units, set the dipswitches SW4-1 and SW4-6 on the BC controller to ON.

Note6. It is also possible to connect Indoor unit sized P/M100-P/M140 with 1 port (set DIP-SW 4-1 and 4-6 to OFF). PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units can be connected to the system using a single port. However, the cooling capacity decreases a little (For details, refer to the chapter OUTDOOR UNITS, 8-5. Correction by port counts of the BC controller).

Note7. Do not connect multiple indoor units to the same port when operating each of them in different mode (cooling, heating, stop, and thermo-off). In case of connecting multiple indoor units to the same port, connecting all indoor units to one remote controller and switching SW1-1 ON in the all connected indoor units (switch to thermostat built in the remote controller) are recommended.

Note8. Indoor capacity is described as its model size. For example, PEFY-P63VML-E, its capacity is P63.

Note9. Total down-stream Indoor capacity is the summary of the model size of Indoors down-stream. For example, PEFY-P63VML-E + PEFY-P32VML-E: Total Indoor capacity = P63 + P32 = P95.

Note10. To enable the continuous heating mode, set SW4 (848) to ON.

Note11. To connect the BC controller to the main pipe, use the reducer (CMY-R301S-G, CMY-R302S-G1, or CMY-R304S-G1).

Note12. Install the pipes correctly referring to the section titled "Procedures for installing the branched pipes."




Fig. 12-2-4AA




Fig. 12-2-4A Piping scheme

Piping length limitation *9

Item	Piping in the figure	Max. length	Max. equivalent length
Total piping length (Total length of high pressure and liquid pipes)	A+B+C+D+E+a+b+c+d+e+f+g+i	*1	-
Farthest IU from OU	A+D+E+i	165 [541']	190 [623']
Distance between OU and BC	A	110 [360'] *1	110 [360'] *1
Farthest IU from BC controller	D+E+i	60 [197'] *2*3	60 [197'] *2*3
Height between OU and IU (OU above IU)	H	50 [164'] *6	-
Height between OU and IU (OU under IU)	H'	40 [131'] *7	-
Height between IU and BC	h1	15 [49'] (10 [32']) *4	-
Height between IU and IU	h2	30 [98'] (20 [65']) *5	-

OU: Outdoor Unit; IU: Indoor Unit; BC: BC controller

*1. Refer to the section 12-2-7.

*2. Details refer to Fig. 1.

*3. When the P200 or P250 model of indoor units are connected to the system, the maximum distance from the BC controller to the farthest indoor unit (indicated as "D + E + i" in the figure is 40 meters.)

*4. Distance of Indoor sized P200, P250 from BC must be less than 10 m, if any.

*5. Distance of Indoor sized P200, P250 from IU must be less than 20 m, if any.

*6. 90 m is available depending on the model and installation conditions.

For more detailed information, contact your local distributor.

*7. 60 m is available depending on the model and installation conditions.

For more detailed information, contact your local distributor.


*8. When the high pressure piping length is 65 m or less, use ø22.2 (ø7/8) pipe.

When the high pressure piping length exceeds 65 m, use ø22.2 (ø7/8) pipe

until 65 m, use ø28.58 (ø1-1/8) pipe for the part that exceeds 65 m.

*9. Total length of high-pressure pipes and liquid pipes

Fig. 1 Piping length and height between IU and BC controller



Bent equivalent length

Outdoor Model	m/bent [ft./bent]
P200YNW-A2/TR2/RU2	0.35 [1.15']
P250YNW-A2/TR2/RU2	0.42 [1.38']
P300YNW-A2/TR2/RU2	0.42 [1.38']
P350YNW-A2/TR2/RU2	0.47 [1.54']
P400YNW-A2/TR2/RU2	0.50 [1.64']
P450YNW-A2/TR2/RU2	0.50 [1.64']
P500YNW-A2/TR2/RU2	0.50 [1.64']
P550YNW-A2/TR2/RU2	0.50 [1.64']

Piping "A" size selection rule

Outdoor Model	Pipe(High pressure)	Pipe(Low pressure)
P200YNW-A2/TR2/RU2	ø15.88 [5/8"]	ø19.05 [3/4"]
P250YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø22.20 [7/8"]
P300YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø22.20 [7/8"]
P350YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø28.58 [1-1/8"]
P400YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P450YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P500YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P550YNW-A2/TR2/RU2	ø22.20 [7/8"] *8	ø28.58 [1-1/8"]

Piping "B", "C", "D", "E" size selection rule

Total down-stream Indoor capacity	Pipe(Liquid)	Pipe(Gas)
P/M140 or less	ø9.52 [3/8"]	ø15.88 [5/8"]
P/M141-P/M200	ø9.52 [3/8"]	ø19.05 [3/4"]
P/M201-P/M250	ø9.52 [3/8"]	ø22.20 [7/8"]

Piping "a", "b", "c", "d", "e", "f", "g", "i" size selection rule

Indoor Unit size	Pipe(Liquid)	Pipe(Gas)
P10 to P50, M20 to M50, GUF-50RD(H)	ø6.35 [1/4"]	ø12.70 [1/2"]
P63 to P140, M63 to M140, GUF-100RD(H)	ø9.52 [3/8"]	ø15.88 [5/8"]
P200	ø9.52 [3/8"]	ø19.05 [3/4"]
P250	ø9.52 [3/8"]	ø22.20 [7/8"]

Selection criteria for joints_A

Total down-stream Indoor capacity	Joint
-P/M200	CMY-Y102SS-G2
P/M201-P/M250	CMY-Y102LS-G2

12-2-5. IF more than 16 ports are in use, or if there is more than one BC controller in use for one outdoor unit

"BC controller," "BC controller (Main)," and "BC controller (Sub)" that appear in this section refer to the M-J1 type, M-JA1 type, P-KA1 type, and M-KB1 type.

Note1. No Header usable on PURY system.

Note2. Indoor unit sized P100-P250/M100-M140 should be connected to BC controller via Y shape joint CMY-R160-J1 ; If the system consists only of PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units, connect to the BC controller via Y-shape joint CMY-R160-J1.

Note3. Indoor unit sized P100-P250/M100-M140 does NOT share BC controller ports with other Indoor units ;

Note4. As bents cause pressure loss on transportation of refrigerant, fewer bents design is better ; Piping length needs to consider the actual length and equivalent length which bents are counted.
Equivalent piping length (m)=Actual piping length+"M" x Number of bent.

Note5. Set DIP-SW 4-6 to ON of BC controller, in case of connected Indoor unit sized P100-P250/M100-M140 with 2 ports. If the system consists only of PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units, set the dipswitches SW4-1 and SW4-6 on the BC controller to ON.

Note6. It is also possible to connect Indoor unit sized P/M100-P/M140 with 1 port (set DIP-SW 4-1 and 4-6 to OFF). PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units can be connected to the system using a single port. However, the cooling capacity decreases a little (For details, refer to the chapter OUTDOOR UNITS, 8-5. Correction by port counts of the BC controller).

Note7. Do not connect multiple indoor units to the same port when operating each of them in different mode (cooling, heating, stop, and thermo-off). In case of connecting multiple indoor units to the same port, connecting all indoor units to one remote controller and switching SW1-1 ON in the all connected indoor units (switch to thermostat built in the remote controller) are recommended.

Note8. The maximum total capacity of indoor units that can be connected to each sub BC controller CMB-M-V-KB1 is 350.

Note9. Indoor capacity is described as its model size. For example, PEFY-P63VML-E, its capacity is P63.

Note10. Total down-stream Indoor capacity is the summary of the model size of Indoors down-stream. For example,
PEFY-P63VML-E + PEFY-P32VML-E : Total Indoor capacity = P63 + P32 = P95.

Note11. To enable the continuous heating mode, set SW4 (848) to ON.

Note12. To connect the BC controller to the main pipe, use the reducer (CMY-R301S-G, CMY-R302S-G1, or CMY-R304S-G1).

Note13. To connect the sub BC controller to the main BC controller, use the reducer (CMY-R303S-G1, CMY-R305S-G1, or CMY-R306S-G).

Note14. Install the pipes correctly referring to the section titled "Procedures for installing the branched pipes."





Fig. 12-2-5AA



OU: Outdoor unit, IU: Indoor unit

Fig. 12-2-5A Piping scheme

Piping length limitation *11

Item	Piping in the figure	Max. length	Max. equivalent length
Total piping length (Total length of high pressure and liquid pipes)	A+B+C+D+E+F+G+J+K+a+b+c+d+e+f+g+i+j+k+m+n	*1	-
Farthest IU from OU	A+F+G+J+K+n	165 [541']	190 [623']
Distance between OU and BC	A	110 [360'] *1	110 [360'] *1
Farthest IU from BC controller	D+E+i	60 [197'] *2*3	60 [197'] *2*3
Farthest IU from BC controller via Sub BC controller	F+G+J+K+n	90 [295'] *9	90 [295'] *9
Height between OU and IU (OU above IU)	H	50 [164'] *7	-
Height between OU and IU (OU under IU)	H'	40 [131'] *8	-
Height between IU and BC	h1	15 [49'] (10 [32']) *4	-
Height between IU and IU	h2	30 [98'] (20 [65']) *5	-
Height between BC(Main or Sub) and BC(Sub)	h3	15 [49'] (10 [32']) *6	-

OU: Outdoor Unit; IU: Indoor Unit; BC: BC controller

*1. Refer to the section 12-2-7.

*2. Details refer to Fig. 2.

*3. When the P200 or P250 model of indoor units are connected to the system, the maximum distance from the BC controller to the farthest indoor unit (indicated as "D + E + i" in the figure is 40 meters.)

*4. Distance of Indoor sized P200, P250 from BC must be less than 10 m, if any.

*5. Distance of Indoor sized P200, P250 from IU must be less than 20 m, if any.

*6. When using 2 Sub BC controllers, max. height "h3" should be considered.

*7. 90 m is available depending on the model and installation conditions. For more detailed information, contact your local distributor.

*8. 60 m is available depending on the model and installation conditions. For more detailed information, contact your local distributor.

*9. When the piping length or the vertical separation exceeds the limit specified in Fig. 2, connect a sub BC to the system.

The restriction for a system with a sub BC connection is shown in Fig. 3. When a given system configuration falls within the shaded area in Fig. 3, increase the size of the high-pressure pipe and the liquid pipe between the main BC and sub BC by one size. When using P/M32, P/M40, P/M50, P/M100, or P/M125 model of indoor units, increase the size of the liquid branch pipe between the sub BC and indoor unit by one size.

When using indoor models P/M140 or larger, the restrictions shown in Fig. 2 cannot be exceeded.

*10. When the high pressure piping length is 65 m or less, use ø22.2 (ø7/8) pipe.

When the high pressure piping length exceeds 65 m, use ø22.2 (ø7/8) pipe until 65 m, use ø28.58 (ø1-1/8) pipe for the part that exceeds 65 m.

*11. Total length of high-pressure pipes and liquid pipes

Bent equivalent length

Outdoor Model	m/bent [ft./bent]
P200YNW-A2/TR2/RU2	0.35 [1.15']
P250YNW-A2/TR2/RU2	0.42 [1.38']
P300YNW-A2/TR2/RU2	0.42 [1.38']
P350YNW-A2/TR2/RU2	0.47 [1.54']
P400YNW-A2/TR2/RU2	0.50 [1.64']
P450YNW-A2/TR2/RU2	0.50 [1.64']
P500YNW-A2/TR2/RU2	0.50 [1.64']
P550YNW-A2/TR2/RU2	0.50 [1.64']

Piping length and height between IU and BC controller




Fig. 2





Fig. 3



*9. When the piping length or the vertical separation exceeds the limit specified in Fig. 2, connect a sub BC to the system.
The restriction for a system with a sub BC connection is shown in Fig. 3.
When a given system configuration falls within the shaded area in Fig. 3, increase the size of the high-pressure pipe and the liquid pipe between the main BC and sub BC by one size.
When using P/M32, P/M40, P/M50, P/M100, or P/M125 model of indoor units, increase the size of the liquid branch pipe between the sub BC and indoor unit by one size.
When using indoor models P/M140 or larger, the restrictions shown in Fig. 2 cannot be exceeded.

Piping "A" size selection rule

(mm [in.])

Outdoor Model	Pipe(High pressure)	Pipe(Low pressure)
P200YNW-A2/TR2/RU2	ø15.88 [5/8"]	ø19.05 [3/4"]
P250YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø22.20 [7/8"]
P300YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø22.20 [7/8"]
P350YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø28.58 [1-1/8"]
P400YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P450YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P500YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P550YNW-A2/TR2/RU2	ø22.20 [7/8"] *10	ø28.58 [1-1/8"]

Selection criteria for joints_A

Total down-stream Indoor capacity	Joint
-P/M200	CMY-Y102SS-G2
P/M201-P/M250	CMY-Y102LS-G2

Selection criteria for joints_B

Total down-stream Indoor capacity	Joint
-P/M350	CMY-R201S-G
P/M351-P/M550	CMY-R202S-G

Piping "B", "C", "D", "E" size selection rule

(mm [in.])

Total down-stream Indoor capacity	Pipe(Liquid)	Pipe(Gas)
P/M140 or less	ø9.52 [3/8"]	ø15.88 [5/8"]
P/M141-P/M200	ø9.52 [3/8"]	ø19.05 [3/4"]
P/M201-P/M250	ø9.52 [3/8"]	ø22.20 [7/8"]

Piping "a", "b", "c", "d", "e", "f", "g", "i", "j", "k", "m", "n" size selection rule (mm [in.])

Indoor Unit size	Pipe(Liquid)	Pipe(Gas)
P10 to P50, M20 to M50, GUF-50RD(H)	ø6.35 [1/4"]	ø12.70 [1/2"]
P63 to P140, M63 to M140, GUF-100RD(H)	ø9.52 [3/8"]	ø15.88 [5/8"]
P200	ø9.52 [3/8"]	ø19.05 [3/4"]
P250	ø9.52 [3/8"]	ø22.20 [7/8"]

Piping "F", "G", "J", "K" size selection rule

(mm [in.])

Total down-stream Indoor capacity	Pipe(Liquid)	Pipe(HP Gas)	Pipe(LP Gas)
P/M200 or less	ø9.52 [3/8"]	ø15.88 [5/8"]	ø19.05 [3/4"]
P/M201 to P/M300	ø9.52 [3/8"]	ø19.05 [3/4"]	ø22.20 [7/8"]
P/M301 to P/M350	ø12.70 [1/2"]	ø19.05 [3/4"]	ø28.58 [1-1/8"]
P/M351 to P/M400	ø12.70 [1/2"]	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P/M401 to P/M600	ø15.88 [5/8"]	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P/M601 to P/M650	ø15.88 [5/8"]	ø28.58 [1-1/8"]	ø28.58 [1-1/8"]
P/M651 to P/M800	ø19.05 [3/4"]	ø28.58 [1-1/8"]	ø34.93 [1-3/8"]
P/M801 to P/M1000	ø19.05 [3/4"]	ø28.58 [1-1/8"]	ø41.28 [1-5/8"]
P/M1001 or above	ø19.05 [3/4"]	ø34.93 [1-3/8"]	ø41.28 [1-5/8"]

HP: High pressure, LP: Low pressure

12-2-6. IF more than 16 ports are in use, or if there is more than one BC controller in use for two outdoor units

"BC controller," "BC controller (Main)," and "BC controller (Sub)" that appear in this section refer to the M-J1 type, M-JA1 type, P-KA1 type, and M-KB1 type.

Note1. No Header usable on PURY system.

Note2. Indoor unit sized P100-P250/M100-M140 should be connected to BC controller via Y shape joint CMY-R160-J1 ; If the system consists only of PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units, connect to the BC controller via Y-shape joint CMY-R160-J1.

Note3. Indoor unit sized P100-P250/M100-M140 does NOT share BC controller ports with other Indoor units ;

Note4. As bents cause pressure loss on transportation of refrigerant, fewer bents design is better ;

Piping length needs to consider the actual length and equivalent length which bents are counted.

Equivalent piping length (m)=Actual piping length+"M" x Number of bent.

Note5. Set DIP-SW 4-6 to ON of BC controller, in case of connected Indoor unit sized P100-P250/M100-M140 with 2 ports.

If the system consists only of PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units, set the dipswitches SW4-1 and SW4-6 on the BC controller to ON.

Note6. It is also possible to connect Indoor unit sized P/M100-P/M140 with 1 port (set DIP-SW 4-1 and 4-6 to OFF).

PEFY-P50, 63, 71, 80, 100VMHS2-E models of indoor units can be connected to the system using a single port.

However, the cooling capacity decreases a little (For details, refer to the chapter "Correction by port counts of the BC controller").

Note7. Do not connect multiple indoor units to the same port when operating each of them in different mode (cooling, heating, stop, and thermo-off). In case of connecting multiple indoor units to the same port, connecting all indoor units to one remote controller and switching SW1-1 ON in the all connected indoor units (switch to thermostat built in the remote controller) are recommended.

Note8. The maximum total capacity of indoor units that can be connected to each sub BC controller CMB-MV-KB1 is 350.

Note9. Indoor capacity is described as its model size. For example, PEFY-P63VME-E, its capacity is P63.

Note10. Total down-stream Indoor capacity is the summary of the model size of Indoors down-stream. For example, PEFY-P63VME-E + PEFY-P32VME-E : Total Indoor capacity = P63 + P32 = P95.

Note11. To enable the continuous heating mode, set SW4 (848) to ON.

Note12. To connect the BC controller to the main pipe, use the reducer (CMY-R301S-G, CMY-R302S-G1, or CMY-R304S-G1).

Note13. To connect the sub BC controller to the main BC controller, use the reducer (CMY-R303S-G1, CMY-R305S-G1, or CMY-R306S-G).

Note14. Install the pipes correctly referring to the section titled "Procedures for installing the branched pipes."





Fig. 12-2-6AA



OU: Outdoor unit, IU: Indoor unit

Fig. 12-2-6A Piping scheme

Piping length limitation *11

Item	Piping in the figure	Max. length	Max. equivalent length (m [ft.])
Total piping length (Total length of high pressure and liquid pipes)	L+M+A+B+C+D+E+F+G+J+K+a+b+c+d+e+f+g+i+j+k+m+n	*1	-
Farthest IU from OU	L(M)+A+F+G+J+K+n	165 [541']	190 [623']
Distance between OU and BC	L(M)+A	110 [360'] *1	110 [360'] *1
Farthest IU from BC controller	D+E+i	60 [197'] *2 *3	60 [197'] *2*3
Farthest IU from BC controller via Sub BC controller	F+G+J+K+n	90 [295'] *9	90 [295'] *9
Height between OU and IU (OU above IU)	H	50 [164'] *7	-
Height between OU and IU (OU under IU)	H'	40 [131'] *8	-
Height between IU and BC	h1	15 [49'] (10 [32']) *4	-
Height between IU and IU	h2	30 [98'] (20 [65']) *5	-
Height between BC(Main or Sub) and BC(Sub)	h3	15 [49'] (10 [32']) *6	-
Distance between Main unit and Sub unit	L+M	5 [16']	-
Height between Main unit and Sub unit	h4	0.1 [0.3']	-

OU: Outdoor Unit; IU: Indoor Unit; BC: BC controller

*1. Refer to the section 12-2-7.

*2. Details refer to Fig. 2.

*3. When the P200 or P250 model of indoor units are connected to the system, the maximum distance from the BC controller to the farthest indoor unit (indicated as "D + E + i" in the figure is 40 meters.)

*4. Distance of Indoor sized P200, P250 from BC must be less than 10 m, if any.

*5. Distance of Indoor sized P200, P250 from IU must be less than 20 m, if any.

*6. When using 2 Sub BC controllers, max. height "h3" should be considered.

*7. 90 m is available depending on the model and installation conditions. For more detailed information, contact your local distributor.

*8. 60 m is available depending on the model and installation conditions. For more detailed information, contact your local distributor.

*9. When the piping length or the vertical separation exceeds the limit specified in Fig. 2, connect a sub BC to the system.

The restriction for a system with a sub BC connection is shown in Fig. 3.

When a given system configuration falls within the shaded area in Fig. 3, increase the size of the high-pressure pipe and the liquid pipe between the main BC and sub BC by one size.

When using P/M32, P/M40, P/M50, P/M100, or P/M125 model of indoor units, increase the size of the liquid branch pipe between the sub BC and indoor unit by one size.

When using indoor models P/M140 or larger, the restrictions shown in Fig. 2 cannot be exceeded.

*10. When the high pressure piping length is 65 m or less, use ø22.2 (ø7/8) pipe.

When the high pressure piping length exceeds 65 m, use ø22.2 (ø7/8) pipe until 65 m, use ø28.58 (ø1-1/8) pipe for the part that exceeds 65 m.

*11. Total length of high-pressure pipes and liquid pipes

Bent equivalent length

Outdoor Model	m/bent [ft./bent]
P400YSNW-A2/TR2/RU2	0.50 [1.64']
P450YSNW-A2/TR2/RU2	0.50 [1.64']
P500YSNW-A2/TR2/RU2	0.50 [1.64']
P550YSNW-A2/TR2/RU2	0.50 [1.64']
P600YSNW-A2/TR2/RU2	0.50 [1.64']
P650YSNW-A2/TR2/RU2	0.50 [1.64']
P700YSNW-A2/TR2/RU2	0.70 [2.29']
P750YSNW-A2/TR2/RU2	0.70 [2.29']
P800YSNW-A2/TR2/RU2	0.70 [2.29']
P850YSNW-A2/TR2/RU2	0.80 [2.62']
P900YSNW-A2/TR2/RU2	0.80 [2.62']
P950YSNW-A2/TR2/RU2	0.80 [2.62']
P1000YSNW-A2/TR2/RU2	0.80 [2.62']
P1050YSNW-A2/TR2/RU2	0.80 [2.62']
P1100YSNW-A2/TR2/RU2	0.80 [2.62']

Piping length and height between IU and BC controller




Fig. 2





Fig. 3



*9. When the piping length or the vertical separation exceeds the limit specified in Fig. 2, connect a sub BC to the system.
The restriction for a system with a sub BC connection is shown in Fig. 3.
When a given system configuration falls within the shaded area in Fig. 3, increase the size of the high-pressure pipe and the liquid pipe between the main BC and sub BC by one size.
When using P/M32, P/M40, P/M50, P/M100, or P/M125 model of indoor units, increase the size of the liquid branch pipe between the sub BC and indoor unit by one size.
When using indoor models P/M140 or larger, the restrictions shown in Fig. 2 cannot be exceeded.

Piping "A" size selection rule (mm [in.])		
Outdoor Model	Pipe(High pressure)	Pipe(Low pressure)
P400YSNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P450YSNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P500YSNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P550YSNW-A2/TR2/RU2	ø22.20 [7/8"] *10	ø28.58 [1-1/8"]
P600YSNW-A2/TR2/RU2	ø22.20 [7/8"] *10	ø28.58 [1-1/8"]
P650YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø28.58 [1-1/8"]
P700YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø34.93 [1-3/8"]
P750YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø34.93 [1-3/8"]
P800YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø34.93 [1-3/8"]
P850YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø41.28 [1-5/8"]
P900YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø41.28 [1-5/8"]
P950YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø41.28 [1-5/8"]
P1000YSNW-A2/TR2/RU2	ø28.58 [1-1/8"]	ø41.28 [1-5/8"]
P1050YSNW-A2/TR2/RU2	ø34.93 [1-3/8"]	ø41.28 [1-5/8"]
P1100YSNW-A2/TR2/RU2	ø34.93 [1-3/8"]	ø41.28 [1-5/8"]

Piping "L", "M" size selection rule (mm [in.])		
Outdoor Model	Pipe(High pressure)	Pipe(Low pressure)
P200YNW-A2/TR2/RU2	ø15.88 [5/8"]	ø19.05 [3/4"]
P250YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø22.20 [7/8"]
P300YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø22.20 [7/8"]
P350YNW-A2/TR2/RU2	ø19.05 [3/4"]	ø28.58 [1-1/8"]
P400YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P450YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P500YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P550YNW-A2/TR2/RU2	ø22.20 [7/8"]	ø28.58 [1-1/8"]

Piping "B", "C", "D", "E" size selection rule (mm [in.])		
Total down-stream Indoor capacity	Pipe(Liquid)	Pipe(Gas)
P/M140 or less	ø9.52 [3/8"]	ø15.88 [5/8"]
P/M141-P/M200	ø9.52 [3/8"]	ø19.05 [3/4"]
P/M201-P/M250	ø9.52 [3/8"]	ø22.20 [7/8"]

Selection criteria for joints_A	
Total down-stream Indoor capacity	Joint
-P/M200	CMY-Y102SS-G2
P/M201-P/M250	CMY-Y102LS-G2

Piping "a", "b", "c", "d", "e", "f", "g", "i", "j", "k", "m", "n" size selection rule (mm [in.])		
Indoor Unit size	Pipe(Liquid)	Pipe(Gas)
P10 to P50, M20 to M50, GUF-50RD(H)	ø6.35 [1/4"]	ø12.70 [1/2"]
P63 to P140, M63 to M140, GUF-100RD(H)	ø9.52 [3/8"]	ø15.88 [5/8"]
P200	ø9.52 [3/8"]	ø19.05 [3/4"]
P250	ø9.52 [3/8"]	ø22.20 [7/8"]

Selection criteria for joints_B	
Total down-stream Indoor capacity	Joint
-P/M350	CMY-R201S-G
P/M351-P/M600	CMY-R202S-G
P/M601-P/M650	CMY-R203S-G
P/M651-P/M1000	CMY-R204S-G
P/M1001-	CMY-R205S-G


Piping "F", "G", "J", "K" size selection rule (mm [in.])			
Total down-stream Indoor capacity	Pipe(Liquid)	Pipe(HP Gas)	Pipe(LP Gas)
P/M200 or less	ø9.52 [3/8"]	ø15.88 [5/8"]	ø19.05 [3/4"]
P/M201 to P/M300	ø9.52 [3/8"]	ø19.05 [3/4"]	ø22.20 [7/8"]
P/M301 to P/M350	ø12.70 [1/2"]	ø19.05 [3/4"]	ø28.58 [1-1/8"]
P/M351 to P/M400	ø12.70 [1/2"]	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P/M401 to P/M600	ø15.88 [5/8"]	ø22.20 [7/8"]	ø28.58 [1-1/8"]
P/M601 to P/M650	ø15.88 [5/8"]	ø28.58 [1-1/8"]	ø28.58 [1-1/8"]
P/M651 to P/M800	ø19.05 [3/4"]	ø28.58 [1-1/8"]	ø34.93 [1-3/8"]
P/M801 to P/M1000	ø19.05 [3/4"]	ø28.58 [1-1/8"]	ø41.28 [1-5/8"]
P/M1001 or above	ø19.05 [3/4"]	ø34.93 [1-3/8"]	ø41.28 [1-5/8"]

HP: High pressure, LP: Low pressure


PURY-P-Y(S)NW-A2/TR2/RU2

12-2-7. Total piping length restrictions


[PURY-P200, 250, 300YNW-A2/TR2/RU2]




[PURY-P350, 400, 450, 500, 550YNW-A2/TR2/RU2]




[PURY-P400, 450, 500, 550, 600YSNW-A2/TR2/RU2]



[PURY-P650YSNW-A2/TR2/RU2]




[PURY-P700, 750, 800, 850, 900, 950, 1000, 1050, 1100YSNW-A2/TR2/RU2]



12-3. Refrigerant charging calculation

"BC controller," "BC controller (Main)," and "BC controller (Sub)" that appear in this section refer to the P-J type, P-JA type, P-KA type, and P-KB type.

Sample connection (with 5 BC controllers and 8 indoor units) (PURY-P700YSNW-A2/TR2/RU2)



Amount of additional refrigerant to be charged

Refrigerant for extended pipes (field piping) is not factory-charged to the outdoor unit. Add an appropriate amount of refrigerant for each pipes on site. Record the size of each high pressure pipe and liquid pipe, and the amount of refrigerant that was charged on the outdoor unit for future reference.

Calculating the amount of additional refrigerant to be charged

The amount of refrigerant to be charged is calculated with the size of the on-site-installed high pressure pipes and liquid pipes, and their length. Calculate the amount of refrigerant to be charged according to the formula below. Round up the calculation result to the nearest 0.1kg. (i.e., 16.03 kg = 16.1 kg)

<Amount of additional refrigerant to be charged>

Calculating the amount of additional refrigerant to be charged

Units "m" and "kg" (In an R2 system)

<Formula>

• When the piping length from the outdoor unit to the farthest indoor unit is 30.5 m (100 ft) or shorter

Amount of additional charge (kg)	=	High-pressure pipe $\phi 34.93$ total length $\times 0.58$ (kg/m)	+	High-pressure pipe $\phi 28.58$ total length $\times 0.36$ (kg/m)	+	High-pressure pipe $\phi 22.2$ total length $\times 0.23$ (kg/m)	+	High-pressure pipe $\phi 19.05$ total length $\times 0.16$ (kg/m)	+	High-pressure pipe $\phi 15.88$ total length $\times 0.11$ (kg/m)
	+	Liquid pipe $\phi 19.05$ total length $\times 0.29$ (kg/m)	+	Liquid pipe $\phi 15.88$ total length $\times 0.2$ (kg/m)	+	Liquid pipe $\phi 12.7$ total length $\times 0.12$ (kg/m)	+	Liquid pipe $\phi 9.52$ total length $\times 0.06$ (kg/m)	+	Liquid pipe $\phi 6.35$ total length $\times 0.024$ (kg/m)

Main or Sub BC controller	Amount (kg/unit)
P-J-type	1.5
P-JA-type	3.0
P-KA-type	4.7
P-KB-type	0.4

Total capacity of connected indoor units	Amount (kg) (to be added for indoor unit)
80 or below	2.0
81 to 160	2.5
161 to 330	3.0
331 to 390	3.5
391 to 480	4.5
481 to 630	5.0
631 to 710	6.0
711 to 800	8.0
801 to 890	9.0
891 to 1070	10.0
1071 to 1250	12.0
1251 or above	14.0

Outdoor unit model		Amount (kg)
Single	200	1.5
	250	1.5
	300	2.5
	350	3.5
	400	3.5
	450	3
	500	4
Combination	550	5
	400	6
	450	6
	500	6
	550	6
	600	6
	650	4.5
	700	5
	750	5
	800	5
	850	4
	900	3
	950	3
	1000	3
	1050	1.5
1100	1.5	

* In case all connected indoor unit models are Case 1, Case 2, Case 3 or Case 4, do not add the refrigerant amount listed in table <A>. Instead, please add the following amount of refrigerant per indoor unit.

Case 1: PEFY-P20/25/32/40/50/63/71/80/100/125VMA3-E**

→ Add 0.54 kg (PEFY-P20VMA3-E**), 0.74 kg (PEFY-P25/32/40VMA3-E**), 1.16 kg (PEFY-P50/63/71/80/100/125VMA3-E**)

Case 2: PEFY-P50/63/71/80/100VMHS2-E**

→ Add 2.7 kg

Case 3: PLFY-EP50/63/80VEM-E**

→ Add 0.5 kg

Case 4: PEFY-M50/63/71/80/100/125VMA2-A

→ Add 1.45 kg

Case 5: PEFY-M50/63/71/80VMA(L)-A1

→ Add 0.75 kg (PEFY-M50/63VMA(L)-A1)

→ Add 1.0 kg (PEFY-M71/80VMA(L)-A1)

Case 6: PLFY-M50/63/71/80VEM6-E

→ Add 0.75 kg (PLFY-M50/63VEM6-E)

→ Add 1.0 kg (PLFY-M71/80VEM6-E)

Table <A>

- * When connecting PEFY-P20VMA3-E units, add 0.54 kg of refrigerant for each of these units.
- * When connecting PEFY-P25/32/40VMA3-E units, add 0.74 kg of refrigerant for each of these units.
- * When connecting PEFY-P50/63/71/80/100/125VMA3-E units, add 1.16 kg of refrigerant for each of these units.
- * When connecting PEFY-P50/63/71/80/100VMHS2-E units, add 2.7 kg of refrigerant for each of these units.
- * When connecting PEFY-M50/63/71/80/100/125VMA2-A units, add 1.45 kg of refrigerant for each of these units.
- * When connecting LEV kit (PAC-LV11M-J), refer to the installation manual of the LEV kit.
- * When connecting PLFY-EP50/63/80VEM-E units, add 0.5 kg of refrigerant for each of these units.
- * When connecting PEFY-M50/63VMA(L)-A1 units, add 0.75 kg of refrigerant for each of these units.
- * When connecting PEFY-M71/80VMA(L)-A1 units, add 1.0 kg of refrigerant for each of these units.
- * When connecting PLFY-M50/63VEM6-E units, add 0.75 kg of refrigerant for each of these units.
- * When connecting PLFY-M71/80VEM6-E units, add 1.0 kg of refrigerant for each of these units.

- When the piping length from the outdoor unit to the farthest indoor unit is longer than 30.5 m (100 ft)

Amount of additional charge (kg)	=	High-pressure pipe ø34.93 total length × 0.52 (kg/m)	+	High-pressure pipe ø28.58 total length × 0.33 (kg/m)	+	High-pressure pipe ø22.2 total length × 0.21 (kg/m)	+	High-pressure pipe ø19.05 total length × 0.14 (kg/m)	+	High-pressure pipe ø15.88 total length × 0.1 (kg/m)
	+	Liquid pipe ø19.05 total length × 0.26 (kg/m)	+	Liquid pipe ø15.88 total length × 0.18 (kg/m)	+	Liquid pipe ø12.7 total length × 0.11 (kg/m)	+	Liquid pipe ø9.52 total length × 0.054 (kg/m)	+	Liquid pipe ø6.35 total length × 0.021 (kg/m)
	+	Main or Sub BC controller		Amount (kg/unit)		Total capacity of connected indoor units		Amount(kg) (to be added for indoor unit)		
		P-J-type		1.5		80 or below		2.0		
		P-JA-type		3.0		81 to 160		2.5		
		P-KA-type		4.7		161 to 330		3.0		
		P-KB-type		0.4		331 to 390		3.5		
						391 to 480		4.5		
						481 to 630		5.0		
						631 to 710		6.0		
						711 to 800		8.0		
						801 to 890		9.0		
						891 to 1070		10.0		
						1071 to 1250		12.0		
						1251 or above		14.0		

* When the piping length from the outdoor unit to farthest indoor unit is longer than 30.5 m (100 ft), no refrigerant needs to be added to the indoor units with specific model names.

* When connecting LEV kit (PAC-LV11M-J), refer to the installation manual of the LEV kit.

■ Amount of factory charged refrigerant

Outdoor unit Model	Charged amount
P200 P250 P300	5.2 kg
P350 P400	8.0 kg
P450 P500 P550	10.8 kg

■ Sample calculation

Indoor	1: 50	A: ø28.58	40m	a: ø6.35	10m
	2: 250	B: ø9.52	10m	b: ø9.52	10m
	3: 15	C: ø12.7	20m	c: ø6.35	5m
	4: 20	D: ø9.52	5m	d: ø6.35	5m
	5: 125	E: ø9.52	5m	e: ø9.52	5m
	6: 100	F: ø9.52	5m	f: ø9.52	5m
	7: 80	G: ø19.05	3m	g: ø9.52	5m
	8: 50	H: ø19.05	1m	h: ø6.35	10m

Outdoor P700

Main BC controller CMB-P108V-JA

Sub BC controller CMB-P104V-KB × 4

The total length of each liquid line as follows:

ø28.58: A = 40 m

ø19.05: G + H = 4 m

ø12.70: C = 20 m

ø9.52: B + D + E + F + b + e + f + g = 50 m

ø6.35: a + c + d + h = 30 m

<Calculation example>

Additional refrigerant charge

= 40 × 0.33 + 4 × 0.14 + 20 × 0.11 + 50 × 0.054

+ 30 × 0.021 + 3 × 0.4 × 4 + 6

= 28.7 (28.69)kg

■ Limitation of the amount of refrigerant to be charged


The above calculation result of the amount of refrigerant to be charged must become below the value in the table below.

Total index of the outdoor units			P200 YNW	P250 YNW	P300 YNW	P350 YNW	P400 YNW	P450 YNW	P500 YNW	P550 YNW	P400 YSNW	P450 YSNW	P500 YSNW	P550 YSNW	P600 YSNW	P650 YSNW
Maximum refrigerant charge	Factory charged	kg	5.2	5.2	5.2	8.0	8.0	10.8	10.8	10.8	10.4	10.4	10.4	10.4	10.4	13.2
	Charged on site	kg	31.8	37.8	37.8	41.3	47.3	44.5	45.2	45.2	48.6	48.6	48.6	48.6	48.6	45.8
	Total for system	kg	37.0	43.0	43.0	49.3	55.3	55.3	56.0	56.0	59.0	59.0	59.0	59.0	59.0	59.0

Total index of the outdoor units			P700 YSNW	P750 YSNW	P800 YSNW	P850 YSNW	P900 YSNW	P950 YSNW	P1000 YSNW	P1050 YSNW	P1100 YSNW
Maximum refrigerant charge	Factory charged	kg	16.0	16.0	16.0	18.8	21.6	21.6	21.6	21.6	21.6
	Charged on site	kg	70.0	70.0	70.0	67.2	64.4	64.4	64.4	64.4	64.4
	Total for system	kg	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0

"BC controller," "BC controller (Main)," and "BC controller (Sub)" that appear in this section refer to the M-J1 type, M-JA1 type, P-KA1 type, and M-KB1 type.

Sample connection (with 5 BC controllers and 8 indoor units) (PURY-P700YSNW-A2/TR2/RU2)



■ Amount of additional refrigerant to be charged

Refrigerant for extended pipes (field piping) is not factory-charged to the outdoor unit. Add an appropriate amount of refrigerant for each pipes on site. Record the size of each high pressure pipe and liquid pipe, and the amount of refrigerant that was charged on the outdoor unit for future reference.

■ Calculating the amount of additional refrigerant to be charged

The amount of refrigerant to be charged is calculated with the size of the on-site-installed high pressure pipes and liquid pipes, and their length.

Calculate the amount of refrigerant to be charged according to the formula below.

Round up the calculation result to the nearest 0.1kg. (i.e., 16.03 kg = 16.1 kg)

<Amount of additional refrigerant to be charged>

■ Calculating the amount of additional refrigerant to be charged

Units "m" and "kg" (In an R2 system)

<Formula>

• When the piping length from the outdoor unit to the farthest indoor unit is 30.5 m (100 ft) or shorter

Amount of additional charge (kg)	=	High-pressure pipe ø34.93 total length × 0.58 (kg/m)	+	High-pressure pipe ø28.58 total length × 0.36 (kg/m)	+	High-pressure pipe ø22.2 total length × 0.23 (kg/m)	+	High-pressure pipe ø19.05 total length × 0.16 (kg/m)	+	High-pressure pipe ø15.88 total length × 0.11 (kg/m)
	+	Liquid pipe ø19.05 total length × 0.29 (kg/m)	+	Liquid pipe ø15.88 total length × 0.2 (kg/m)	+	Liquid pipe ø12.7 total length × 0.12 (kg/m)	+	Liquid pipe ø9.52 total length × 0.06 (kg/m)	+	Liquid pipe ø6.35 total length × 0.024 (kg/m)

Main or Sub BC controller	Amount (kg/unit)
M-J1-type	1.5
M-JA1-type	3.0
P-KA1-type	4.7
M-KB1-type	0.4

Total capacity of connected indoor units	Amount (kg) (to be added for indoor unit)
80 or below	2.0
81 to 160	2.5
161 to 330	3.0
331 to 390	3.5
391 to 480	4.5
481 to 630	5.0
631 to 710	6.0
711 to 800	8.0
801 to 890	9.0
891 to 1070	10.0
1071 to 1250	12.0
1251 or above	14.0

Outdoor unit model		Amount (kg)
Single	200	1.5
	250	1.5
	300	2.5
	350	3.5
	400	3.5
	450	3
	500	4
	550	5
Combination	400	6
	450	6
	500	6
	550	6
	600	6
	650	4.5
	700	5
	750	5
	800	5
	850	4
	900	3
	950	3
	1000	3
1050	1.5	
1100	1.5	

* In case all connected indoor unit models are Case 1, Case 2, Case 3 or Case 4, do not add the refrigerant amount listed in table <A>. Instead, please add the following amount of refrigerant per indoor unit.

Case 1: PEFY-P20/25/32/40/50/63/71/80/100/125VMA3-E**

→ Add 0.54 kg (PEFY-P20VMA3-E**), 0.74 kg (PEFY-P25/32/40VMA3-E**), 1.16 kg (PEFY-P50/63/71/80/100/125VMA3-E**)

Case 2: PEFY-P50/63/71/80/100VMHS2-E**

→ Add 2.7 kg

Case 3: PLFY-EP50/63/80VEM-E**

→ Add 0.5 kg

Case 4: PEFY-M50/63/71/80/100/125VMA2-A

→ Add 1.45 kg

Case 5: PEFY-M50/63/71/80VMA(L)-A1

→ Add 0.75 kg (PEFY-M50/63VMA(L)-A1)

→ Add 1.0 kg (PEFY-M71/80VMA(L)-A1)

Case 6: PLFY-M50/63/71/80VEM6-E

→ Add 0.75 kg (PLFY-M50/63VEM6-E)

→ Add 1.0 kg (PLFY-M71/80VEM6-E)

Table <A>

- * When connecting PEFY-P20VMA3-E units, add 0.54 kg of refrigerant for each of these units.
 * When connecting PEFY-P25/32/40VMA3-E units, add 0.74 kg of refrigerant for each of these units.
 * When connecting PEFY-P50/63/71/80/100/125VMA3-E units, add 1.16 kg of refrigerant for each of these units.
 * When connecting PEFY-P50/63/71/80/100VMS2-E units, add 2.7 kg of refrigerant for each of these units.
 * When connecting PEFY-M50/63/71/80/100/125VMA2-A units, add 1.45 kg of refrigerant for each of these units.
 * When connecting LEV kit (PAC-LV11M-J), refer to the installation manual of the LEV kit.
 * When connecting PLFY-EP50/63/80VEM-E units, add 0.5 kg of refrigerant for each of these units.
 * When connecting PEFY-M50/63VMA(L)-A1 units, add 0.75 kg of refrigerant for each of these units.
 * When connecting PEFY-M71/80VMA(L)-A1 units, add 1.0 kg of refrigerant for each of these units.
 * When connecting PLFY-M50/63VEM6-E units, add 0.75 kg of refrigerant for each of these units.
 * When connecting PLFY-M71/80VEM6-E units, add 1.0 kg of refrigerant for each of these units.

• When the piping length from the outdoor unit to the farthest indoor unit is longer than 30.5 m (100 ft)

Amount of additional charge (kg)	=	High-pressure pipe ø34.93 total length × 0.52 (kg/m)	+	High-pressure pipe ø28.58 total length × 0.33 (kg/m)	+	High-pressure pipe ø22.2 total length × 0.21 (kg/m)	+	High-pressure pipe ø19.05 total length × 0.14 (kg/m)	+	High-pressure pipe ø15.88 total length × 0.1 (kg/m)
	+	Liquid pipe ø19.05 total length × 0.26 (kg/m)	+	Liquid pipe ø15.88 total length × 0.18 (kg/m)	+	Liquid pipe ø12.7 total length × 0.11 (kg/m)	+	Liquid pipe ø9.52 total length × 0.054 (kg/m)	+	Liquid pipe ø6.35 total length × 0.021 (kg/m)
	+	Main or Sub BC controller		Amount (kg/unit)		Total capacity of connected indoor units		Amount(kg) (to be added for indoor unit)		
		M-J1-type		1.5		80 or below		2.0		
		M-JA1-type		3.0		81 to 160		2.5		
		P-KA1-type		4.7		161 to 330		3.0		
		M-KB1-type		0.4		331 to 390		3.5		
					+	391 to 480		4.5		
						481 to 630		5.0		
						631 to 710		6.0		
						711 to 800		8.0		
						801 to 890		9.0		
						891 to 1070		10.0		
						1071 to 1250		12.0		
						1251 or above		14.0		

- * When the piping length from the outdoor unit to farthest indoor unit is longer than 30.5 m (100 ft), no refrigerant needs to be added to the indoor units with specific model names.
 * When connecting LEV kit (PAC-LV11M-J), refer to the installation manual of the LEV kit.

■ Amount of factory charged refrigerant

Outdoor unit Model	Charged amount
P200	5.2 kg
P250	
P300	
P350	8.0 kg
P400	
P450	10.8 kg
P500	
P550	

■ Sample calculation

Indoor	1: 50	A: ø28.58	40m	a: ø6.35	10m
	2: 250	B: ø9.52	10m	b: ø9.52	10m
	3: 15	C: ø12.7	20m	c: ø6.35	5m
	4: 20	D: ø9.52	5m	d: ø6.35	5m
	5: 125	E: ø9.52	5m	e: ø9.52	5m
	6: 100	F: ø9.52	5m	f: ø9.52	5m
	7: 80	G: ø19.05	3m	g: ø9.52	5m
	8: 50	H: ø19.05	1m	h: ø6.35	10m

Outdoor P700
 Main BC controller CMB-M108V-JA1
 Sub BC controller CMB-M104V-KB1 × 4

The total length of each liquid line as follows:
 ø28.58: A = 40 m
 ø19.05: G + H = 4 m
 ø12.70: C = 20 m
 ø9.52: B + D + E + F + b + e + f + g = 50 m
 ø6.35: a + c + d + h = 30 m
 <Calculation example>
 Additional refrigerant charge
 = 40 × 0.33 + 4 × 0.14 + 20 × 0.11 + 50 × 0.054
 + 30 × 0.021 + 3 + 0.4 × 4 + 6
 = 28.7 (28.69)kg

■ Limitation of the amount of refrigerant to be charged

The above calculation result of the amount of refrigerant to be charged must become below the value in the table below.

Total index of the outdoor units			P200 YNW	P250 YNW	P300 YNW	P350 YNW	P400 YNW	P450 YNW	P500 YNW	P550 YNW	P400 YSNW	P450 YSNW	P500 YSNW	P550 YSNW	P600 YSNW	P650 YSNW
Maximum refrigerant charge	Factory charged	kg	5.2	5.2	5.2	8.0	8.0	10.8	10.8	10.8	10.4	10.4	10.4	10.4	10.4	13.2
	Charged on site	kg	31.8	37.8	37.8	41.3	47.3	44.5	45.2	45.2	48.6	48.6	48.6	48.6	48.6	45.8
	Total for system	kg	37.0	43.0	43.0	49.3	55.3	55.3	56.0	56.0	59.0	59.0	59.0	59.0	59.0	59.0

Total index of the outdoor units			P700 YSNW	P750 YSNW	P800 YSNW	P850 YSNW	P900 YSNW	P950 YSNW	P1000 YSNW	P1050 YSNW	P1100 YSNW
Maximum refrigerant charge	Factory charged	kg	16.0	16.0	16.0	18.8	21.6	21.6	21.6	21.6	21.6
	Charged on site	kg	70.0	70.0	70.0	67.2	64.4	64.4	64.4	64.4	64.4
	Total for system	kg	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0

13-1. Requirement on installation site

1. No direct thermal radiation to the unit.
2. No possibility of annoying the neighbors by the sound of the unit.

Valves and refrigerant flow on the outdoor unit may generate noise.

3. Avoid the sites where strong winds blow.
4. With strength to bear the weight of the unit.
5. Drain flow from the unit is cared at heating mode.
6. Enough space for installation and service as shown at 13-2.
7. Avoid the sites where acidic solutions or chemical sprays (sulfuric compounds) are used frequently.
8. The unit should be secure from combustible gas, oil, steam, chemical gas like acidic solution, sulfur gas and so on.


PURY-P-Y(S)NW-A2/TR2/RU2

13-2. Spacing

In case of single installation

(1) When all walls are within their height limits*.

[mm (in)]




* Height limit	
Front/Right/Left/Rear	Same height or lower than the overall height of the unit


	Required minimum distance [mm (in)]		
	L ₁ (Front)	L ₂ (Rear)	L ₃ (Right/Left)
When the distance behind the unit (L ₂) needs to be small	450 (17-3/4)	100 (3-15/16)	50 (2)
When the distance to the right or left (L ₃) needs to be small	450 (17-3/4)	300 (11-13/16)	15 (5/8)

(2) When one or more walls exceed their height limits*.


When the wall(s) at the front and/or the right/left exceed(s) their height limits



When the wall at the rear exceeds its height limit





When all walls exceed their height limits



If the height of the walls around the unit exceeds the height limit, add half of the height that exceeds the limit ($h_1/2$ - $h_3/2$) to L₁, L₂, and L₃ as shown in the table below.

	Required minimum distance [mm (in)]		
	L ₁ (Front)	L ₂ (Rear)	L ₃ (Right/Left)
When the distance behind the unit (L ₂) needs to be small	450 (17-3/4) + $h_1/2$	100 (3-15/16) + $h_2/2$	50 (2) + $h_3/2$
When the distance to the right or left (L ₃) needs to be small	450 (17-3/4) + $h_1/2$	300 (11-13/16) + $h_2/2$	15 (5/8) + $h_3/2$

(3) When there are overhead obstacles




In case of collective installation and continuous installation

- When installing multiple units, make sure to take into consideration factors such as providing enough space for people to pass through, ample space between blocks of units, and sufficient space for airflow. (The areas marked with [A] in the figures below must be left open.)
- In the same way as with the single unit installation, if the height of the walls around the unit exceeds the height limit, add half of the height that exceeds the limit ($(h_1/2 - h_3/2)$) to L_1 , L_2 , and L_3 as shown in the table below.
- If there are walls in the front and rear of the block of units, up to six units (three units for units P500 and P550) can be installed consecutively side by side, and a space of 1000 mm (39-3/8 in) or more must be left between each block of six units (three units for units P500 and P550).


(1) Side-by-side installation

When the distances between the units (L_4) need to be small



Required minimum distance [mm (in)]		
L_1 (Front)	L_2 (Rear)	L_4 (Between)
$450 (17-3/4) + h_1/2$	$300 (11-13/16) + h_2/2$	$30 (1-3/16)$


When the distance behind the block of units (L_2) needs to be small



Required minimum distance [mm (in)]		
L_1 (Front)	L_2 (Rear)	L_4 (Between)
$450 (17-3/4) + h_1/2$	$100 (3-15/16) + h_2/2$	$100 (3-15/16)$


(2) Face-to-face installation

When there are walls in the front and rear of the block of units



Required minimum distance [mm (in)]		
L_1 (Front)	L_2 (Rear)	L_4 (Between)
$450 (17-3/4) + h_1/2$	$100 (3-15/16) + h_2/2$	$450 (17-3/4)$


When there is a wall on either the right or left side of the block of units



Required minimum distance [mm (in)]	
L_3 (Right/Left)	L_4 (Between)
$15 (5/8) + h_3/2$	$450 (17-3/4)$

(3) Combination of face-to-face and side-by-side installations


When there are walls in the front and rear of the block of units



Required minimum distance [mm (in)]		
L_2 (Rear)	L_2' (Rear)	L_4 (Between)
$300 (11-13/16) + h_2/2$	$300 (11-13/16) + h_2'/2$	$900 (35-7/16)$

[A]: Leave open in two directions.

When there are two walls in an L-shape




Required minimum distance [mm (in)]		
L_2 (Rear)	L_3 (Right/Left)	L_4 (Between)
$300 (11-13/16) + h_2/2$	$1000 (39-3/8) + h_3/2$	$900 (35-7/16)$

13-3. Piping direction

13-3-1. Lifting method

- Always use two slings to lift up the unit. Each sling must be at least 8 m (26 ft) long and must be able to support the weight of the unit.
- Put protective pads between slings and the unit where the slings touch the unit at the base to protect the unit from being scratched.
- Put 50 mm (2 in) or thicker protective pads between slings and the unit where the slings touch the unit at the top of the unit to protect the unit from being scratched and to avoid contact with the slings and the fan guard.
- Make sure that the angles between slings at the top are less than 40 degrees



⚠ CAUTION

Exercise caution when transporting products.

- Products weighing more than 20 kg [45 LBS] should not be carried alone.
- Do not carry the product by the PPbands.
- To avoid the risk of injury, do not touch the heat exchanger fins.
- Plastic bags may pose a risk of choking hazard to children. Tear plastic bags into pieces before disposing of them.
- When lifting and transporting outdoor units with ropes, run the ropes through lifting hole at the unit base. Securely fix the unit so that the ropes will not slide off, and always lift the unit at four points to prevent the unit from falling.

13-3-2. Installation

- Secure the unit with anchor bolts as shown in the figure below so that the unit will not topple over with strong wind or during an earthquake.
- Install the unit on a durable base made of such materials as concrete or angle steel.
- Take appropriate anti-vibration measures (e.g., vibration damper pad, vibration isolation base) to keep vibrations and noise from being transmitted from the unit through walls and floors.
- When installing a unit on a base, place an anti-vibration pad between the base and the unit.
- When using an anti-vibration rubber pad, install it so that the pad covers the entire width of the unit leg.
- All the bottom corners of the unit must still be supported by both the anti-vibration rubber pads and the base.
- Install the unit in such a way that the corner of the angle bracket at the base of the unit shown in the figure below is securely supported.
- Install the anchor bolt in such a way that the top end of the anchor bolt do not stick out more than 30 mm [1-3/16 in.].
- This unit is not designed to be anchored with post-installation-type anchor bolts, although by adding fixing brackets anchoring with such type of anchor bolts becomes possible.
- Securely bolt down the unit as illustrated below so that it will not fall over when subject to wind gusts or earthquakes.

- (A) M10 anchor bolt* procured at the site
*Required specification for M10 anchor bolt: Tensile load of 5.6 kN or more to withstand the short-term load caused by earthquakes or strong winds
- (B) (Incorrect installation) The corner section is not securely received.
- (C) Fixing bracket for M12 hole-in anchor bolt* procured at the site (3 locations to fix with M5 self-tapping screws)
*Required specification for M12 hole-in anchor bolt: Tensile load of 6.7 kN or more to withstand the short-term load caused by earthquakes or strong winds
Use the fixing bracket with sufficient strength.
- (D) Anti-vibration rubber pad
(The pad needs to be large enough to cover the entire width of each unit leg.)
- (E) Detachable leg


WARNING

Properly install the unit on a surface that can withstand the weight of the unit. Unit installed on an unstable surface may fall and cause injury.



WARNING

Take adequate measures against natural disasters including earthquakes and windstorms so that the unit will not fall or tip over. Consult your local specialist for safety measures to be taken.


<Without detachable leg>





Install the unit in such a way that the corner of the angle bracket at the base of the unit shown in the figure is securely supported. The brackets may bend if they are not securely supported.



<With detachable leg>



Install the unit in such a way that the corner of the angle bracket at the base of the unit shown in the figure is securely supported. The brackets may bend if they are not securely supported.




Take into consideration the durability of the base, water drainage route (Drain water is discharged from outdoor units during operation.), piping route, and wiring route when performing foundation work.


13-3-3. Anchor bolt positions

<P200-450>

• Individual installation




• Collective installation




(Unit : mm [in.])

<P500, 550>

• Individual installation



• Collective installation



Leave a minimum of 30 mm [1-3/16 in.] between units.

PURY	P200, 250, 300	P350, 400, 450	P500, 550
A	760±2 [29-15/16(29-7/8~30)]	1060±2 [41-3/4(41-11/16~41-13/16)]	795±2 [31-5/16(31-1/4~31-7/16)]
B	190 [7-1/2]	210 [8-5/16]	190 [7-1/2]


PUR-P-Y(S)NW-A2/TR2/RU2

13-3-4. Installation

When the pipes and/or cables are routed at the bottom of the unit, make sure that the through hole at the base of the unit does not get blocked with the installation base.


When the pipes are routed at the bottom of the unit, the base should be at least 100 mm [3-15/16 in.] in height.

(Unit: mm[in.])




NO.	Usage	Specifications
(A)	For pipes	Bottom through hole 150 × 94 Knockout hole [5-15/16] [3-3/4]
(B)	For wires	Bottom through hole ø65 Knockout hole [2-9/16]
(C)		Bottom through hole ø52 Knockout hole [2-1/16]
(D)	For transmission cables	Bottom through hole ø34 Knockout hole [1-3/8]


Installation base parallel to the unit's front panel



Installation base perpendicular to the unit's front panel



13-3-5. Refrigerant pipe routing



Example of closure materials (field supply) Fill the gap at the site

The gaps around the edges of through holes for pipes and wires on the unit allow water or mice to enter the unit and damage its parts. Close these gaps with filler plates.

- This unit allows two types of pipe routing:
- Bottom piping
 - Front piping

CAUTION

To prevent small animals, water and snow from entering the unit and damage its parts, close the gap around the edges of through holes for pipes and wires with filler plates.

13-3-6. Twinning on the outdoor unit side

- The pipe from multiple outdoor units must be installed so that oil will not accumulate in the pipe under certain conditions. Refer to the figures below for details.

* Small dots in the figures indicate branching points.

① To a BC controller

- (1) The pipe from the outdoor units must be inclined downward to the indoor unit side. In the figure on the right, because the pipe is inclined upward, the oil in the pipe accumulates when Unit 1 is in operation and Unit 2 is stopped.



- (2) The distance between the unit bottom and the pipe (H) must be 0.2 m (7-7/8 in) or below. In the figure on the right, because the distance is more than 0.2 m (7-7/8 in), the oil accumulates in Unit 1 when Unit 2 is in operation and Unit 1 is stopped.




- (3) The vertical separation between units (H) must be 0.1 m (3-15/16 in) or below. In the figure on the right, because the distance is more than 0.1 m (3-15/16 in), the oil accumulates in Unit 1 when Unit 2 is in operation and Unit 1 is stopped.



- (4) The vertical separation between units (H) must be 0.1 m (3-15/16 in) or below. In the figure on the right, because the distance is more than 0.1 m (3-15/16 in), the oil accumulates in Unit 2 when Unit 1 is in operation and Unit 2 is stopped.




- The Twinning pipe must be installed horizontally using a level vessel to avoid unit damage.



- If the length of the pipe between the branching point and the outdoor unit exceeds 2 m (6 ft), provide an expansion loop or an offset within 2 m (6 ft) from the branching point. The expansion loop or offset must be at least 200 mm (7-7/8 in) in height. (high-pressure pipe only) If there is no expansion loop or offset, oil can accumulate inside the pipe, causing a shortage of oil and may damage the compressor.


* Small dots in the figures indicate branching points.



① To a BC controller
② Expansion loop or offset (high-pressure pipe only)
③ High-pressure pipe

**Caution:**


- Do not install expansion loops or offsets other than the ones between outdoor units described on a separate sheet to prevent oil backflow and compressor start-up failure.
- Do not install solenoid valves to prevent oil backflow and compressor start-up failure.
- Do not install a sight glass because it may show improper refrigerant flow. If a sight glass is installed, inexperienced technicians that use the glass may overcharge the refrigerant.
- Refrigerant pipes may expand or shrink due to temperature fluctuations of the refrigerant inside the pipes. When installing long straight pipes, provide expansion loops or offsets to absorb the thermal expansions of the pipes.



13-3-7. Twinning on the outdoor unit side

See the following drawing for connecting the pipes between the outdoor units.

<In case of 2units combination>



- ♦ PURY-P200YNW-A2/TR2/RU2 through PURY-P500YNW-A2/TR2/RU2, and PURY-EP200YNW-A2/TR2/RU2 through PURY-EP500YNW-A2/TR2/RU2 can be used in a Hybrid City Multi system. Contact your dealer when connecting the larger capacity units in a Hybrid City Multi system.

13-4. Weather countermeasure

In cold and/or snowy areas, sufficient countermeasures to wind and snow damages should be taken for operating unit in normal and good condition in winter time. Surround the units with snow nets or fences to protect them from snow. Even in the other areas, full consideration is required for installation of unit in order to prevent abnormal operations caused by wind or snow. **When rain and snow directly fall on unit in the case of air-conditioning operations in 10 or less degrees centigrade outdoor air (50 or less degrees fahrenheit outdoor air), mount inlet and outlet ducts on unit for assuring stable operations. It is recommended to install a duct to fully make use of the advantages of the panel heater.**


Countermeasure to snow and wind

Prevention the Outdoor unit from wind and snow damages in cold or snowy areas, snow hood shown below is recommended and helpful.

*Do not use a snow hood made of stainless steel, which may cause the unit to rust. If the use of a stainless snow hood is the only option, contact the sales office before installing it.


*When installing a snow hood, take pressure loss into consideration to prevent airflow from decreasing.

- Snow hood



13-5. Countermeasure to wind

Referring to the figure shown below, take appropriate measures which will suit the actual situation of the place for installation. A unit installed alone is vulnerable to strong winds. Select the installation site carefully to minimize the effect of winds. To install a unit in a place where the wind always blows from the same direction, install the unit so that the outlet faces away from the direction of the wind.



13-6. Precautions for installing a panel heater

If there is a risk that the drain water will freeze inside the outdoor unit, the installation of a panel heater is recommended. When installing a panel heater, provide sufficient space for maintenance accordingly. For details, refer to the installation manual for the panel heater.

Installation information

1. Installation information 2

 1-1. General precautions 2

 1-2. Precautions for Indoor unit and BC controller 4

 1-3. Precautions for outdoor unit/heat source unit 5

 1-4. Precautions for control-related items 6

* Refer to the enclosed Installation Manual for details on installation. Arrange to have an expert install the system correctly.

1-1. General precautions

1-1-1. Usage

- The air-conditioning system described in this DATA BOOK is designed for human comfort.
- This product is not designed to assist in the preservation of food, provide conditions to maintain plants or animals, or stabilize environments for the preservation of precision equipment or art objects. To prevent loss of quality, do not use the product for purposes other than those it is designed for.
- To reduce the risk of water leakage and electric shock, do not use the product for air-conditioning vehicles or vessels.

1-1-2. Installation environment

- Do not install any unit other than the dedicated unit in an area where the voltage changes significantly, large amounts of mineral oil (e.g., cutting oil) are present, cooking oil may splash, or a large quantity of steam can be generated, such as a kitchen.
- Do not install the unit in acidic or alkaline environments.
- Installation should not be performed in locations exposed to chlorine or other corrosive gases. Avoid installation near sewers.
- To reduce the risk of fire, do not install the unit in an area where flammable gas may leak or flammable material is present.
- This air-conditioning unit has a built-in microcomputer. The effects of noise should be taken into consideration when deciding on the installation position. It is recommended that the air-conditioning unit be installed in a position away from antennas or electronic devices.
- Install the unit on a solid foundation in accordance with local safety measures against typhoons, wind gusts, and earthquakes to prevent the unit from being damaged, toppling over, or falling.

1-1-3. Backup system

- In regions in which the malfunctioning of the air conditioner may have a critical effect, it is recommended to have two or more systems made up of single outdoor/heat source units and multiple indoor units.

1-1-4. Unit characteristics

- The heat pump efficiency of the outdoor unit depends on the outdoor temperature. In heating mode, performance drops as the outside air temperature drops. In cold climates, performance can be poor. Warm air will continue to be trapped near the ceiling and the floor level will remain cold. In such cases, heat pumps require a supplemental heating system or air circulator. Before purchasing, consult your local distributor for assistance in selecting the unit and system.
- When the outdoor temperature is low and the humidity is high, the heat exchanger on the outdoor/heat source unit side tends to collect frost, which reduces its heating performance. The Auto-defrost function will be activated in order to remove the frost, and the heating mode will temporarily stop for 3-10 minutes. Heating mode will automatically resume upon completion of the defrost process.
- An air conditioner with a heat pump requires time to warm up the whole room after the heating operation begins, because the system circulates warm air in order to warm up the whole room.
- Sound levels were obtained in an anechoic room. Sound levels during actual operation are usually higher than the simulated values due to ambient noise and echoes. Refer to the section on "SOUND LEVELS" in the DATA BOOK for the measurement location.
- Depending on the operating conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes even when operating normally. Try to avoid positioning the air conditioner in locations where quietness is required. With regard to the BC/HBC controller, it is recommended that the unit be installed in areas such as corridor ceilings, restrooms and plant rooms.
- The total capacity of the connected indoor units can be greater than the capacity of the outdoor/heat source unit. However, when the connected indoor units operate simultaneously, each unit's capacity may become smaller than the rated capacity.
- When the unit is started up for the first time within 12 hours after the power comes on, i.e. after a power failure, it performs initial startup operation (capacity control operation) to prevent damage to the compressor. The initial startup operation requires a maximum of 90 minutes to complete, depending on the operating load.

1-1-5. Related equipment

- ♦Use an earth leakage breaker (ELB) with medium sensitivity, and an activation speed of 0.1 second or less.
- ♦Consult your local distributor or a qualified technician when installing an earth leakage breaker.
- ♦If the unit is an inverter type, select an earth leakage breaker able to respond to high harmonic waves and surges.
- ♦Leakage current is generated not only through the air-conditioning unit but also through the power wires. The leakage current of the main power supply is therefore greater than the total leakage current of each unit. Take the capacity of the earth leakage breaker or leakage alarm into consideration when installing one at the main power supply. To measure the leakage current simply on site, use a measurement tool equipped with a filter, and clamp all the four power wires together. The leakage current measured on the ground wire may not be accurate because the leakage current from other systems may be included in the measurement value.
- ♦Do not install a phase-advancing capacitor on a unit connected to the same power system as an inverter-type unit and its related equipment.
- ♦If a large current flows due to the malfunctioning of the product or faulty wiring, both the earth leakage breaker on the product side and the upstream overcurrent breaker may trip almost at the same time. Separate the power system or coordinate all the breakers depending on the system's priority level.

1-1-6. Unit installation

- ♦Your local distributor or a qualified technician must read the Installation Manual that is provided with each unit carefully before performing installation work.
- ♦Consult your local distributor or a qualified technician when installing the unit. Improper installation by an unqualified person may result in water leakage, electric shock, or fire.
- ♦Ensure that there is enough space around each unit.

1-1-7. Optional accessories

- ♦Only use accessories recommended by Mitsubishi Electric. Consult your local distributor or a qualified technician when installing them. Improper installation by an unqualified person may result in water leakage, power leakage, system breakdown, or fire.
- ♦Some optional accessories may not be compatible for use with the air-conditioning unit or may not be suitable for the installation conditions. Check the compatibility when considering any accessories.
- ♦Note that some optional accessories may affect the air conditioner's external form, appearance, weight, operating sound, and other characteristics.

1-1-8. Operation/Maintenance

- ♦Read the Instruction Book that is provided with each unit carefully prior to use.
- ♦Maintenance or cleaning of each unit may be risky and require expertise. Read the Instruction Book to ensure safety. Consult your local distributor or a qualified technician when special expertise is required, such as when the indoor unit needs to be cleaned.

1-2. Precautions for Indoor unit and BC controller

1-2-1. Operating environment

- The refrigerant (R410A) used in the air conditioner is non-toxic and nonflammable. However, if the refrigerant leaks, the oxygen level may drop to harmful levels. If the air conditioner is installed in a small room, measures must be taken to prevent the refrigerant concentration from exceeding the safety limit even if the refrigerant leaks.
- If the units operate in cooling mode at a humidity above 80%, condensation may collect and drip from the indoor units.
- Regular checking and cleaning of the drain drainage paths, such as the drain pan or the drain pump, is recommended to prevent clogging. The neglect of a clogged drain pump may trigger the water-leakage protection function which stops operation of the entire system.

1-2-2. Unit characteristics

- The return air temperature display on the remote controller may differ from the displays on the other thermometers.
- The clock on the remote controller may be displayed with a time lag of approximately one minute every month.
- The temperature measured by the built-in temperature sensor on the remote controller may differ from the actual room temperature due to the effect of the wall temperature.
- Use the built-in thermostat on the remote controller or a separately-sold thermostat when indoor units installed on or in the ceiling operate the automatic cooling/heating switchover.
- The room temperature may rise drastically due to Thermo OFF in areas where the air-conditioning load is large, such as computer rooms.
- Be sure to use a regular filter. If an irregular filter is installed, the unit may not operate properly, and operating noise may increase.
- The room temperature may increase above the preset temperature in environments in which the heating or air-conditioning load is small.

1-2-3. Unit installation

- The insulation for the low-pressure pipe between the BC controller and the outdoor/heat source unit must be at least 20 mm thick. If the unit is installed on the top floor or in a high-temperature, high-humidity environment, thicker insulation may be necessary.
- Do not have any branching points on the downstream of the refrigerant pipe header.
- When a field-supplied external thermistor is installed or when a device for demand control is used, the unit may stop abnormally or damage may occur to the electromagnetic contactor. Consult your local distributor for details.
- When indoor units employ fresh air intake, install a filter in the duct (locally procured) to remove dust from the air.
- The 4-way or 2-way Airflow Ceiling Cassette Type units that have an outside air inlet can be connected to the duct, but need a booster fan to be installed at site. Refer to the chapter "Indoor Unit" for the available range for fresh air intake volume.
- Employing fresh air intake for the indoor unit may increase the sound pressure level.
- Do not install the unit above the cooking or food processing area.

1-2-4. Noise level (Sound pressure level)

- The sound pressure level is a value measured in an anechoic room in accordance with the conventional method in JIS standard. The sound pressure level actually measured at the installation site is usually higher than the value indicated in this DATA BOOK due to the influence of ambient noise and echoes.

1-3. Precautions for outdoor unit/heat source unit

1-3-1. Installation environment

- ♦The outdoor unit with the salt-resistant specification is recommended for use in an area in which it will be exposed to salt air.
- ♦Even when the unit with the salt-resistant specification is used, it is not completely protected against corrosion. Be sure to follow the directions or precautions described in the Instruction Book and Installation Manual for installation and maintenance. The salt-resistant specification is referred to in the guidelines published by JRAIA (JRA9002).
- ♦Install the unit in an area where the flow of discharge air is not obstructed. If the flow of discharge air is obstructed, short-cycling of discharge air may occur.
- ♦Provide proper drainage around the base of the units; condensation may collect and drip from outdoor units. Provide water-proofing protection to the floor when installing the unit on the rooftop.
- ♦In regions where snowfall can be expected, install the unit so that the outlet faces away from the direction of the wind, and install a snow guard to protect the unit from snow. Install the unit on a base approximately 50 cm higher than the expected snowfall. Close the openings for pipes and wiring, because the ingress of water and small animals may cause equipment damage. If a SUS snow guard is used, refer to the Installation Manual that comes with the snow guard and be careful with the installation to avoid the risk of corrosion.
- ♦When the unit is expected to operate continuously for a long period of time at outside air temperatures of below 0°C, take appropriate measures, such as the use of a unit base heater, to prevent ice forming on the unit base. (Not applicable to the PUMY-Series)
- ♦Install the snow guard so that the outlet/inlet faces away from the direction of the wind.
- ♦When approximately 50 cm or more of snow accumulates on the snow guard, remove the snow from the guard. Install a roof that is strong enough to withstand loads caused by snow in areas where snow accumulates.
- ♦Provide proper protection around the outdoor units in places such as schools to avoid the risk of injury.
- ♦A cooling tower and heat source water circuit should be a closed circuit so that water is not exposed to the atmosphere. When a tank is installed to ensure that the circuit has enough water, minimize the contact with outside air to ensure that the oxygen dissolved in the water is 1 mg/L or less.
- ♦Install a strainer (50 mesh or more recommended) on the water pipe inlet on the heat source unit.
- ♦Interlock the heat source unit and water circuit pump.
- ♦Note the following to prevent the freezing and bursting of pipes when the heat source unit is installed in an area where the ambient temperature can be 0°C or below.
 - ♦Keep the water circulating to prevent it from freezing when the ambient temperature is 0°C or below.
 - ♦Before a long period of non-use, be sure to purge the water from the unit.
- ♦The salt-resistant unit is resistant to salt corrosion, but not salt-proof.

Please note the following when installing and maintaining outdoor units in a marine environment.

 1. Install the salt-resistant unit in an area in which it is not directly exposed to sea breezes, and minimize exposure to salt water mist.
 2. Avoid installing a sun shade over the outdoor unit, so that rain will wash away salt deposits off the unit.
 3. Install the unit horizontally to ensure proper water drainage from the base of the unit. Accumulation of water in the base of the outdoor unit will significantly accelerate corrosion.
 4. Periodically wash salt deposits off the unit, especially when the unit is installed in a coastal area.
 5. Repair all noticeable scratches after installation and during maintenance.
 6. Periodically check the unit, and apply an anti-rust agent and replace corroded parts as necessary.
- ♦Do not install the units in a place where iron or copper powders fly around, in an acidic or alkaline atmosphere, or where a large amount of sand containing saline particles accumulates because these factors can corrode the aluminum pipes.

1-3-2. Circulating water

- ♦Regularly check the quality of the water in the heat source unit, following the guidelines published by JRAIA (JRA-GL02-1994).
- ♦A cooling tower and heat source water circuit should be a closed circuit so that water is not exposed to the atmosphere. When a tank is installed to ensure that the circuit has enough water, minimize the contact with outside air to ensure that the oxygen dissolved in the water is 1 mg/L or less.

1-3-3. Unit characteristics

- ♦When the Thermo ON and OFF is frequently repeated on the indoor unit, the operating status of outdoor/heat source units may become unstable.

1-3-4. Related equipment

- ♦Provide grounding in accordance with the local regulations.

1-3-5. Noise level (Sound pressure level)

- ♦The sound pressure level is a value measured in an anechoic room in accordance with the conventional method in JIS standard. The sound pressure level actually measured at the installation site is usually higher than the value indicated in this DATA BOOK due to the influence of ambient noise and echoes.

Valve operation noise and refrigerant flow noise may occur from inside the outdoor unit/heat-source unit.

1-4. Precautions for control-related items

1-4-1. Product specification

- ♦To introduce the MELANS system, a consultation with us is required in advance. Especially to introduce the electricity charge-apportioning function or energy save function, further detailed consultation is required. Consult your local distributor for details.
- ♦Billing calculation for AE-200E/AE-50E/EW-50E, or the billing calculation unit is unique and based on our original method. (Backup operation is included.) It is not based on the metering method, and do not use it for official business purposes. It is not the method that the amount of electric power consumption (input) by air conditioner is calculated. Note that the electric power consumption by air conditioner is apportioned by using the ratio corresponding to the operation status (output) for each air conditioner (indoor unit) in this method.
- ♦In the apportioned billing function for AE-200E/AE-50E and EW-50E, separate watt-hour meters should be used for A-control units, K-control units, and CITY MULTI packaged air conditioners. It is recommended that an individual watt-hour meter should be used for large-capacity indoor units (with two or more addresses).
- ♦When using the peak cut function on the AE-200E/AE-50E or EW-50E, note that the control is performed once every minute and it takes time to obtain the effect of the control. Take appropriate measures such as lowering the criterion value. Power consumption may exceed the limits if the AE-200E/AE-50E or EW-50E malfunctions or stops. Provide a back-up remedy as necessary.
- ♦The controllers cannot operate while the indoor unit is OFF. (No error)
Turn ON the power to the indoor unit when operating the controllers.
- ♦When using the interlocked control function on the AE-200E/AE-50E/EW-50E/PAC-YG66DCA or PAC-YG63MCA, do not use the control for fire prevention or security. (This function should never be used in a way that would put people's lives at risk.) Employ any methods or circuits that allow ON/OFF operation using an external switch in case of failure.

1-4-2. Installation environment

- ♦Surge protection may be required for the transmission line in areas where lightning strikes occur frequently.
- ♦The receiver for a wireless remote controller may not work properly due to the effect of general lighting. Leave a space of at least 1 m between the general lighting and the receiver.
- ♦When the auto-elevating panel is used and the system is operated using a wired remote controller, install the wired remote controller in a place where all the air conditioners being controlled (at least the bottom part of them) can be seen from the wired remote controller. If not, the descending panel may cause damage or injury; be sure to use a wireless remote controller designed for use with the elevating panel (sold separately).
- ♦Install the wired remote controller (switch box) in a place where the following conditions are met.
 - ♦Where the installation surface is flat
 - ♦Where the remote controller can detect an accurate room temperature
The temperature sensors that detect the room temperature are installed both in the remote controller and in the indoor unit.
When the room temperature is detected using the sensor in the remote controller, the main remote controller is used to detect the room temperature. In this case, follow the instructions below.
 - ♦ Install the controller in a place where it is not affected by a heat source.
(If the remote controller faces direct sunlight or the direction of the supply air flow, the remote controller cannot detect the accurate room temperature.)
 - ♦ Install the controller in a place where the average room temperature can be detected.
 - ♦ Install the controller in a place where no other wires are present around the temperature sensor.
(If other wires are present, the remote controller cannot detect an accurate room temperature.)
- ♦To prevent unauthorized access, always use a security device such as a VPN router when connecting the AE-200E/AE-50E or EW-50E to the Internet.

Caution for refrigerant leakage for R410A

- 1. Caution for refrigerant leakage for R410A 2
 - 1-1. Refrigerant property 2
 - 1-2. Confirm the Critical concentration and take countermeasure 2

The installer and/or air conditioning system specialist shall secure safety against refrigerant leakage according to local regulations or standards.
The following standard may be applicable if no local regulation or standard is available.

1-1. Refrigerant property

R410A refrigerant is harmless and incombustible. The R410A is heavier than the indoor air in density. Leakage of the refrigerant in a room has possibility to lead to a hypoxia situation. Therefore, the critical concentration specified below shall not be exceeded even if the leakage happens.

• Critical concentration

Critical concentration hereby is the refrigerant concentration in which no human body would be hurt if immediate measures can be taken when refrigerant leakage happens.

Critical concentration of R410A: 0.44kg/m³
(The weight of refrigeration gas per 1 m³ air conditioning space.);

* The Critical concentration is subject to ISO5149, EN378-1.

For the CITY MULTI system, the concentration of refrigerant leaked should not have a chance to exceed the critical concentration in any situation.

1-2. Confirm the Critical concentration and take countermeasure

The maximum refrigerant leakage concentration (Rmax) is defined as the result of the possible maximum refrigerant weight (Wmax) leaked into a room divided by its room capacity (V). It is referable to Fig.1-1. The refrigerant of Outdoor/Heat source unit here includes its original charge and additional charge at the site.

The additional charge is calculated according to the refrigerant charging calculation of each kind of Outdoor/Heat source unit, and shall not be over charged at the site. Procedure 1-2-1~3 tells how to confirm maximum refrigerant leakage concentration (Rmax) and how to take countermeasures against a possible leakage.




Fig. 1-1 The maximum refrigerant leakage concentration

1-2-1. Find the room capacity (V),

If a room having total opening area more than 0.15% of the floor area at a low position with another room/space, the two rooms/space are considered as one. The total space shall be added up.

1-2-2. Find the possible maximum leakage (Wmax) in the room. If a room has Indoor unit(s) from more than 1 Outdoor/Heat source unit, add up the refrigerant of the Outdoor/Heat source units.

1-2-3. Divide (Wmax) by (V) to get the maximum refrigerant leakage concentration (Rmax).

1-2-4. Find if there is any room in which the maximum refrigerant leakage concentration (Rmax) is over 0.44kg/m³.

If no, then the CITY MULTI is safe against refrigerant leakage.

If yes, following countermeasure is recommended to do at site.

Countermeasure 1: Let-out (making V bigger)

Design an opening of more than 0.15% of the floor area at a low position of the wall to let out the refrigerant whenever leaked.

e.g. make the upper and lower seams of door big enough.

Countermeasure 2: Smaller total charge (making Wmax smaller)

e.g. Avoid connecting more than 1 Outdoor/Heat source unit to one room.

e.g. Using smaller model size but more Outdoor/Heat source units.

e.g. Shorten the refrigerant piping as much as possible.

Countermeasure 3: Fresh air in from the ceiling (Ventilation)

As the density of the refrigerant is bigger than that of the air. Fresh air supply from the ceiling is better than air exhausting from the ceiling.

Fresh air supply solution refers to Fig.1-2~4.




Fig.1-2. Fresh air supply always ON




Fig.1-3. Fresh air supply upon sensor action




Fig.1-4. Fresh air supply and refrigerant shut-off upon sensor action

Note 1. Countermeasure 3 should be done in a proper way in which the fresh air supply shall be on whenever the leakage happens.

Note 2. In principle, MITSUBISHI ELECTRIC requires proper piping design, installation and air-tight testing after installation to avoid leakage happening.

In the area should earthquake happen, anti-vibration measures should be fully considered.

The piping should consider the extension due to the temperature variation.

⚠ Warning

- Do not use refrigerant other than the type indicated in the manuals provided with the unit and on the nameplate.
 - Doing so may cause the unit or pipes to burst, or result in explosion or fire during use, repair, or at the time of disposal of the unit.
 - It may also be in violation of applicable laws.
 - MITSUBISHI ELECTRIC CORPORATION cannot be held responsible for malfunctions or accidents resulting from the use of the wrong type of refrigerant.
- Our air conditioning equipment and heat pumps contain a fluorinated greenhouse gas, R410A.

mitsubishi **ELECTRIC CORPORATION**

www.MitsubishiElectric.com